

Bugoye13.0MWRun-of-River HydropowerProject

DocumentPreparedby: CarbonLimitsAS

ContactInformation:MarkDavis,Norfund,mark.davis@norfund.no

ProjectTitle	Bugoye13.0MWRun-of-RiverHydropowerProject
Version	05
ReportID	BugoyeVCS05
DateofIssue	26/03/2013
ProjectID	UNFCCCref.no.3017,SGSref.no.CCP.VOL0889
MonitoringPeriod	7-10-2009to31-12-2010
PreparedBy	FrançoisSammuet,CarbonLimitsAS
Contact	ØvreVollgate6,0158Oslo,Norway fsa@carbonlimits.no Phone:+4748260402

TableofContents

1 ProjectDetails.....3

1.1 SummaryDescriptionofProject.....3

1.2 SectoralScopeandProjectType.....4

1.3 ProjectProponent.....4

1.4 OtherEntitiesInvolvedintheProject.....4

1.5 ProjectStartDate.....4

1.6 ProjectCreditingPeriod.....4

1.7 ProjectLocation.....4

1.8 TitleandReferenceofMethodology.....5

2 ImplementationStatus.....5

2.1 ImplementationStatusoftheProjectActivity.....5

2.2 ProjectDescriptionDeviations.....7

2.3 GroupedProject.....7

3 DataandParameters.....7

3.1 DataandParametersAvailableatValidation... ..7

3.2 DataandParametersMonitored.....11

3.3 DescriptionoftheMonitoringPlan.....15

4 QuantificationofGHGEmissionReductionsandRemovals.....18

4.1 BaselineEmissions.....18

4.2 ProjectEmissions.....19

4.3 Leakage.....21

4.4 SummaryofGHGEmissionReductionsandRemovals.....21

5 AdditionalInformation.....23

1 PROJECT DETAILS

1.1 Summary Description of Project

Tronder Power Ltd has implemented the Bugoye hydropower project, a run-of-river plant. The project is located at the foot of the Rwenzori Mountains in the Kasese District, Western Uganda. The project diverts water from the river Isya and runs via a five kilometer-long canal into a 950 meter-long penstock with a head of 160 meters. After passing through two turbines, the water is discharged to the Mubuku River. The project uses the remaining head between two existing hydropower plants; Mubuku 1, upstream of the project site, and Mubuku 3, downstream of the project site. The hydropower plant is connected to the national grid via a 6 km long transmission line routed to the Nkenda substation. The primary purpose of the project is to supply affordable renewable energy to the population of Uganda.

Implementation of the project consists of construction of the following main items:

- A main intake and sedimentation basin where water from the river Mubuku is diverted through a 1,0 km canal to the river Isya;
- A second intake and sedimentation basin at the river Isya, where tailrace water from the Mubuku 1 power station is added to the system;
- An open concrete headrace canal with total length of 4.0 km;
- A spillway of approximately 1 km, a forebay and 950 m penstock;
- Power house with two horizontal 7.228 MW Francis turbines (manufactured by Mavel) and two 7.140 MW generators (manufactured by manufacturer EL PROM ZEM);
- Tailrace canal back to the Mubuku river;
- Switch station and a 33 kV transmission line of 6.5 km;
- An emergency diesel generator.

Total electricity production for year 2009 after official commissioning is based on 1,620.7 operating hours¹ for unit 1 and 1,880.2 operating hours for unit 2, and estimated to be 15,805 MWh², which is sold to the Uganda Electricity Transmission Company Limited (UETCL).

Annual electricity generation for year 2010 is based on 6,682.1 operating hours for unit 1 and 4,694.4 operating hours for unit 2; The generated 66,359 MWh is sold to the Uganda Electricity Transmission Company Limited (UETCL) as per the power purchase agreement dated 28th February 2008.³

Below is a summary of key events related to the project activity and related infrastructure:

¹The number of operating hours for year 2009 is calculated by subtracting the number of down-time hours from 2064 till end of the year) for each unit.

²The total annual generation is calculated by summing up the monthly generation reports which are confirmed by the purchaser.

³The number of operating hours for year 2010 is calculated by subtracting the number of down-time hours from 8760 for each unit.

Date(s):	Description of event:
January 2008	Start of construction of the Bugoye 13 .0 MW Run-of-River Hydropower plant
7 October 2009	Commissioning of the Bugoye 13.0 MW Run-of-River Hydropower plant
1 January 2011	Registration date for the "Bugoye 13 .0 MW Run-of-River Hydropower Project" CDM project activity
1 January 2011	Start of CDM monitoring period

During Monitoring Period No. 00 (from 07/10/2009 to 31/12/2010), the net emission reductions achieved is calculated to be **51,177 tCO₂e** in accordance with the formulae presented in Section B.6.3 of the registered PDD (see Section E below for detailed calculations).

1.2 Sectoral Scope and Project Type

1. Energy (renewable/non-renewable)

1.3 Project Proponent

Tronder Power Ltd.
 PO Box 11103, Crusader House, 3 Portal Avenue, Kampala, Uganda
 Tel: +256(41)4340243 - Fax: +256(41)4257861
 Email: post@tronderpower.com

Contact names: Annicent Busingye (General Manager), Losio Lemuresuk Chaplin (Operational Manager)

1.4 Other Entities Involved in the Project

Not Applicable

1.5 Project Start Date

7 October 2009

1.6 Project Crediting Period

7 October 2009 to 31 December 2010. Total number of years: 1 year, 2 months, 25 days

1.7 Project Location

The project is located in the Bugoye Sub County which is situated around 15 km north of Kasese town, in Kasese District in the Western region of Uganda, 400 km drive from Kampala, in the Republic of Uganda.

Coordinates for the main project infrastructure are given below:

Project coordinates		
Diversion intake:	020°02.30"N	3004°27.76"E
Intake:	019°46.58"N	3004°16.27"E
Forebay:	018°51.93"N	3005°43.25"E
Power station:	018°25.80"N	3005°57.57"E
Tailrace outlet:	018°27.94"N	3006°07.20"E

1.8 Title and Reference of Methodology

The project comes under AMSType I – Renewable Energy Project and Category I.D.-Grid connected renewable electricity generation (version 15).

2 IMPLEMENTATION STATUS

2.1 Implementation Status of the Project Activity

Commissioning date of the Bugoye 13.0 MW Run-of-River Hydropower was 7 October 2009, although supply of electricity to the UETCL grid started in September 2009 (test runs of the plant prior to official commissioning). All operations are at one single site and within an integrated physical facility.

The plant has been operating continuously since September 2009 to the present day, with the exception of operational and unanticipated shutdowns, which are fully reported in the “Downtime reports” for each year.

During the monitoring period, the hydropower plant has been operating continuously, with the exception of operational and unanticipated shutdowns, which are fully reported in the “Downtime reports” for 2009 and 2010. In total, during 2009, 143 and 91 downtimes were recorded for Turbine-Generator group 1 (TG1) and Turbine-Generator group 2 (TG2) respectively. During 2010, 614 and 409 downtimes were recorded for Turbine-Generator group 1 (TG1) and Turbine-Generator group 2 (TG2) respectively. It should be noted however that downtimes are recorded over 24 hour periods, so the same event which spans two separate days is recorded as two separate events. Downtimes are divided into five different categories:

- Forced outage of plant (FP)
- Scheduled outage of plant (SP)
- Forced outage of grid (FG)
- Scheduled outage of grid (SG)
- Force majeure (FM) e.g. low water level in the river

Figure 1 below indicates a simple single-line diagram of the project activity with the main monitoring points.

Figure 1: Project single-line diagram




Table I summarizes the number and category of downtime events for 2009, and Table II summarizes the number and category of downtime events for 2010.

Table I: Number and category of downtime events for 2009

Category of event	Unit	
	TG1	TG2
Forced outage of plant	66	40
Scheduled outage of plant	10	18
Forced outage of grid	11	9
Scheduled outage of grid	0	0
Force majeure	56	24
Total	143	91

Table II: Number and category of downtime events for 2010

Category of event	Unit	
	TG1	TG2
Forced outage of plant	360	192
Scheduled outage of plant	72	43
Forced outage of grid	110	57
Scheduled outage of grid	0	1
Force majeure	72	116
Total	614	409

The downtime reports for 2009 and 2010 are provided as an annex, and detail the date and time of each event, duration, type (category), equipment affected, description of problem, actions taken and production loss.

The overall electricity production (as supplied to UETCL) totaled 15,805 MWh and 66,359 MWh during 2009 and 2010 respectively. Electricity production during 2009 therefore amounted to 26% of the planned annual production (82,000 MWh), which considering that the plant only started operation and delivery of electricity to the grid in the month of September, operations at the plant can be considered to be consistent with planned production. Electricity production during 2010

amounted to approximately 81% of the planned annual production (82,000 MWh). This lower than planned production was primarily due to a significant number of plant outages.

No events during the monitoring period affected the applicability of the methodology.

2.2 Project Description Deviations

With respect to the registered monitoring plan, the following should be highlighted:

- Calibration of the main and check meters was stated in the CDM-PDD as having to be undertaken annually. Since the project has been implemented it has become apparent that there is no relevant expertise in Uganda needed to undertake the calibration of the said meters. The meter manufacturers (CEWE instruments) have confirmed that the installed meters, following initial test and calibration, do not require any further or regular calibration. For this reason, annual calibration, which is not considered to be required and which cannot be undertaken locally, has not been implemented. It should be mentioned that there has been a continuous check of the readings of the Main Meter vis-à-vis the Check Meter in order to ensure the accuracy of the Main Meter. The meter readings have been performed in the presence of the UETCL representatives (as purchaser of the generated electricity) and all of the invoices have been approved by UETCL and paid.
- The overall responsibility for monitoring and reporting issues lies with Tronder Power Ltd and Erling Legran, the Managing Director of the company. Mr Erling Legran replaces Mr Jon Einar Værnes who was originally named in the CDM-PDD.

2.3 Grouped Project

Not applicable.

3 DATA AND PARAMETERS

3.1 Data and Parameters Available at Validation

Parameters for the “Tool to calculate the emissions factor for an electrical system”

Data/Parameter:	FC_{i,m,y}
Data unit:	Mass or volume unit
Description:	Amount of fossil fuel type <i>i</i> consumed by power plant <i>m</i> in year <i>y</i> (for calculation of EF _{EL,m,y})
Source of data used:	Utility official publications, collected from UETCL, See Annex 3

Value applied:	For operating margin:		
			FC _{i,m,y} , 1000 litres
	2005	LGGO Aggreko1	37,724
		Kiira Aggreko2	-
	2006	LGGO Aggreko1	83,970
		Kiira Aggreko2	13,203
	2007	LGGO Aggreko1	73,989
		Kiira Aggreko2	70,445
	For build margin:		
			FC _{i,m,y} , 1000 litres
Powerplants	Start of operation		
Kakira Sugar Works (KSW)	2007	-	
50*KIIRA Aggreko	2006	70,445	
20*LGGO Aggreko	2005	29,596	
Total		100,051	
Justification of the choice of data or description of measurement methods and procedures actually used:	<ul style="list-style-type: none"> • OM: Most recent three historical years for which data is available at the time of submission of the CDM-PDD to the DOE for validation (2005-2007) • BM: For the first crediting period, once <i>ex-ante</i>, following the guidance included in step 6. Sample group of power units according to option (b) representing 20.44% of system generation 		
Any comment:	Calculation of the simple adjusted OM in cases where fuel consumption data is available for all powerplants /units		

Data/Parameter:	EF _{CO₂,i,y}
Data unit:	tCO ₂ /TJ
Description:	CO ₂ emission factor of fossil fuel type <i>i</i> in year <i>y</i>

Source of data used:	<p>The following data sources may be used if the relevant conditions apply:</p> <table border="1" style="width: 100%;"> <thead> <tr> <th style="text-align: left;">Data source</th> <th style="text-align: left;">Conditions for using the data source</th> </tr> </thead> <tbody> <tr> <td>Values provided by the fuel supplier of the power plants in invoices</td> <td>If data is collected from power plant operators (e.g. utilities)</td> </tr> <tr> <td>Regional or national average default values</td> <td>If values are reliable and documented in regional or national energy statistics/energy balances</td> </tr> <tr> <td>IPCC default values at the lower limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories</td> <td></td> </tr> </tbody> </table> <p>Neither values from fuel suppliers nor regional/national values are available, so the IPCC default values are used.</p>	Data source	Conditions for using the data source	Values provided by the fuel supplier of the power plants in invoices	If data is collected from power plant operators (e.g. utilities)	Regional or national average default values	If values are reliable and documented in regional or national energy statistics/energy balances	IPCC default values at the lower limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	
Data source	Conditions for using the data source								
Values provided by the fuel supplier of the power plants in invoices	If data is collected from power plant operators (e.g. utilities)								
Regional or national average default values	If values are reliable and documented in regional or national energy statistics/energy balances								
IPCC default values at the lower limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories									
Value applied:	72.6 tCO ₂ /TJ								
Justification of the choice of data or description of measurement methods and procedures actually used:	IPCC standard for diesel (lower limit of uncertainty at 95%) used as values are not available by fuel suppliers and no reliable national default values are available								
Any comment:	--								

Data/Parameter:	EG_{m,y}, EG_{k,y}
Data unit:	MWh
Description:	Net electricity generated and delivered to the grid by power plant/unit <i>m</i> or <i>k</i> in year <i>y</i>
Source of data used:	Most recent 3 years data (2005 - 2007) collected from Electricity Regulatory Authority (ERA) and Uganda Electricity Transmission Company Limited (UETCL), see Annex 3.

Value applied:	For operating margin:		
		Gen(EG _{m,y}), MWh	
	2005	LGGO Aggreko1	140,911
		Kiira Aggreko2	-
	2006	LGGO Aggreko1	319,320
		Kiira Aggreko2	50,137
	2007	LGGO Aggreko1	272,995
		Kiira Aggreko2	266,437
Justification of the choice of data or description of measurement methods and procedures actually used:	For build margin:		
		Gen(EG _{m,y}), MWh	
	Powerplants	Start of operation	
	Kakira Sugar Works (KSW)	2007	1,828
	50*KIIRA Aggreko	2006	266,437
	20*LGGO Aggreko	2005	109,198
	Total		377,463
Any comment:	--		

Data/Parameter:	NCV _{i,y}								
Unit:	GJ per tonne								
Description:	Weighted average net calorific value of diesel fuel in year y								
Source of data:	<table border="1"> <thead> <tr> <th>Datasource</th> <th>Conditions for using the datasource</th> </tr> </thead> <tbody> <tr> <td>a) Values provided by the fuel supplier in invoices</td> <td>This is the preferred source if the carbon fraction of the fuel is not provided (Option A)</td> </tr> <tr> <td>b) Measurements by the project participants</td> <td>If a) is not available</td> </tr> <tr> <td>c) Regional or national default values</td> <td>If a) is not available These sources can only be used for liquid fuels and should be based on well documented, reliable</td> </tr> </tbody> </table>	Datasource	Conditions for using the datasource	a) Values provided by the fuel supplier in invoices	This is the preferred source if the carbon fraction of the fuel is not provided (Option A)	b) Measurements by the project participants	If a) is not available	c) Regional or national default values	If a) is not available These sources can only be used for liquid fuels and should be based on well documented, reliable
Datasource	Conditions for using the datasource								
a) Values provided by the fuel supplier in invoices	This is the preferred source if the carbon fraction of the fuel is not provided (Option A)								
b) Measurements by the project participants	If a) is not available								
c) Regional or national default values	If a) is not available These sources can only be used for liquid fuels and should be based on well documented, reliable								

		sources.
	d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.2 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	ifa) is not available
	Neither values from fuel suppliers nor regional/national values are available, so the IPCC default values are used.	
Value of data	41.4 TJ/Gg	
Brief description of measurement methods and procedures to be applied:	Measurement method not required as d) chosen	
QA/QC procedures to be applied (if any):	Any future revision of the IPCC Guidelines will be taken into account	
Any comment:	--	

Data/Parameter:	EF_{CO2}
Unit:	tCO ₂ e/MWh
Description:	CO ₂ Emission Factor for the electricity grid
Source of data:	As determined in the PDD for the “Bugeye 13.0 MW Run-of-River Hydropower Project”, and according to the “Tool to calculate the emission factor for an electricity system” (version 02)
Value of data	0.62286 tCO ₂ /MWh
Brief description of measurement methods and procedures to be applied:	Used for Baseline emission calculations. According to methodology AMSI.D., the baseline emissions are the product of electrical energy produced by the renewable generating unit multiplied by an emission factor: $BE_y = EG_{BL,y} * EF_{CO2}$
QA/QC procedures to be applied (if any):	None
Any comment:	None

3.2 Data and Parameters Monitored

Data Unit/Parameter:	EG_y
Data unit:	MWh

Description:	Net electricity supplied by the project to the grid								
Source of data:	Measurement of energy output meter at the 33kV side of the transformer that connects to the 33kV line that evacuates the power to the main grid.								
Description of measurement methods and procedures to be applied:	Automatic metering of electricity supplied to UETCL grid through main and check meter, meters read each month. Representatives from UETCL and UMEME, together with a representative from Tronder Power (TPL), retrieve historical data for the previous month from each meter by using an optical eye connected to a laptop and the meter.								
Frequency of monitoring/recording:	Hourly measurements and monthly recordings of net electricity supplied by the project activity to the grid will be taken.								
Value monitored:	82,164.6 MWh								
Monitoring equipment:	<p>Specified information for main meter given below:</p> <table border="1"> <tr> <td>Type</td> <td>Cewe Prometer R, 57/99-120/208V, 5A (5mA–10A), 50Hz, 0.2s, Aux: 40-276 VAC/40-300VDC (single), I/O: 4 inputs and 6 outputs, Com: No communication</td> </tr> <tr> <td>Accuracy class</td> <td>0.2s</td> </tr> <tr> <td>Serial number</td> <td>1641802</td> </tr> <tr> <td>Date of last calibration</td> <td>10.07.2008</td> </tr> </table>	Type	Cewe Prometer R, 57/99-120/208V, 5A (5mA–10A), 50Hz, 0.2s, Aux: 40-276 VAC/40-300VDC (single), I/O: 4 inputs and 6 outputs, Com: No communication	Accuracy class	0.2s	Serial number	1641802	Date of last calibration	10.07.2008
Type	Cewe Prometer R, 57/99-120/208V, 5A (5mA–10A), 50Hz, 0.2s, Aux: 40-276 VAC/40-300VDC (single), I/O: 4 inputs and 6 outputs, Com: No communication								
Accuracy class	0.2s								
Serial number	1641802								
Date of last calibration	10.07.2008								
QA/QC procedures to be applied:	Measurement results shall be cross-checked with records for sold electricity (to UETCL).								
Calculation method:	Not applicable								
Any comment:	None								

Data Unit/Parameter:	FC_{i,j,y}
Data unit:	tonne/year
Description:	Quantity of diesel fuel used by site diesel generator during year
Source of data:	On-site measurement
Description of measurement methods and procedures to be applied:	Counter on the diesel generator control panel (run-hours meter) monitoring continuously the number of hours the diesel generator has been running multiplied by the consumption rate of the generator (according to manufacturer's specifications).
Frequency of monitoring/recording:	Continuous
Value monitored:	0.846 tonnes/year (2009) 1.830 tonnes/year (2010)
Monitoring equipment:	Fuel counter on control panel (volume meter) monitoring continuously
QA/QC procedures to be applied:	The consistency of metered fuel consumption quantities will

applied:	becross-checkedbyanannualenergybalan cethatisbased onpurchasedquantitiesandstockchanges. Verifiedagainstannualdieselfuelpurchaseinvoic esfromthe financialrecords.
Calculationmethod:	Notapplicable
Anycomment:	Willonlybeestimatedifemissionsfr omthedieselgenerator equalorexceed1%ofbaselineemissions.

DataUnit/Parameter:	NCV_{i,y}	
Dataunit:	GJpertonne	
Description:	Weightedaveragenetcalorificvalueo fdieselfuelinyeary	
Sourceofdata:	Datasource	Conditionsforusingthe datasource
	a)Valuesprovidedbythefuel supplierininvoices	Thisisthepreferred sourceifthecarbon fractionofthefuelisnot provided(OptionA)
	b)Measurementsbythe projectparticipants	Ifa)isnotavailable
	c)Regionalornationaldefault values	Ifa)isnotavailable Thesesourcescanonly beusedforliquidfuels andshouldbebasedon welldocumented,reliable sources.
	d)IPCCdefaultvaluesatthe upperlimitoftheuncertainty ata95%confidenceinterval asprovidedintable1.2of Chapter1ofVol.2(Energy)of the2006IPCCGuidelineson NationalGHGInventories	Ifa)isnotavailable
	Neithervaluesfromfuelsuppliernorregional/national valuesareavailable,sotheIPCCdefaultvaluesare used.	
Descriptionofmeasurement methodsandprocedures to beapplied:	Measurement method not required as option d) above is chosen (IPCC default values at the upper limit of the uncertaintyata95%confidenceintervalasprovide dintable 1.2 of Chapter1 of Vol. 2 (Energy) of the 2006 IPCC GuidelinesonNationalGHGInventories)	
Frequencyof monitoring/recording:	Notapplicable	

Value monitored:	43.3Tj/Gg
Monitoring equipment:	Not applicable
QA/QC procedure to be applied:	Any future revision of the IPCC Guidelines will be taken into account
Calculation method:	Not applicable
Any comment:	None

Data Unit/Parameter:	EF _{CO₂,i,y}	
Data unit:	tCO ₂ /GJ	
Description:	Weighted average CO ₂ emission factor of diesel fuel in year y	
Source of data:	Datasource	Conditions for using the datasource
	a) Values provided by the fuel supplier in invoices	This is the preferred source if the carbon fraction of the fuel is not provided (Option A)
	b) Measurements by the project participants	If a) is not available
	c) Regional or national default values	If a) is not available These sources can only be used for liquid fuels and should be based on well documented, reliable sources.
	d) IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories	If a) is not available
	Neither values from fuel supplier nor regional/national values are available, so the IPCC default values are used.	
Description of measurement methods and procedures to be applied:	Measurement method not required as option d) above is chosen (IPCC default values at the upper limit of the uncertainty at a 95% confidence interval as provided in table 1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories)	

	1.4 of Chapter 1 of Vol. 2 (Energy) of the 2006 IPCC Guidelines on National GHG Inventories)	C
Frequency of monitoring/recording:	Not applicable	
Value monitored:	7.48 tCO ₂ /GJ	
Monitoring equipment:	Not applicable	
QA/QC procedure to be applied:	Any future revision of the IPCC Guidelines will be taken into account	
Calculation method:	Not applicable	
Any comment:	None	

3.3 Description of the Monitoring Plan

The monitoring consists of metering the electricity generated by the renewable technology in line with "I.D. Grid connected renewable electricity generation" and the "Tool to calculate the emission factor for an electricity system".

The monitoring plan ensures that the true, maintainable and measurable GHGs of CDM project can be monitored, recorded and reported. This is the key procedure to determine the CERs. According to monitoring plan, monitoring system should be reliable, conservative and comprehensive; this system should have the function of data evaluation, measurement, and collection and monitoring.

CDM Manager

The overall responsibility for quality assurance of monitoring and reporting issues lies with the CDM Manager in Trønder Energi Norway. If errors or omissions in the primary data required as part of the CDM monitoring are detected during final QA/QC by CDM Manager in Trønder Energi Norway, the CDM Manager is responsible for initiating a dialogue with the CDM Director in Kampala to handle these issues, ensuring a conservative approach is selected and taking into account guidance in the relevant CDM methodology, the registered CDM-PDD and any other CDMEB guidance.

CDM Director

The CDM Director in Kampala is responsible for proper quality assurance of all primary data to be utilized for CDM monitoring purposes. Any issues identified regarding primary data used for CDM monitoring detected during initial quality assurance shall without delay be communicated to the CDM Coordinator on site until the issue is resolved.

On a periodical basis the CDM Director shall, subject to having undertaken proper quality control, submit an electronic copy of the consolidated CDM reporting template to the CDM Manager of Trønder Power in Norway.

At the end of each monitoring period, the CDM Director is responsible for reviewing the final dataset to be used as basis for CDM calculations for the monitoring period in consideration. This includes undertaking any relevant consistency checks vis-à-vis operational values. Following finalization of the complete dataset as contained in the CDM Monitoring Model (in excel format), the relevant data for the monitoring period in consideration shall be extracted into a CDM

verification reporting template. Calculations of CDM M parameter values, Baseline Emissions, Project Emissions and Emission Reductions relevant for the monitoring period shall be undertaken in line with CDM requirements and presented transparently in the CDM verification reporting template.

The CDM Director is responsible for organizing quarterly internal audits with a pre-notification of the CDM Coordinator. The internal audits include overall quality control of the Monitoring System and ensuring that all the internal specific CDM procedures are followed closely. On an annual basis, the CDM Managers shall be involved in the internal audits as well.

CDM Coordinator

The CDM Coordinator on Bugoye is responsible for measurement and recording of all the primary data, including electricity exports to the grid, back-up diesel consumption, down-time events, and all of the supporting measurements and records.


Responsibility holders for the Monitoring Period under consideration in this report

CDM Manager in TrønderEnergi Norway: Mr. Erling Legran (Managing Director)

CDM Director in Kampala: Mrs. Annicent Busingye (General Manager of Tronder Power in Kampala)

CDM Coordinators in Bugoye Power Plant: Mr. Losio Chaplin Lemuresuk (Operational Manager in Bugoye Power Plant)

Figure 2 summarizes, in a visual manner, the monitoring system and how the CDM responsibilities are distributed. Specific CDM procedures have been developed for all of the personnel involved in monitoring to describe the responsibilities and ensure the properness of implementation of the Monitoring Plan.



Meter

One main meter and one check meter system has been installed. The main and check meter, physically installed in the control room at the powerhouse, measure the power flow at the 33 kV side of the transformer (i.e. the output of the transformer) that connects to the 33 kV line that evacuate the power to the main grid.

There is only one line and the meter will be a two-way hourly meter, so each meter reading will be a net reading of power exported/imported to the power station. The main meter and the check meter system installed, owned and maintained by TPL is designed such that the overall error of the installation, (including instrument transformers, wiring, and metering instruments) shall be no greater than 0.2% over the equivalent range.

All instruments are of the flush mounting type and fitted with non-reflecting glass according to the relevant international standards.

As the main meter, TPL has installed a Cewe Prometer R supplied by Cewe Instrument AB. The Cewe Prometer R is a Precision meter in class 0.2S⁴. The serial number for the main meter is 1641802.

As the check main meter, TPL has installed a Cewe Prometer R supplied by Cewe Instrument AB. The Cewe Prometer R is a Precision meter in class 0.2S. The serial number for the main meter is 1641801.

Testing/calibration

Testing has been carried out by qualified personnel using test equipment with a rated error of $\pm 0.1\%$ or better according to national standards and IEC standards 60521. The test has been carried out for both main and the check meter. The EMH calibration stations are tested by CEWE instruments every 3rd month with EMHKOM 200.3. The EMHKOM 200.3 Comparator is tested at SP, Swedish National Testing and Research Institute, every 12 months. Test certificates for both main and check meters are provided with the monitoring report.

Recording

Main and Check meter is read at 12:00 on the 2nd day of each month. Representatives from UETCL and UMEME, together with a representative from Trønder Power (TPL), retrieve historical data for the previous month from each meter by using an optical eye connected to a laptop and the meter. The data is saved as an excel file. A copy of the data is copied on to a hard copy which is signed by the representatives from UETCL, TPL and UMEME.

Reporting

All readings are reported to UETCL and reading from main meter is used for preparing the invoice. All data required for verification and issuance will be kept for at least two years after the end of the crediting period or the last issuance of CERs of this project, whichever occurs later. The invoiced documentation can be used to quality assure report.

Emergency

If the meter is found to be inaccurate for more than two-tenths of a percent ($\pm 0.2\%$) or otherwise function improperly, the Trønder Power and UETCL shall jointly prepare an estimate for correct reading.

Training

Key staff have been trained in Norway at the facilities of one of the investors (Trønder Energi). Before the project was put into operation, the staffs received a training program on operation and metering, both on general operation of hydropower plant and specifically on CDM.

With respect to the registered monitoring plan, the following should be highlighted:

⁴For more information, see <http://www.ceweinstrument.se/>

- Calibration of the main and check meters was state undertaken annually. Since the project has been imp d in the CDM-PDD as having to be implemented it has become apparent that there is no relevant expertise in Uganda needed to undertake the calibration of the said meters. The meter manufacturers (CEWE instruments) have confirmed that the installed meters, following initial test and calibration, do not require any further or regular calibration. For this reason, annual calibration, which is not c onsidered to be required and which cannot be undertaken locally, has not been implemented.
- The overall responsibility for monitoring and repo rting issues lies with Tronder Power Ltd and Erling Legran, the Managing Director of the company . Mr Erling Legran replaces Mr Jon Einar Værnes who was originally named in the CDM-PD D.

4 QUANTIFICATION OF GHG EMISSION REDUCTIONS AND REM OVALS

4.1 Baseline Emissions

According to the CDM methodology AMSI.D., the base line emissions are the product of electrical energy baseline $EG_{BL,y}$ expressed in kWh of electricity produced by the re newable generating unit multiplied by an emission factor:

$$BE_y = EG_{BL,y} * EF_{CO_2}$$

Where:

BE_y Baseline Emissions in year, tCO₂

$EG_{BL,y}$ Energy baseline in year, kWh

EF_{CO_2} CO₂ Emission Factor in year, tCO₂e/kWh.⁵

Table below summarizes the amount of generated elec tricity per month and thus the baseline emissions.

SUMMARY OF BASELINE EMISSION REDUCTION CALCULATIONS			
	Generated Electricity EG_y	Uganda GEF EF_{CO_2}	Baseline ERs
	<i>MWh</i>	<i>(tCO₂/MWh)</i>	<i>(tCO_{2e})</i>
October 2009⁶	4,073.29	0.62286	2,537
November 2009	5,977.67	0.62286	3,723
December 2009	5,754.42	0.62286	3,584
January 2010	4,671.56	0.62286	2,910
February 2010	1,836.12	0.62286	1,144
March 2010	6,366.81	0.62286	3,966
April 2010	6,479.74	0.62286	4,036

⁵The CO₂ Emission Factor of the grid was calculated during the validation of the CDM-PDD and could be used for the entire crediting period of the project. The calculated value is 0.62286 tCO₂/MWh.

⁶Please note that the start date of the monitoring period is from October 7, 2009 and hence the electricity generation and consequently emission reduction for the month of October 2009 is considered from October 7, 2009 to October 31, 2009.

May2010	3,639.54	0.62286	2,267
June2010	3,759.50	0.62286	2,342
July2010	4,501.76	0.62286	2,804
August2010	5,117.77	0.62286	3,188
September2010	6,795.41	0.62286	4,233
October2010	8,206.91	0.62286	5,112
November2010	8,769.53	0.62286	5,462
December2010	6,214.57	0.62286	3,871

The Emission Factor or can

be calculated in a transparent and conservative manner:

a) A combined margin (CM), consisting of the combined margin (BM) according to the procedures prescribed for an electricity system" (version 02); OR

b) The weighted average emissions (in kg CO₂e/kWh) of the current generation mix. The data of the year in which project generation occurs must be used.

For this project, option a) above was chosen as the entire crediting period. The Emission Factor was presented in the PDD for the registered project.

According to the formula above, baseline emissions

$$BE_y = 82,164.6 * 0.62286$$

$$BE_y = 51,177 \text{ tCO}_2\text{e}$$

neras:

ation of operating margin (OM) and build in the "Tool to calculate the emission factor

used.

will give a more accurate emission factor for s calculated to be 0.62286 tCO₂e/MWh; as

are calculated as follows:

4.2 Project Emissions

As described in the CDM-PDD, as the Bugoye run-of-river hydro power project does not lead to any emissions due to the operation of geothermal power plants, or from water reservoirs, project emissions, PE_y, should equal 0.

As noted in the CDM-PDD, however, a diesel generator has been installed in the plant to provide emergency power in the event of any grid blackouts. The generator was expected to be operating for less than 100 hours a year. Based on a conservative assumption that the generator operates for 100 hrs/yr, it was calculated that the emission from this source will amount to 19.37 tCO₂e/yr, which accounts for less than 0.05% of baseline emissions (see annex 6 of the CDM-PDD).

Nevertheless, fuel consumption of the diesel generator was to be monitored, and if running hours, and therefore fuel consumption, were to increase to a level where emissions from this source will be equal to or exceed 1% of baseline emissions, the electricity generation metered will be adjusted by deducting the electricity generation from fossil fuels using the specific fuel consumption and the quantity of fossil fuel used, as prescribed in AMSI.D.v15.

The estimation of emissions from the diesel generator or presented in Annex 6 of the CDM-PDD is based on a conservative assumption that typical fuel consumption for the said diesel generator is 4.8 USg/hr, i.e. assumption is made that fuel consumption by diesel generator is over 3.5 times that proposed by manufacturer. Running hours for the diesel generator amounted to 51 hours during g2009 and 110.3 hours during 2010, giving a total of 161.3 hours during the totality of the monitoring period (i.e. 07/10/2009 to 31/12/2010). The estimate made in the CDM-PDD showed that if the generator ran for 100 hrs/yr, total CO₂

iver hydro power project does not lead to any emissions due to the operation of geothermal power plants, or from water reservoirs, project emissions, PE_y, should equal 0.

has been installed in the plant to provide emergency power in the event of any grid blackouts. The generator was expected to be operating for less than 100 hours a year. Based on a conservative assumption that the generator operates for 100 hrs/yr, it was calculated that the emission from this source will amount to 19.37 tCO₂e/yr, which accounts for less than 0.05% of baseline emissions (see annex 6 of the CDM-PDD).

and therefore fuel consumption, were to increase to a level where emissions from this source will be equal to or exceed 1% of baseline emissions, the electricity generation metered will be adjusted by deducting the electricity generation from fossil fuels using the specific fuel consumption and the quantity of fossil fuel used, as prescribed in AMSI.D.v15.

or presented in Annex 6 of the CDM-PDD is based on a conservative assumption that typical fuel consumption for the said diesel generator is 4.8 USg/hr, i.e. assumption is made that fuel consumption by diesel generator is over 3.5 times that proposed by manufacturer. Running hours for the diesel generator amounted to 51 hours during g2009 and 110.3 hours during 2010, giving a total of 161.3 hours during the totality of the monitoring period (i.e. 07/10/2009 to 31/12/2010). The estimate made in the CDM-PDD showed that if the generator ran for 100 hrs/yr, total CO₂

emissions from diesel use would amount to 19.37 tCO₂. Based on the estimation of emissions from the diesel generator presented in Annex 6 of the CDM-PDD, emissions from the diesel generator would therefore amount to 31.24 tCO₂/yr (161.3/100 * 19.37). As a percentage of baseline emissions, 31.24 tCO₂/yr represents 0.035% of baseline emissions.

In addition to the above, emissions from the diesel generator can also be verified based on total diesel fuel use. Total diesel used since plant start up on 07 October 2009 to 31 December 2011 (fuel use for 2009 and 2010 alone is not available) amounts to 1950 litres (purchased diesel quantities since start up to 31 December 2011 amounting to 2325 litres, minus stock on 31 December 2011 of 375 litres). Based on a COEF value for diesel (EF_{CO₂,i,y}) of 7.48 tCO₂/GJ diesel, as given in the CDM-PDD, total CO₂ emissions since project startup amount to:

Amount of diesel used = volume used * density of diesel = 1950 litres * 0.842 t/m³ = 1.642 t diesel used

Emissions from diesel used = 1.642 t diesel used * 3.24 tCO₂/tonne diesel = 5.32 tCO₂

As a percentage of baseline emissions, 5.32 tCO₂/yr represents 0.01% of baseline emissions.

As stated in the CDM-PDD "if running hours, and therefore fuel consumption, will increase to a level where emissions from this source will be equal to or exceed 1% of baseline emissions, the electricity generation metered will be adjusted by deducting the electricity generation from fossil fuels using the specific fuel consumption and the quantity of fossil fuel used, as prescribed in AMS I.D. v 15.". As emissions from this source have been shown not to equal or exceed 1% of baseline emissions, electricity generation metered is therefore not adjusted.

The below table summarizes calculations of the Project Emissions as well as two ways to verify it.

PROJECT EMISSION CALCULATIONS

According to the CDM -PDD:	<i>if the generator ran for 100 hrs/yr, total CO₂ emissions from diesel use would amount to 19.37 tCO₂</i>	
Running hours of the Generator during the entire Monitoring Period	161.3	Hours
Emissions from diesel use	31.24	tonne CO ₂
Percentage of Baseline Emissions	0.061%	<i>This value is far below 1% of the Baseline Emissions so could be set to zero</i>

Method to verify - Method 1

Running hours of the Generator during the entire Monitoring Period	161.3	Hours
Fuel consumption rate of the diesel generator (Manufacturer's Manual)	18	Litres/Hour
Density of diesel	0.842	Ton/m ³

Diese emission factor	3.24	tonneCO ₂ /tonnediesel
Emissions from diesel used	7.92	tonneCO ₂
Percentage of Baseline Emissions	0.015%	<i>This value is far below 1% of the Baseline Emissions so could be set to zero</i>

Method to verify-Method 2

Total diesel used since plant startup 07/10/2010 - 31/12/2011 (Purchased quantities)	1950	Litres
Density of diesel	0.842	Ton/m ³
Diese emission factor	3.24	tonneCO ₂ /tonnediesel
Emissions from diesel used	5.32	tonneCO ₂
Percentage of Baseline Emissions	0.010%	<i>This value is far below 1% of the Baseline Emissions so could be set to zero</i>

4.3 Leakage

As stated in the CDM-PDD, if the energy generating equipment is transferred from another activity, leakage (LE_y) is to be considered. As all generating equipment installed for the project activity is new and not transferred from another activity, it is concluded that LE_y=0.

4.4 Summary of GHG Emission Reductions and Removals

Emission reductions are calculated as follows:

$$ER_y = BE_y - PE_y - LE_y$$

Where:

ER_y Emission reductions in year y (tCO₂e/y)

BE_y Baseline Emissions in year y (tCO₂e/y)

PE_y Project emissions in year y (tCO₂e/y)

LE_y Leakage emissions in year y (tCO₂e/y)

Values for the above parameters are summarized in the table below:

Time Period	Baseline emissions or baselines net GHG removals by sinks (tCO ₂ e)	Project emissions or actual net GHG removals by sinks (tCO ₂ e)	Leakage (tCO ₂ e)	Emission reductions or net anthropogenic GHG removals by sinks (tCO ₂ e)
October 2009 ⁷	2,537	0	0	2,537
November 2009	3,723	0	0	3,723
December 2009	3,584	0	0	3,584
January 2010	2,910	0	0	2,910
February 2010	1,144	0	0	1,144
March 2010	3,966	0	0	3,966
April 2010	4,036	0	0	4,036
May 2010	2,267	0	0	2,267
June 2010	2,342	0	0	2,342
July 2010	2,804	0	0	2,804
August 2010	3,188	0	0	3,188
September 2010	4,233	0	0	4,233
October 2010	5,112	0	0	5,112
November 2010	5,462	0	0	5,462
December 2010	3,871	0	0	3,871
Total	51,177	0	0	51,177

Emission reductions for this period are therefore:

$$ER_y = 51,177 - 0 - 0$$

$$ER_y = 51,177$$

⁷Please note that the start date of the monitoring period is from October 7, 2009 and hence the electricity generation and consequently emission reduction for the month of October 2009 is considered from October 7, 2009 to October 31, 2009.

5 ADDITIONAL INFORMATION

Additional lands supporting information provided with this report as separated documents include:

- Downtime report (logbook of turbine generation) for 2009 and 2010

The following documents have been submitted to the DOE separately as a part of the soft copy:

- Test certificates for meters
- Emission Reduction and Project Emission Calculation spreadsheet
- Run hours for diesel generator for 2009 and 2010
- Monthly meter reading records for 2009 and 2010

Downtime Tables

In the below downtime tables, the dates, duration and type of the outage of power plant units are indicated. The duration is indicated in two columns, Hrs:Mins shows the number of hours and minutes that the unit has been down.

Outage				Duration	Type	Problem Description
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
29-Oct-09	TG1	00:46	06:24	05:38:00	FP	DE Axial brg. temperature HH
29-Oct-09	TG2	00:46	01:06	00:20:00	FP	Grid failure
29-Oct-09	TG2	12:29	12:44	00:15:00	FG	Grid failure
30-Oct-09	TG1	00:00	06:00	06:00:00	SP	To allow Norem cowork on spillway
30-Oct-09	TG1	09:28	10:00	00:32:00	FP	Stuffing box temperature HH
30-Oct-09	TG1	10:14	10:35	00:21:00	FP	Stuffing box temperature HH
30-Oct-09	TG1	11:12	11:24	00:12:00	FM	Low water level in the river
31-Oct-09	TG1	08:46	08:52	00:06:00	FP	Stuffing box temperature HH
06-Nov-09	TG1	00:00	24:00	24:00:00	FM	Low water level in the river
07-Nov-09	TG1	00:00	24:00	24:00:00	FM	Low water level in the river
08-Nov-09	TG1	00:00	24:00	24:00:00	FM	Low water level in the river
09-Nov-09	TG1	00:00	24:00	24:00:00	FM	Low water level in the river
10-Nov-09	TG1	00:00	16:30	16:30:00	FM	WORK GOING ON AT THE SPILLWAY
11-Nov-09	TG1	09:41	09:55	00:14:00	FG	Grid failure
11-Nov-09	TG1	11:25	12:40	01:15:00	FG	Emergency shutdown on main grid. Island mode failed
11-Nov-09	TG2	09:11	09:35	00:24:00	FM	Low water level in the river
11-Nov-09	TG2	11:30	12:40	01:10:00	FM	Emergency shutdown by the Grid
11-Nov-09	TG2	13:00	21:40	08:40:00	FM	Mechanical stoppage
12-Nov-09	TG1	14:26	16:20	01:54:00	FM	Low water level in the river
12-Nov-09	TG1	17:50	18:08	00:18:00	FP	Powerhouse flooding
12-Nov-09	TG2	04:21	04:36	00:15:00	FM	Low water level in the river

12-Nov-09	TG2	17:50	18:08	00:18:00	FP	Powerhouseflooding
13-Nov-09	TG1	13:26	14:25	00:59:00	FM	Lowwaterlevelintheriver
14-Nov-09	TG1	02:54	03:06	00:12:00	FM	Lowwaterlevelintheriver
14-Nov-09	TG1	13:30	13:40	00:10:00	FG	Gridfailure
14-Nov-09	TG1	17:56	18:09	00:13:00	FM	Lowwaterlevelintheriver
14-Nov-09	TG1	18:50	19:06	00:16:00	FP	Powerhouseflooding
14-Nov-09	TG1	22:29	22:57	00:28:00	FM	Lowwaterlevelintheriver
15-Nov-09	TG1	06:40	15:39	08:59:00	FM	Lowwaterlevelintheriver
15-Nov-09	TG1	17:15	17:46	00:31:00	FM	Lowwaterlevelintheriver
15-Nov-09	TG1	17:56	18:07	00:11:00	FG	Gridfailure
15-Nov-09	TG2	02:38	03:50	01:12:00	FM	Lowwaterlevelintheriver
15-Nov-09	TG2	05:05	06:08	01:03:00	FM	Lowwaterlevelintheriver
15-Nov-09	TG2	17:37	18:02	00:25:00	FG	Gridfailure
15-Nov-09	TG2	22:50	23:00	00:10:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	01:13	02:00	00:47:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	03:16	04:30	01:14:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	07:33	08:18	00:45:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	08:49	09:32	00:43:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	10:05	11:28	01:23:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	12:09	13:46	01:37:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG1	18:08	18:22	00:14:00	FP	DEAxialbrg.temperatureHH
16-Nov-09	TG1	18:34	19:16	00:42:00	FP	Powerhouseflooding
16-Nov-09	TG1	19:39	20:08	00:29:00	FP	DEAxialbrg.temperatureHH
16-Nov-09	TG1	20:18	21:10	00:52:00	FP	DEAxialbrg.temperatureHH
16-Nov-09	TG1	21:26	22:15	00:49:00	FP	DEAxialbrg.temperatureHH
16-Nov-09	TG1	22:40	23:11	00:31:00	FP	StuffingboxtemperatureHH
16-Nov-09	TG1	23:21	23:47	00:26:00	FP	StuffingboxtemperatureHH
16-Nov-09	TG1	23:56	00:00	00:04:00	FP	StuffingboxtemperatureHH
16-Nov-09	TG2	00:00	00:25	00:25:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG2	14:40	16:02	01:22:00	FM	Lowwaterlevelintheriver
16-Nov-09	TG2	21:47	22:00	00:13:00	FP	Powerhouseflooding
16-Nov-09	TG2	22:40	22:58	00:18:00	FM	Lowwaterlevelintheriver
17-Nov-09	TG1	00:00	00:08	00:08:00	FP	Powerhouseflooding
17-Nov-09	TG1	00:33	01:08	00:35:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	02:09	02:29	00:20:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	03:13	03:36	00:23:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	03:52	05:01	01:09:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG1	05:36	05:49	00:13:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG1	07:34	07:56	00:22:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	08:04	08:14	00:10:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	08:16	08:20	00:04:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG1	08:49	09:21	00:32:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG1	09:24	09:44	00:20:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	09:45	10:32	00:47:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	11:43	12:06	00:23:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	12:14	12:29	00:15:00	FP	StuffingboxtemperatureHH
17-Nov-09	TG1	16:20	16:31	00:11:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG2	00:00	00:10	00:10:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG2	00:58	01:10	00:12:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG2	02:22	02:33	00:11:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG2	16:51	17:08	00:17:00	FP	DEAxialbrg.temperatureHH
17-Nov-09	TG2	20:04	22:43	02:39:00	FP	DEAxialbrg.temperatureHH
18-Nov-09	TG1	18:31	19:00	00:29:00	FP	DEAxialbrg.temperatureHH

18-Nov-09	TG1	19:21	19:54	00:33:00	FP	DEAxialbrg.temperatureHH
18-Nov-09	TG2	08:04	10:41	02:37:00	FP	DEAxialbrg.temperatureHH
18-Nov-09	TG2	11:27	12:04	00:37:00	FP	Coolingwaterflowingintostuffingbox.
18-Nov-09	TG2	19:21	19:56	00:35:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG1	05:15	05:26	00:11:00	FP	Powerhouseflooding
19-Nov-09	TG1	12:46	13:00	00:14:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG1	14:16	14:31	00:15:00	FG	Gridfailure
19-Nov-09	TG1	14:55	15:31	00:36:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG1	15:49	16:44	00:55:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG1	17:00	17:32	00:32:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG1	18:09	18:35	00:26:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG2	05:15	05:26	00:11:00	FP	PowerHouseFlooding
19-Nov-09	TG2	07:38	10:28	02:50:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG2	16:43	16:45	00:02:00	FP	DEAxialbrg.temperatureHH
19-Nov-09	TG2	16:50	16:55	00:05:00	FP	Coolingwaterflowingintostuffingbox.
19-Nov-09	TG2	18:34	18:53	00:19:00	FP	Coolingwaterflowingintostuffingbox.
20-Nov-09	TG1	23:27	00:00	00:33:00	SP	ToallowNoremcoworkonspillway
21-Nov-09	TG1	00:00	01:02	01:02:00		ToallowNoremcoworkonspillway
21-Nov-09	TG1	01:23	09:40	08:17:00		ToallowNoremcoworkonspillway
23-Nov-09	TG1	00:00	24:00	24:00:00		waterlevelwaslow
24-Nov-09	TG1	00:00	13:36	13:36:00	FP	Butterflyvalvenotopening(plasticpipe stuck inwicketgates)
24-Nov-09	TG1	13:46	00:00	10:14:00	FP	StuffingboxtemperatureHH
24-Nov-09	TG2	13:05	13:33	00:28:00	FP	Coolingwaterflowingintostuffingbox.
24-Nov-09	TG2	15:56	16:12	00:16:00	FP	Coolingwaterflowingintostuffingbox.
25-Nov-09	TG1	21:58	22:33	00:35:00	FP	DEAxialbrg.temperatureHH
25-Nov-09	TG2	13:05	13:33	00:28:00	FP	Coolingwaterflowingintostuffingbox.
26-Nov-09	TG1	00:00	00:45	00:45:00	FP	DEAxialbrg.temperatureHH
26-Nov-09	TG1	23:39	00:00	00:21:00	FP	DEAxialbrg.temperatureHH
26-Nov-09	TG2	18:50	19:24	00:34:00	FG	Gridfailure
26-Nov-09	TG2	23:21	23:37	00:16:00	FP	DEAxialbrg.temperatureHH
27-Nov-09	TG1	05:01	07:45	02:44:00	FP	DEAxialbrg.temperatureHH
27-Nov-09	TG1	12:33	13:03	00:30:00	FP	DEAxialbrg.temperatureHH
27-Nov-09	TG2	03:04	05:03	01:59:00	FP	StuffingboxtemperatureHH
28-Nov-09	TG1	11:05	11:36	00:31:00	FP	Lowoillevelofthestationauxiliary transformer
28-Nov-09	TG1	13:15	14:00	00:45:00	FG	Gridfailure
28-Nov-09	TG1	14:18	15:10	00:52:00	FG	Gridfailure
28-Nov-09	TG2	12:33	13:03	00:30:00	FG	Gridfailure
28-Nov-09	TG2	13:14	14:03	00:49:00	FG	Gridfailure
28-Nov-09	TG2	14:18	15:10	00:52:00	FG	Gridfailure
28-Nov-09	TG2	15:45	16:38	00:53:00	FM	Lowwaterlevelintheriver
29-Nov-09	TG1	01:41	01:53	00:12:00	SP	Tochangefromstandbygeneratortostation transformer
29-Nov-09	TG2	11:05	11:36	00:31:00	SP	Lowoillevelofthestationtransformer. Toppingupoil
30-Nov-09	TG2	00:59	01:11	00:12:00	FP	Coolingwaterflowingintostuffingbox.
30-Nov-09	TG2	13:52	00:00	10:08:00	SP	Toallowworkonspillwaybyavoiding spillage.
01-Dec-09	TG1	17:54	18:04	00:10:00	FG	Gridfailure
01-Dec-09	TG2	00:00	02:23	02:23:00	SP	Toallowworkonspillwaybyavoiding spillage.
01-Dec-09	TG2	10:16	15:04	04:48:00	SP	Toallowworkonspillwaybyavoiding spillage.

01-Dec-09	TG2	15:34	16:15	00:41:00	SP	Toallowworkonspillwaybyavoiding spillage.
01-Dec-09	TG2	17:19	18:23	01:04:00	SP	Toallowworkonspillwaybyavoiding spillage.
01-Dec-09	TG2	19:09	00:00	04:51:00	SP	Toallowworkonspillwaybyavoiding spillage.
02-Dec-09	TG1	10:15	12:28	02:13:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
02-Dec-09	TG2	00:00	00:00	24:00:00	SP	Toallowworkonspillwaybyavoiding spillage.
04-Dec-09	TG1	03:31	03:46	00:15:00	FG	Gridfailure
04-Dec-09	TG1	13:56	14:27	00:31:00	SP	Tocheckdrainagepump
04-Dec-09	TG1	21:41	21:56	00:15:00	FG	Gridfailure
04-Dec-09	TG2	10:14	12:27	02:13:00	SP	Toallowworkonspillwaybyavoiding spillage.
04-Dec-09	TG2	12:34	13:49	01:15:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
04-Dec-09	TG2	13:56	14:26	00:30:00	SP	Toallowworkonspillwaybyavoiding spillage.Checkthemuddrainage.
04-Dec-09	TG2	15:24	17:13	01:49:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
04-Dec-09	TG2	21:41	21:57	00:16:00	FG	Gridfailure
04-Dec-09	TG2	22:24	00:00	01:36:00	FM	Lowwaterlevelintheriver
05-Dec-09	TG1	06:09	06:34	00:25:00	FM	Lowwaterlevelintheriver
05-Dec-09	TG1	14:48	18:41	03:53:00	FM	Lowwaterlevelintheriver
05-Dec-09	TG2	00:00	03:38	03:38:00	FM	Lowwaterlevelintheriver
05-Dec-09	TG2	04:20	14:45	10:25:00	FM	Lowwaterlevelintheriver
06-Dec-09	TG2	11:48	12:06	00:18:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG1	09:36	13:53	04:17:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG1	14:05	14:28	00:23:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG1	14:40	15:52	01:12:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG1	17:21	17:32	00:11:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG2	17:21	17:39	00:18:00	FM	Lowwaterlevelintheriver
07-Dec-09	TG2	18:42	00:00	05:18:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
08-Dec-09	TG1	00:00	21:07	21:07:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
08-Dec-09	TG2	00:00	07:43	07:43:00	FM	Lowwaterlevelintheriver
08-Dec-09	TG2	07:43	00:00	16:17:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
09-Dec-09	TG1	09:41	23:59	14:18:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
09-Dec-09	TG2	00:00	09:38	09:38:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
10-Dec-09	TG1	01:02	01:17	00:15:00	FP	DEAxialbrg.temperatureHH
10-Dec-09	TG2	10:07	21:09	11:02:00	SP	Shutdown
10-Dec-09	TG2	21:09	00:00	02:51:00	FM	Lowwaterlevelintheriver
11-Dec-09	TG1	00:00	00:17	00:17:00	FP	DEAxialbrg.temperatureHH
11-Dec-09	TG1	01:02	02:09	01:07:00	FP	DEAxialbrg.temperatureHH
11-Dec-09	TG1	02:22	02:40	00:18:00	FP	DEAxialbrg.temperatureHH
11-Dec-09	TG1	02:40	23:59	21:19:00	FM	Lowwaterlevelintheriver
11-Dec-09	TG2	00:00	00:59	00:59:00	FM	Lowwaterlevelintheriver
12-Dec-09	TG1	00:17	02:13	01:56:00	FM	Lowwaterlevelintheriver
12-Dec-09	TG1	02:49	03:16	00:27:00	FP	Compressorfortheautofilterwasnot

						running.
13-Dec-09	TG1	02:50	03:15	00:25:00	FM	Lowwaterlevelintheriver
13-Dec-09	TG1	08:27	08:55	00:28:00	FP	DEAxialbrg.temperatureHH
13-Dec-09	TG1	14:49	15:02	00:13:00	FP	DEAxialbrg.temperatureHH
13-Dec-09	TG1	20:58	21:10	00:12:00	FP	DEAxialbrg.temperatureHH
13-Dec-09	TG2	16:48	17:03	00:15:00	FP	Coolingwaterflowingintostuffingbox.
13-Dec-09	TG2	20:55	21:05	00:10:00	FP	DEAxialbrg.temperatureHH
14-Dec-09	TG1	09:47	14:53	05:06:00	SP	ToallowNoremcoworkonthespillway withoutspillage.
14-Dec-09	TG1	15:16	23:59	08:43:00	FM	Lowwaterlevelintheriver
14-Dec-09	TG2	07:20	07:32	00:12:00	FP	DEAxialbrg.temperatureHH
14-Dec-09	TG2	14:41	15:00	00:19:00	FG	Gridfailure
15-Dec-09	TG1	08:54	12:43	03:49:00	FM	Lowwaterlevelintheriver
15-Dec-09	TG1	15:44	16:00	00:16:00	SP	Changingthestandbygeneratortothestation transformer.
15-Dec-09	TG2	09:18	11:53	02:35:00	SP	Earthingworkattheswitchyard
15-Dec-09	TG2	15:51	16:13	00:22:00	SP	Changingstandbygeneratorpowertostation transformer.
16-Dec-09	TG1	02:00	02:24	00:24:00	FP	DEAxialbrg.temperatureHH
16-Dec-09	TG1	13:06	14:43	01:37:00	SP	Frank(ABB)wasworkingonlevelsensors.
16-Dec-09	TG1	17:18	17:37	00:19:00	FP	DEAxialbrg.temperatureHH
16-Dec-09	TG1	18:23	18:37	00:14:00	FP	DEAxialbrg.temperatureHH
16-Dec-09	TG1	19:59	20:13	00:14:00	FP	DEAxialbrg.temperatureHH
16-Dec-09	TG1	22:44	22:56	00:12:00	FP	Powerhouseflooding
16-Dec-09	TG2	22:45	22:55	00:10:00	FP	PowerHouseflooding
16-Dec-09	TG2	23:45	23:57	00:12:00	FP	PowerHouseflooding
17-Dec-09	TG1	04:16	04:58	00:42:00	FP	DEAxialbrg.temperatureHH
17-Dec-09	TG1	05:10	06:00	00:50:00	FM	Lowwaterlevelintheriver
17-Dec-09	TG1	14:48	15:06	00:18:00	FG	Gridfailure
17-Dec-09	TG2	09:28	10:18	00:50:00	FP	Powerhouseflooding
17-Dec-09	TG2	14:48	15:06	00:18:00	FG	Gridfailure
17-Dec-09	TG2	21:14	21:27	00:13:00	FP	Coolingwaterflowingintostuffingbox.
20-Dec-09	TG1	05:10	05:59	00:49:00	FM	Lowwaterlevelintheriver
20-Dec-09	TG1	06:00	06:39	00:39:00	FM	Lowwaterlevelintheriver
20-Dec-09	TG1	09:02	09:15	00:13:00	FM	Lowwaterlevelintheriver
20-Dec-09	TG1	09:36	11:07	11:05:00	FM	Lowwaterlevelintheriver
20-Dec-09	TG1	11:33	11:46	00:13:00	FP	DEAxialbrg.temperatureHH
20-Dec-09	TG1	12:33	13:19	00:46:00	FP	DEAxialbrg.temperatureHH
20-Dec-09	TG1	15:07	15:52	00:45:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	00:00	01:16	01:16:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	06:26	06:40	00:14:00	FP	Powerhouseflooding
21-Dec-09	TG1	07:34	08:28	00:54:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	09:02	09:16	00:14:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	09:36	11:08	01:32:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	11:33	11:46	00:13:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	12:33	14:49	02:16:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	15:12	18:11	02:59:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG1	18:55	23:59	05:04:00	FM	Lowwaterlevelintheriver
21-Dec-09	TG2	06:26	06:38	00:12:00	FP	Powerhouseflooding
22-Dec-09	TG1	00:00	05:00	05:00:00	FM	Lowwaterlevelintheriver
22-Dec-09	TG1	15:40	20:30	04:50:00	FM	Lowwaterlevelintheriver
22-Dec-09	TG1	20:55	23:30	02:35:00	FM	Lowwaterlevelintheriver
22-Dec-09	TG1	23:50	00:00	00:10:00	FM	Lowwaterlevelintheriver

22-Dec-09	TG2	15:20	15:35	00:15:00	FP	Penstockpressurelow
22-Dec-09	TG2	20:30	20:55	00:25:00	FP	Coolingwaterflowingintostuffingbox.
23-Dec-09	TG1	05:17	06:00	00:43:00	FM	Lowwaterlevelintheriver
23-Dec-09	TG1	06:32	08:45	02:13:00	FM	Lowwaterlevelintheriver
23-Dec-09	TG1	09:03	11:05	02:02:00	FM	Lowwaterlevelintheriver
23-Dec-09	TG1	22:00	00:00	02:00:00	FM	Lowwaterlevelintheriver
23-Dec-09	TG2	02:50	03:30	00:40:00	FP	DEAxialbrg.temperatureHH
23-Dec-09	TG2	06:00	06:15	00:15:00	FP	Coolingwaterflowingintostuffingbox.
23-Dec-09	TG2	08:45	09:03	00:18:00	FP	Coolingwaterflowingintostuffingbox.
23-Dec-09	TG2	11:05	14:00	02:55:00	FP	Coolingwaterflowingintostuffingbox.
24-Dec-09	TG1	00:00	23:59	23:59:00	FM	Lowwaterlevelintheriver
25-Dec-09	TG1	00:00	06:00	06:00:00	FM	Lowwaterlevelintheriver
26-Dec-09	TG1	00:00	11:45	11:45:00	FP	Pressureimbalancebeforeandafterbutterfly valve.Presssureafterbutterflyvalvelow (14.5)bar).Penstockpressurebeforebutterfly valve16bar
27-Dec-09	TG1	04:20	04:30	00:10:00	FM	Penstockpressurelow
27-Dec-09	TG1	14:30	16:05	01:35:00	FM	Lowwaterlevelintheriver
27-Dec-09	TG2	18:14	19:24	01:10:00	FM	Lowwaterlevelintheriver
28-Dec-09	TG1	00:00	04:20	04:20:00	FP	Pressureimbalancebeforeandafterbutterfly valve.Presssureafterbutterflyvalvelow (14.5)bar).Penstockpressurebeforebutterfly valve16bar
28-Dec-09	TG1	04:30	00:00	19:30:00	FP	Pressureimbalancebeforeandafterbutterfly valve.Presssureafterbutterflyvalvelow (14.5)bar).Penstockpressurebeforebutterfly valve16bar
28-Dec-09	TG2	04:20	04:35	00:10:00	FP	Penstockpressurelow
28-Dec-09	TG2	08:50	09:08	00:18:00	FP	Stationbreakertripped
28-Dec-09	TG2	14:27	14:43	00:16:00	FP	Powerhouseflooding
29-Dec-09	TG1	15:31	17:19	01:48:00	FP	Airbreakerswitchopened
29-Dec-09	TG2	15:42	17:29	01:47:00	FM	Lowwaterlevelintheriver
29-Dec-09	TG2	18:17	19:24	01:07:00	FM	Lowwaterlevelintheriver
30-Dec-09	TG2	06:22	07:43	01:21:00	FM	Lowwaterlevelintheriver
30-Dec-09	TG2	08:48	10:10	01:22:00	FM	Lowwaterlevelintheriver
30-Dec-09	TG2	17:29	00:00	06:31:00	FP	FaultywaterlevelsensordatForebay&the operationiscontrolledbywaterlevel
01-Jan-10	TG1	09:36	10:25	00:49:00	FP	Airbreakerswitchopenedduetothegrid.
01-Jan-10	TG2	10:55	18:44	07:49:00	FM	Lowwaterlevel
01-Jan-10	TG2	19:05	22:43	03:38:00	FM	Lowwaterlevel
01-Jan-10	TG2	23:37	00:00	00:23:00	FM	Lowwaterlevel
02-Jan-10	TG2	00:00	03:09	03:09:00	FM	Lowwaterlevel
02-Jan-10	TG2	03:36	00:00	20:24:00	FM	Lowwaterlevel
03-Jan-10	TG1	19:38	20:10	00:32:00	FP	TheDEaxialtemp.washigh
03-Jan-10	TG1	20:10	23:59	03:49:00	FM	lowwaterlevel
03-Jan-10	TG2	00:00	02:54	02:54:00	FM	Lowwaterlevel
03-Jan-10	TG2	03:31	05:16	01:45:00	FM	Lowwaterlevel
03-Jan-10	TG2	06:01	10:15	04:14:00	FM	Lowwaterlevel
03-Jan-10	TG2	10:31	12:18	01:47:00	FM	Lowwaterlevel
03-Jan-10	TG2	12:32	17:45	05:13:00	FM	Lowwaterlevel
03-Jan-10	TG2	18:15	19:15	01:00:00	FM	Lowwaterlevel
04-Jan-10	TG1	00:00	04:20	04:20:00	FM	lowwaterlevel
04-Jan-10	TG1	07:43	08:18	00:35:00	FG	MainGridtripped
04-Jan-10	TG1	08:39	16:46	08:07:00	FM	lowwaterlevel

04-Jan-10	TG2	04:20	08:12	03:52:00	FM	Lowwaterlevel
04-Jan-10	TG2	16:36	16:58	00:22:00	FG	Underfrequency
04-Jan-10	TG2	17:20	00:00	06:40:00	FM	Lowwaterlevel
05-Jan-10	TG1	12:40	12:48	00:08:00	FP	powerhouseflooding
05-Jan-10	TG1	12:48	00:00	11:12:00	FM	lowwaterlevel
05-Jan-10	TG2	00:00	12:48	12:48:00	FM	Lowwaterlevel
06-Jan-10	TG1	00:00	18:17	18:17:00	FM	lowwaterlevel
06-Jan-10	TG2	18:17	21:00	02:43:00	FP	Stuffingboxtempraising,stopedtomake adjustmentonit.
06-Jan-10	TG2	22:13	00:00	01:47:00	FM	Lowwaterlevel
07-Jan-10	TG1	00:37	00:44	00:07:00	FP	Guideaxialtemphigh
07-Jan-10	TG1	10:05	18:02	07:57:00	FM	lowwaterlevelandwantedtotestthestuffing temp.
07-Jan-10	TG1	21:14	23:59	02:45:00	FG	Gridwasoff
07-Jan-10	TG2	00:00	10:00	10:00:00	FM	Lowwaterlevel
07-Jan-10	TG2	18:26	22:50	04:24:00	FM	Lowwaterlevel
08-Jan-10	TG1	00:00	04:59	04:59:00	FM	Lowwaterlevel
08-Jan-10	TG2	04:47	06:20	01:33:00	FP	Powerhouseflooding
08-Jan-10	TG2	06:45	07:50	01:05:00	FM	Lowwaterlevel
09-Jan-10	TG1	05:40	06:32	00:52:00	FP	PMturb1governor
09-Jan-10	TG1	06:57	22:09	15:12:00	FM	Lowwaterlevel
09-Jan-10	TG2	00:00	23:09	23:09:00	FM	Lowwaterlevel
09-Jan-10	TG2	23:32	00:00	00:28:00	FM	Lowwaterlevel
10-Jan-10	TG1	15:48	15:53	00:05:00	FG	OverfrequencyTrip
10-Jan-10	TG1	15:53	17:35	01:42:00	FM	Lowwaterlevel
10-Jan-10	TG1	20:31	22:23	01:52:00	FM	Lowwaterlevel
10-Jan-10	TG1	23:05	00:00	00:55:00	FM	Lowwaterlevel
10-Jan-10	TG2	00:00	00:00	00:00:00	FM	Lowwaterlevel
11-Jan-10	TG1	00:00	00:00	00:00:00	SP	Penstockinspection
11-Jan-10	TG2	13:18	20:27	07:09:00	SP	Inspectionofpenstockbecauseitisvibrating
12-Jan-10	TG1	00:00	20:00	20:00:00	SP	Penstockinspection
12-Jan-10	TG1	20:54	00:00	03:06:00	FM	Lowwaterlevel
12-Jan-10	TG2	00:00	17:05	17:05:00	SP	Inspectionofpenstockbecauseitisvibrating
13-Jan-10	TG1	00:00	01:50	01:50:00	FM	Lowwaterlevel
13-Jan-10	TG1	03:01	04:38	01:37:00	FM	Lowwaterlevel
13-Jan-10	TG2	09:13	09:32	00:19:00	FM	Lowwaterlevel
14-Jan-10	TG1	00:00	08:35	08:35:00	FG	MainGridtripped
14-Jan-10	TG2	00:00	09:32	09:32:00	FP	Outletairtemperaturehigh
15-Jan-10	TG1	11:22	14:13	02:51:00	FM	Lowwaterlevel
15-Jan-10	TG1	19:53	20:53	01:00:00	FM	Lowwaterlevel
15-Jan-10	TG1	21:51	00:23	02:32:00	FM	Lowwaterlevel
16-Jan-10	TG1	00:00	16:22	16:22:00	FM	Lowwaterlevel
17-Jan-10	TG1	00:00	16:15	16:15:00	FP	Penstockpressureimbalance
17-Jan-10	TG1	20:25	00:00	03:35:00	FP	Hydraulichosejointfaulty
17-Jan-10	TG2	16:10	00:00	07:50:00	FM	Lowwaterlevel
18-Jan-10	TG1	00:01	10:44	10:43:00	FP	Hydraulichosejointfaulty
18-Jan-10	TG2	00:00	12:53	12:53:00	FM	Lowwaterlevel
19-Jan-10	TG1	11:00	11:56	00:56:00	FG	OverfrequencyTrip
19-Jan-10	TG1	11:59	13:46	01:47:00	FG	MainGridtripped
19-Jan-10	TG2	00:00	11:00	11:00:00	FM	Lowwaterlevel
19-Jan-10	TG2	11:59	16:13	04:14:00	FG	Gridfailure
20-Jan-10	TG1	18:15	18:29	00:14:00	FG	MainGridtripped

20-Jan-10	TG2	00:00	17:24	17:24:00	FM	Lowwaterlevel
20-Jan-10	TG2	17:56	00:00	06:04:00	FM	Lowwaterlevel
21-Jan-10	TG1	11:00	11:16	00:16:00	FP	Lowgridvoltage(32kv).
21-Jan-10	TG1	14:45	14:55	00:10:00	FG	Over/UnderfrequencyTrip
21-Jan-10	TG1	15:50	16:06	00:16:00	FP	Allthesubmersiblepumpsfailed&injector.
21-Jan-10	TG1	18:19	18:59	00:40:00	FP	HigherwaterlevelduetoTG1trip
21-Jan-10	TG2	00:00	16:06	16:06:00	FM	Lowwaterlevel
21-Jan-10	TG2	18:19	00:00	05:41:00	FM	lowwaterlevel
22-Jan-10	TG2	00:00	21:58	21:58:00	FM	Lowwaterlevel
22-Jan-10	TG2	22:37	00:00	01:23:00	FM	Lowwaterlevel
23-Jan-10	TG2	00:01	00:00	23:59:00	FM	Lowwaterlevel
24-Jan-10	TG2	00:01	06:49	06:48:00	FM	Lowwaterlevel
25-Jan-10	TG1	06:49	08:20	01:31:00	FP	Outletairtemperaturehigh
25-Jan-10	TG2	00:01	10:24	10:23:00	FM	Lowwaterlevel
25-Jan-10	TG2	11:30	00:00	12:30:00	FM	Lowwaterlevel
26-Jan-10	TG2	00:00	20:23	20:23:00	FM	Lowwaterlevel
27-Jan-10	TG1	20:15	23:59	03:44:00	FP	Lowcoolingwaterflowintoturbines.All coolingwaterpumpsfaulty
27-Jan-10	TG2	00:00	11:25	11:25:00	FM	Lowwaterlevel
28-Jan-10	TG1	00:00	23:59	23:59:00	FP	Lowcoolingwaterflowintiturbines.All coolingwaterpumpsfaulty
29-Jan-10	TG1	00:00	23:59	23:59:00	FP	Lowcoolingwaterflowintoturbines.All coolingwaterpumpsfaulty
30-Jan-10	TG1	00:00	23:59	23:59:00	FP	Lowcoolingwaterflowintoturbines.All coolingwaterpumpsfaulty
30-Jan-10	TG2	11:11	23:59	12:48:00	FG	Overfrequency(54hz)
31-Jan-10	TG2	23:57	00:00	00:03:00	FG	Overfrequency(54hz)
01-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
01-Feb-10	TG2	00:00	23:59	23:59:00	FG	Overfrequency(54hz)
02-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
02-Feb-10	TG2	00:00	02:16	02:16:00	FP	Coolingwaterintothe tubine
02-Feb-10	TG2	02:20	04:40	02:20:00	FP	Coolingwaterintothe tubine
02-Feb-10	TG2	05:20	07:23	02:03:00	FP	Coolingwaterintothe tubine
03-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
04-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
04-Feb-10	TG2	11:10	11:18	00:08:00	SP	AirsupportbyMavel
05-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
06-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
06-Feb-10	TG2	08:42	09:15	00:33:00	SP	Airsupport(ByMavel)
06-Feb-10	TG2	09:16	17:21	08:05:00	SP	Marvelshutdown
07-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
08-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
08-Feb-10	TG2	16:58	23:59	07:01:00	FP	Coolingwaterintothe tubine
09-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/EIprom
09-Feb-10	TG2	10:08	23:59	13:51:00	SP	maintenanceatthepowerplant.

10-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
10-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
11-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
11-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
12-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
12-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
13-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
13-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
14-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
14-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
15-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
15-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
16-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
16-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
17-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
17-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
18-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
18-Feb-10	TG2	00:00	23:59	23:59:00	SP	maintenanceatthepowerplant.
19-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
19-Feb-10	TG2	00:00	14:47	14:47:00	SP	maintenanceatthepowerplant.
20-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
20-Feb-10	TG2	00:00	17:27	17:27:00	SP	maintenanceatthepowerplant.
21-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
22-Feb-10	TG1	00:00	23:59	23:59:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
22-Feb-10	TG2	06:49	19:17	12:28:00	FG	Overfrequency(54hz)
23-Feb-10	TG1	00:00	16:06	16:06:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
23-Feb-10	TG1	16:36	19:36	03:00:00	SP	Shutdownforsnaglistrectificationby Mavel/Elprom
23-Feb-10	TG1	22:21	22:35	00:14:00	FG	Gridfreqhigh(54.9)hz
23-Feb-10	TG2	02:00	22:57	20:57:00	SP	Efficiencytest
24-Feb-10	TG1	03:17	03:31	00:14:00	FG	Gridfreqhigh(55.0)hz
24-Feb-10	TG1	05:21	05:32	00:11:00	FP	Bearingtemp.high.
24-Feb-10	TG1	06:21	06:31	00:10:00	FG	STUFFINGBOX
24-Feb-10	TG1	08:43	16:32	07:49:00	SP	TestingTG2efficiency
24-Feb-10	TG1	19:22	19:53	00:31:00	FP	Bearingtemperaturehigh
24-Feb-10	TG1	21:20	01:25	04:05:00	SP	TestingTG2efficiency
24-Feb-10	TG2	00:00	00:47	00:47:00	SP	Lowwaterflowintheriver
24-Feb-10	TG2	21:18	22:37	01:19:00	SP	Tests
25-Feb-10	TG1	03:51	04:05	00:14:00	FP	TrippedbearingHH
25-Feb-10	TG1	10:15	22:25	12:10:00	SP	TestingTG2efficiency

25-Feb-10	TG2	01:28	04:27	02:59:00	SP	Efficiencytest
26-Feb-10	TG1	02:52	13:59	11:07:00	SP	Eff. Testing
26-Feb-10	TG1	16:00	16:43	00:43:00	SP	Eff. Testing
26-Feb-10	TG1	18:20	18:43	00:23:00	SP	Eff. Testing
26-Feb-10	TG1	19:44	23:59	04:15:00	SP	TorunTG2
26-Feb-10	TG2	00:00	06:17	06:17:00	SP	Efficiencytest
26-Feb-10	TG2	18:47	20:07	01:20:00	SP	Efficiencytest
27-Feb-10	TG1	00:01	00:05	00:04:00	SP	Eff. Testing
27-Feb-10	TG2	06:37	09:57	03:20:00	SP	Drainandremoveefficiencytestgadget
27-Feb-10	TG2	11:06	11:47	00:41:00	FG	NoloadatNkenda
28-Feb-10	TG1	07:08	10:57	03:49:00	FG	NoloadatNkenda
28-Feb-10	TG1	16:45	21:20	04:35:00	FG	Gridoff
28-Feb-10	TG2	07:36	13:37	06:01:00	FG	NoloadatNkenda
01-Mar-10	TG1	08:34	08:38	00:04:00	FP	PenstockpressureCriticalLow
01-Mar-10	TG1	08:38	11:46	03:08:00	SP	Mubuku1intakeundermodification.
01-Mar-10	TG1	11:54	12:00	00:06:00	FP	Stuffingboxtemperature
01-Mar-10	TG1	18:45	20:17	01:32:00	FP	Stuffingboxtemperature
01-Mar-10	TG2	08:03	08:48	00:45:00	FP	PenstockpressureCriticalLow
01-Mar-10	TG2	11:37	12:16	00:39:00	SP	Mubuku1intakeundermodification.
01-Mar-10	TG2	14:17	22:00	07:43:00	FM	Waterlevellow
02-Mar-10	TG1	01:17	02:01	00:44:00	FP	Stuffingboxtemperature
02-Mar-10	TG1	07:43	08:01	00:18:00	FP	forebaywaterlevelcriticallow
02-Mar-10	TG1	10:14	20:49	10:35:00	FM	lowwaterlevel
02-Mar-10	TG1	21:29	21:46	00:17:00	FP	Penstockpressurelow
02-Mar-10	TG2	07:43	10:22	02:39:00	FP	forebaycriticallowwaterlevel
03-Mar-10	TG1	10:09	13:01	02:52:00	SP	ImmergencyvalueONandOFFGridoperation settingsbyMavel.
03-Mar-10	TG1	14:59	16:36	01:37:00	SP	Mubuku1intakeundermodification.
03-Mar-10	TG2	10:41	18:00	07:19:00	SP	ImmergencyvalueONandOFFGridoperation settingsbyMavel.
04-Mar-10	TG1	08:25	16:14	07:49:00	SP	Mubuku1intakeundermodification.
04-Mar-10	TG1	18:32	20:28	01:56:00	FP	Axialbearingtemphighduefilterschocked
04-Mar-10	TG1	21:03	21:20	00:17:00	FP	Axialbearingtemphighduefilterschocked
04-Mar-10	TG1	21:36	21:53	00:17:00	FP	Axialbearingtemphighduefilterschocked
04-Mar-10	TG1	22:13	23:41	01:28:00	FP	Axialbearingtemphighduefilterschocked
04-Mar-10	TG2	16:15	16:30	00:15:00	FP	Axialbearingtemphighduechockedfilters.
04-Mar-10	TG2	18:31	20:18	01:47:00	FP	Axialbearingtemphighduechockedfilters.
04-Mar-10	TG2	20:43	21:48	01:05:00	FP	Axialbearingtemphighduechockedfilters.
04-Mar-10	TG2	22:00	22:13	00:13:00	FP	Axialbearingtemphighduechockedfilters.
05-Mar-10	TG1	00:00	00:59	00:59:00	FP	Axialbearingtemphighduefilterschocked
05-Mar-10	TG1	01:21	02:58	01:37:00	FP	Axialbearingtemphighduefilterschocked
05-Mar-10	TG1	06:53	07:09	00:16:00	FP	Axialbearingtemphighduefilterschocked
05-Mar-10	TG1	07:58	17:45	09:47:00	FP	TG2Axialbearingtemphigh
05-Mar-10	TG1	18:25	19:25	01:00:00	FP	Coolingwaterflowintotheturbine
05-Mar-10	TG1	20:00	20:55	00:55:00	FP	HHbearingtemperature
05-Mar-10	TG1	21:03	21:22	00:19:00	FP	Coolingwaterflowintotheturbine
05-Mar-10	TG1	21:41	21:59	00:18:00	FP	HHbearingtemperature
05-Mar-10	TG2	03:34	07:53	04:19:00	FP	Axialbearingtemphighduechockedfilters.
05-Mar-10	TG2	17:37	19:27	01:50:00	FP	Axialbearingshightemp.
05-Mar-10	TG2	19:52	21:37	01:45:00	FP	Shutdownduetocoolingwaterflowintothe turbine
05-Mar-10	TG2	21:45	00:00	02:15:00	FP	CBfordrainagepumpstripped
06-Mar-10	TG1	07:41	08:57	01:16:00	FP	Lowpenstockpressure

06-Mar-10	TG1	09:12	13:16	04:04:00	SP	IntakegateclosedtoenableNoremcotodo theirwork.
06-Mar-10	TG1	13:27	13:52	00:25:00	FP	Stuffingboxtemperature
06-Mar-10	TG1	13:55	15:26	01:31:00	FP	Stuffingboxtemperature
06-Mar-10	TG1	15:45	16:40	00:55:00	FP	Stuffingboxtemperature
06-Mar-10	TG1	16:56	17:25	00:29:00	FP	Stuffingboxtemperature
06-Mar-10	TG1	17:34	19:13	01:39:00	FP	Stuffingboxtemperature
06-Mar-10	TG1	19:21	22:11	02:50:00	FP	Stuffingboxtemperature
06-Mar-10	TG2	00:37	07:56	07:19:00	FP	DEAxialbearing79.9C
06-Mar-10	TG2	22:04	23:23	01:19:00	FP	DEAxialbearinghigh.
07-Mar-10	TG1	04:21	15:44	11:23:00	FP	Stuffingboxtemperature
07-Mar-10	TG1	16:48	17:05	00:17:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG1	17:25	17:58	00:33:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG1	18:27	19:04	00:37:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG1	19:26	19:45	00:19:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG1	20:05	21:10	01:05:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG1	22:36	22:57	00:21:00	FP	DEAxialbearingtemperature79.9C
07-Mar-10	TG2	01:16	06:32	05:16:00	FP	DEAxialbearing79.9C
07-Mar-10	TG2	15:36	22:00	06:24:00	FP	DEAxialbearing79.9C
08-Mar-10	TG1	00:55	01:12	00:17:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	02:04	03:54	01:50:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	04:46	06:37	01:51:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	06:51	09:46	02:55:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	10:22	12:11	01:49:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	12:50	13:45	00:55:00	FP	DEAxialbearingtemperature79.9C
08-Mar-10	TG2	14:07	15:44	01:37:00	FP	Outletair1temphigh
08-Mar-10	TG2	16:00	16:27	00:27:00	FP	Outletair1temphigh
08-Mar-10	TG2	16:44	17:51	01:07:00	FP	DEAxialbearingtemperature79.9C
09-Mar-10	TG2	00:36	03:15	02:39:00	FP	DEAxialbearingtemperature79.9C
09-Mar-10	TG2	05:51	14:48	08:57:00	SP	shutdown
09-Mar-10	TG2	14:57	15:51	00:54:00	FP	DEAxialbearinghigh.
09-Mar-10	TG2	17:14	19:01	01:47:00	FP	DEAxialbearingtemperature79.9C
09-Mar-10	TG2	19:02	20:28	01:26:00	FP	DEAxialbearingtemperature79.9C
09-Mar-10	TG2	20:51	22:03	01:12:00	FP	DEAxialbearingtemperature79.9C
10-Mar-10	TG2	15:11	16:41	01:30:00	FP	DEAxialbearingtemperature79.3
10-Mar-10	TG2	18:16	20:13	01:57:00	FP	DEAxiltemperature
10-Mar-10	TG2	21:21	00:00	02:39:00	FP	DEAxialbearingtemperature
11-Mar-10	TG2	00:00	05:00	05:00:00	FP	DEAxialbearingtemperature
11-Mar-10	TG2	05:13	17:09	11:56:00	SP	Noremcosshutdown
12-Mar-10	TG1	06:11	18:52	12:41:00	SP	Noremcosshutdown
12-Mar-10	TG1	19:22	23:59	04:37:00	FM	Lowwaterflow
12-Mar-10	TG2	05:44	16:39	10:55:00	SP	Noremcosshutdown
13-Mar-10	TG1	00:00	01:47	01:47:00	FM	Lowwaterflow
13-Mar-10	TG1	02:23	19:00	16:37:00	FM	Lowwaterflow
13-Mar-10	TG1	20:21	20:39	00:18:00	FM	Lowwaterflow
13-Mar-10	TG2	18:55	20:38	01:43:00	FP	Tripduetocoolingwaterflowintotheturbine
13-Mar-10	TG2	22:10	00:00	01:50:00	FM	Stoppedduetolowwaterlevel
14-Mar-10	TG1	12:57	13:20	00:23:00	FP	Coolingwaterflowintotheturbine
14-Mar-10	TG2	00:00	16:06	16:06:00	FM	Stoppedduetolowwaterlevel
14-Mar-10	TG2	16:48	21:33	04:45:00	FM	Stoppedduetolowwaterlevel
17-Mar-10	TG1	09:41	10:21	00:40:00	SP	TestingTG2
17-Mar-10	TG1	11:19	21:55	10:36:00	SP	StilltestingTG2
17-Mar-10	TG1	22:44	23:59	01:15:00	FM	Lowwaterlevel

17-Mar-10	TG2	00:00	10:50	10:50:00	FM	LesswaterintheCanal
18-Mar-10	TG1	00:00	01:25	01:25:00	FM	Lowwaterlevel
18-Mar-10	TG1	17:37	18:02	00:25:00	FG	132kvwentoff.
18-Mar-10	TG1	20:25	20:41	00:16:00	FP	HHbearingtemperature
18-Mar-10	TG1	21:41	22:17	00:36:00	FP	HHbearingtemperature
18-Mar-10	TG1	22:27	22:41	00:14:00	FP	FM12commonfault
18-Mar-10	TG1	23:15	23:51	00:36:00	FP	HHbearingtemperature
18-Mar-10	TG2	01:15	06:40	05:25:00	FG	Powersurgeongrid
18-Mar-10	TG2	17:21	22:04	04:43:00	FG	132kvlinewentoff
18-Mar-10	TG2	22:09	23:12	01:03:00	FP	stuffingboxtemperaturehigh
18-Mar-10	TG2	23:43	00:00	00:17:00	FP	stuffingboxtemperaturehigh
19-Mar-10	TG1	01:15	01:54	00:39:00	FP	HHbearingtemperature
19-Mar-10	TG1	02:53	03:39	00:46:00	FP	HHbearingtemperature
19-Mar-10	TG2	00:00	20:58	20:58:00	FP	stuffingboxtemperaturehigh
21-Mar-10	TG1	15:06	15:23	00:17:00	FP	HHbearingtemperature
21-Mar-10	TG1	20:50	21:24	00:34:00	FP	HHbearingtemperature
21-Mar-10	TG1	21:42	22:00	00:18:00	FP	HHbearingtemperature
21-Mar-10	TG1	22:18	22:36	00:18:00	FP	HHbearingtemperature
21-Mar-10	TG2	20:41	20:43	00:02:00	FP	33T2CBtripped
22-Mar-10	TG1	21:30	22:29	00:59:00	FP	HHbearingtemperature
22-Mar-10	TG2	19:59	20:49	00:50:00	FP	Coolingwaterflowintotheturbine
23-Mar-10	TG1	00:36	00:53	00:17:00	FP	HHbearingtemperature
23-Mar-10	TG1	01:10	01:27	00:17:00	FP	HHbearingtemperature
23-Mar-10	TG1	01:40	02:19	00:39:00	FP	HHbearingtemperature
23-Mar-10	TG1	03:22	03:39	00:17:00	FP	HHbearingtemperature
23-Mar-10	TG1	17:25	18:01	00:36:00	FP	HHbearingtemperature
23-Mar-10	TG2	08:28	22:33	14:05:00	SP	ABBworkonthebreakerspringcharging motor&CTs
24-Mar-10	TG1	07:31	07:48	00:17:00	FP	HHbearingtemperature
24-Mar-10	TG2	08:05	16:18	08:13:00	FG	Freqfluctuationofgridandfinallybroken wicketgateprotectionpin
26-Mar-10	TG1	16:00	16:32	00:32:00	FP	POWERHOUSEFLOODING
26-Mar-10	TG1	17:04	17:20	00:16:00	FP	POWERHOUSEFLOODING
26-Mar-10	TG1	17:42	18:13	00:31:00	FP	HHbearingtemperature
26-Mar-10	TG1	18:28	18:43	00:15:00	FP	HHbearingtemperature
26-Mar-10	TG1	19:08	19:41	00:33:00	FP	HHbearingtemperature
26-Mar-10	TG1	19:59	20:16	00:17:00	FP	HHbearingtemperature
26-Mar-10	TG1	21:03	21:30	00:27:00	FP	HHbearingtemperature
26-Mar-10	TG2	16:00	17:16	01:16:00	FP	Powerhouseflooding
26-Mar-10	TG2	17:20	19:13	01:53:00	FP	Powerhouseflooding
27-Mar-10	TG1	15:41	16:15	00:34:00	FP	HHbearingtemperature
27-Mar-10	TG1	16:36	18:03	01:27:00	FP	HHbearingtemperature
27-Mar-10	TG1	18:03	19:03	01:00:00	FP	HHbearingtemperature
27-Mar-10	TG1	19:09	19:52	00:43:00	FP	HHbearingtemperature
27-Mar-10	TG1	19:57	20:20	00:23:00	FP	HHbearingtemperature
27-Mar-10	TG1	20:26	21:18	00:52:00	FP	HHbearingtemperature
27-Mar-10	TG1	21:25	22:33	01:08:00	FP	HHbearingtemperature
27-Mar-10	TG1	22:45	23:03	00:18:00	FP	HHbearingtemperature
27-Mar-10	TG1	23:09	23:59	00:50:00	FP	HHbearingtemperature
27-Mar-10	TG2	16:29	20:19	03:50:00	FP	Axialbearingtemp,high
27-Mar-10	TG2	20:25	23:27	03:02:00	FP	stuffingboxtemperaturehigh
28-Mar-10	TG1	00:00	00:44	00:44:00	FP	HHbearingtemperature
28-Mar-10	TG1	01:00	02:14	01:14:00	FP	HHbearingtemperature
28-Mar-10	TG1	02:20	03:22	01:02:00	FP	HHbearingtemperature

28-Mar-10	TG1	04:00	04:56	00:56:00	FP	HHbearingtemperature
28-Mar-10	TG1	05:00	06:30	01:30:00	FP	Stuffingboxtemperature
28-Mar-10	TG1	08:26	08:48	00:22:00	FP	HHbearingtemperature
28-Mar-10	TG1	14:12	14:43	00:31:00	FP	HHbearingtemperature
28-Mar-10	TG1	16:47	17:28	00:41:00	FP	HHbearingtemperature
28-Mar-10	TG1	18:55	19:22	00:27:00	FP	HHbearingtemperature
28-Mar-10	TG1	19:53	20:10	00:17:00	FG	33LH1ECBtripped
28-Mar-10	TG1	22:19	22:39	00:20:00	FP	Bearingtemperaturehigh
28-Mar-10	TG1	23:31	00:00	00:29:00	FP	Bearingtemperaturehigh
28-Mar-10	TG2	04:13	06:18	02:05:00	FP	Axialbearingtemp,high
28-Mar-10	TG2	06:21	20:11	13:50:00	FP	stuffingboxtemperaturehigh
29-Mar-10	TG1	00:00	00:07	00:07:00	FP	Bearingtemperaturehigh
29-Mar-10	TG1	00:39	01:06	00:27:00	FP	Bearingtemperaturehigh
29-Mar-10	TG1	02:19	03:00	00:41:00	FP	Bearingtemperaturehigh
30-Mar-10	TG1	00:22	00:38	00:16:00	FP	Bearingtemperaturehigh
31-Mar-10	TG1	01:07	01:24	00:17:00	FP	Bearingtemperaturehigh
31-Mar-10	TG1	01:52	02:12	00:20:00	FP	Bearingtemperaturehigh
31-Mar-10	TG1	02:28	15:56	13:28:00	FP	Bearingtemperaturehigh
31-Mar-10	TG1	17:45	18:50	01:05:00	FP	Bearingtemperaturehigh
31-Mar-10	TG1	20:31	20:46	00:15:00	FP	Bearingtemperaturehigh
31-Mar-10	TG2	11:05	17:58	06:53:00	FP	Forebaytrashrackblocked
01-Apr-10	TG1	04:30	04:53	00:23:00	FP	DEAxialbearingtemp.High
01-Apr-10	TG1	17:19	18:06	00:47:00	FG	Gridfailure
01-Apr-10	TG1	18:16	18:35	00:19:00	FG	Gridfailure
01-Apr-10	TG1	18:45	19:59	01:14:00	FG	Gridfailure
01-Apr-10	TG1	20:26	23:59	03:33:00	FG	Gridfailure
01-Apr-10	TG2	17:19	23:59	06:40:00	FG	Gridfailure
02-Apr-10	TG1	00:00	13:22	13:22:00	FG	Gridfailure
02-Apr-10	TG1	14:35	14:50	00:15:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	15:00	15:25	00:25:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	15:45	16:14	00:29:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	17:26	17:43	00:17:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	20:52	21:15	00:23:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	21:48	22:15	00:27:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG1	23:05	23:31	00:26:00	FP	DEAxialbearingtemp.High
02-Apr-10	TG2	00:00	20:38	20:38:00	FG	Gridfailure
03-Apr-10	TG1	00:08	00:26	00:18:00	FP	DEAxialbearingtemp.High
04-Apr-10	TG1	22:04	22:24	00:20:00	FM	Lowwaterflow
07-Apr-10	TG1	19:54	20:38	00:44:00	FG	Gridfailure
07-Apr-10	TG2	19:54	22:09	02:15:00	FG	Gridfailure
08-Apr-10	TG1	10:19	10:36	00:17:00	FG	Gridfailure
08-Apr-10	TG2	10:19	20:25	10:06:00	FG	Gridfailure
12-Apr-10	TG1	08:18	12:28	04:10:00	FM	Lowwaterflow
12-Apr-10	TG1	13:25	14:26	01:01:00	FM	Lowwaterflow
12-Apr-10	TG1	22:00	23:59	01:59:00	FM	Lowwaterflow
12-Apr-10	TG2	14:38	18:27	03:49:00	FP	LeakingTX2
13-Apr-10	TG1	00:00	00:46	00:46:00	FM	Lowwaterflow
13-Apr-10	TG1	02:40	02:56	00:16:00	FP	DEAxialbearingtemp.High
13-Apr-10	TG1	06:59	08:43	01:44:00	FG	Gridfailure
13-Apr-10	TG1	08:47	09:04	00:17:00	FG	Gridfailure
13-Apr-10	TG1	10:49	11:08	00:19:00	FG	Gridfailure
13-Apr-10	TG1	13:23	14:13	00:50:00	FM	Lowwaterflow
13-Apr-10	TG1	14:51	15:41	00:50:00	FP	DEAxialbearingtemp.High

13-Apr-10	TG1	15:52	19:16	03:24:00	FP	DEAxialbearingtemp.High
13-Apr-10	TG1	19:30	20:27	00:57:00	FP	StuffingboxtempHH
13-Apr-10	TG1	20:43	21:06	00:23:00	FP	StuffingboxtempHH
13-Apr-10	TG1	21:11	21:30	00:19:00	FP	StuffingboxtempHH
13-Apr-10	TG1	21:39	22:29	00:50:00	FP	StuffingboxtempHH
13-Apr-10	TG1	22:45	23:01	00:16:00	FP	DEAxialbearingtemp.High
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
13-Apr-10	TG1	23:21	23:44	00:23:00	FP	DEAxialbearingtemp.High
13-Apr-10	TG1	23:59	00:00	00:01:00	FP	DEAxialbearingtemp.High
13-Apr-10	TG2	07:17	15:45	08:28:00	FG	Gridfailure
14-Apr-10	TG1	00:00	00:14	00:14:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	01:03	01:40	00:37:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	04:36	04:53	00:17:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	05:45	06:00	00:15:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	06:38	06:59	00:21:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	07:16	07:31	00:15:00	FP	DEAxialbearingtemp.High
14-Apr-10	TG1	14:12	14:56	00:44:00	FG	Gridfailure
14-Apr-10	TG2	14:12	16:53	02:41:00	FG	Gridfailure
15-Apr-10	TG1	02:44	03:00	00:16:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	03:22	03:45	00:23:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	04:03	04:22	00:19:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	04:35	04:53	00:18:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	05:16	05:35	00:19:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	05:49	06:14	00:25:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	06:35	07:04	00:29:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	07:11	07:43	00:32:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	08:00	08:26	00:26:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	08:49	09:22	00:33:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	09:52	10:10	00:18:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	10:28	10:41	00:13:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	11:16	11:29	00:13:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	13:29	13:40	00:11:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	14:28	14:50	00:22:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	15:25	15:48	00:23:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG1	16:41	17:02	00:21:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	04:31	05:35	01:04:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	06:09	07:15	01:06:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	07:54	09:51	01:57:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	10:18	11:34	01:16:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	13:31	14:40	01:09:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	15:23	17:02	01:39:00	FP	DEAxialbearingtemp.High
15-Apr-10	TG2	17:28	18:55	01:27:00	FP	DEAxialbearingtemp.High
17-Apr-10	TG1	19:48	20:13	00:25:00	FG	Gridfailure
17-Apr-10	TG2	19:48	20:43	00:55:00	FG	Gridfailure
18-Apr-10	TG1	00:00	00:28	00:28:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	00:37	00:55	00:18:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	01:00	01:34	00:34:00	FP	StuffingboxtempHH
18-Apr-10	TG1	02:05	02:21	00:16:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	02:28	02:43	00:15:00	FP	Waterflowforaircoolers

18-Apr-10	TG1	03:06	03:34	00:28:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	03:39	04:10	00:31:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	06:26	07:00	00:34:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	08:22	09:36	01:14:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	09:52	10:40	00:48:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	11:06	11:30	00:24:00	FP	StuffingboxtempHH
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
18-Apr-10	TG1	11:48	12:09	00:21:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	12:36	12:51	00:15:00	FP	DEAxialbearingtemp.High
18-Apr-10	TG1	13:06	13:19	00:13:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG1	10:31	11:34	01:03:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG1	13:51	14:40	00:49:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG1	18:20	18:55	00:35:00	FP	StuffingboxtempHH
19-Apr-10	TG1	20:41	20:57	00:16:00	FP	StuffingboxtempHH
19-Apr-10	TG1	21:03	21:28	00:25:00	FP	StuffingboxtempHH
19-Apr-10	TG1	22:24	23:40	01:16:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG1	23:42	00:00	00:18:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG2	14:25	15:20	00:55:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG2	15:50	22:50	07:00:00	FP	DEAxialbearingtemp.High
19-Apr-10	TG2	23:25	00:00	00:35:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	00:00	00:07	00:07:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	00:11	00:27	00:16:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	00:35	01:22	00:47:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	01:30	01:50	00:20:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	02:19	02:38	00:19:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	02:51	03:53	01:02:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	04:10	04:42	00:32:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	04:58	05:14	00:16:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	05:27	05:50	00:23:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	06:06	06:51	00:45:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	07:31	08:13	00:42:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	08:50	10:20	01:30:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG1	12:03	12:48	00:45:00	FP	StuffingboxtempHH
20-Apr-10	TG1	14:18	15:08	00:50:00	FP	StuffingboxtempHH
20-Apr-10	TG1	15:18	15:56	00:38:00	FP	StuffingboxtempHH
20-Apr-10	TG2	00:00	00:43	00:43:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG2	00:47	02:00	01:13:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG2	02:06	04:55	02:49:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG2	05:22	07:10	01:48:00	FP	DEAxialbearingtemp.High
20-Apr-10	TG2	12:01	16:53	04:52:00	FP	DEAxialbearingtemp.High
21-Apr-10	TG1	04:25	04:43	00:18:00	FP	DERadialbearingtemp.High
21-Apr-10	TG2	14:00	18:33	04:33:00	FP	DEAxialbearingtemp.High
21-Apr-10	TG2	19:33	23:38	04:05:00	FP	DEAxialbearingtemp.High
22-Apr-10	TG1	00:00	00:03	00:03:00	FP	DERadialbearingtemp.High
22-Apr-10	TG1	16:48	17:06	00:18:00	FG	Gridfailure
22-Apr-10	TG1	20:25	20:42	00:17:00	FP	DERadialbearingtemp.High
22-Apr-10	TG1	20:57	21:20	00:23:00	FP	DERadialbearingtemp.High
22-Apr-10	TG2	03:58	12:56	08:58:00	FP	DEAxialbearingtemp.High
22-Apr-10	TG2	16:48	23:59	07:11:00	FG	Gridfailure

23-Apr-10	TG1	06:34	07:03	00:29:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	07:38	08:01	00:23:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	08:14	09:49	01:35:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	09:56	10:41	00:45:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	11:14	13:25	02:11:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	13:29	17:00	03:31:00	FP	DERadialbearingtemp.High
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
23-Apr-10	TG1	17:22	17:57	00:35:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	18:10	19:10	01:00:00	FP	DERadialbearingtemp.High
23-Apr-10	TG1	19:31	20:05	00:34:00	FP	DERadialbearingtemp.High
23-Apr-10	TG2	00:00	23:59	23:59:00	FP	DEAxialbearingtemp.High
24-Apr-10	TG1	10:59	11:15	00:16:00	FP	Powerhouseflooding
24-Apr-10	TG1	11:17	11:56	00:39:00	FP	CCTBREAKEROPENED
24-Apr-10	TG1	11:58	13:43	01:45:00	FP	DERadialbearingtemp.High
24-Apr-10	TG2	00:00	18:11	18:11:00	FP	DEAxialbearingtemp.High
25-Apr-10	TG1	18:50	19:19	00:29:00	FP	DERadialbearingtemp.High
25-Apr-10	TG2	00:00	18:59	18:59:00	FP	DEAxialbearingtemp.High
25-Apr-10	TG2	19:03	23:07	04:04:00	FP	DERadialbearingtemp.High
25-Apr-10	TG2	23:27	00:00	00:33:00	FP	DERadialbearingtemp.High
26-Apr-10	TG1	00:50	01:08	00:18:00	FG	Gridfailure
26-Apr-10	TG1	18:41	19:24	00:43:00	FG	Gridfailure
26-Apr-10	TG2	01:20	19:24	18:04:00	FP	DERadialbearingtemp.High
26-Apr-10	TG2	19:26	22:29	03:03:00	FP	Wicketgateprotectionpinbroken
26-Apr-10	TG2	22:44	23:58	01:14:00	FP	DERadialbearingtemp.High
27-Apr-10	TG1	00:49	01:07	00:18:00	FP	DERadialbearingtemp.High
27-Apr-10	TG1	02:15	02:58	00:43:00	FP	DERadialbearingtemp.High
27-Apr-10	TG1	03:31	03:48	00:17:00	FP	DERadialbearingtemp.High
27-Apr-10	TG1	05:49	06:40	00:51:00	FP	DERadialbearingtemp.High
27-Apr-10	TG1	15:41	16:07	00:26:00	SP	MAVELtestsonlubricationunit
27-Apr-10	TG1	17:49	18:38	00:49:00	FG	Gridfailure
27-Apr-10	TG1	20:36	21:13	00:37:00	FP	DEAxialbearingtemp.High
27-Apr-10	TG1	22:09	22:51	00:42:00	FP	DEAxialbearingtemp.High
27-Apr-10	TG2	00:23	08:52	08:29:00	FP	DERadialbearingtemp.High
27-Apr-10	TG2	15:14	18:31	03:17:00	SP	MAVELtestsonlubricationunit
28-Apr-10	TG1	00:35	01:46	01:11:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG1	03:00	03:44	00:44:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG1	06:10	07:00	00:50:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG1	12:51	13:28	00:37:00	FG	Gridfailure
28-Apr-10	TG1	17:08	18:09	01:01:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG1	21:21	21:53	00:32:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG1	23:44	00:00	00:16:00	FP	DEAxialbearingtemp.High
28-Apr-10	TG2	12:51	17:43	04:52:00	FG	Gridfailure
28-Apr-10	TG2	18:38	19:37	00:59:00	FP	DERadialbearingtemp.High
28-Apr-10	TG2	19:50	23:53	04:03:00	FP	DERadialbearingtemp.High
29-Apr-10	TG1	00:00	00:19	00:19:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	01:21	01:43	00:22:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	02:58	03:15	00:17:00	FP	DERadialbearingtemp.High
29-Apr-10	TG1	12:01	12:35	00:34:00	FG	Gridfailure
29-Apr-10	TG1	13:33	14:03	00:30:00	FP	DERadialbearingtemp.High

29-Apr-10	TG1	14:14	15:02	00:48:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	15:57	16:37	00:40:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	18:20	19:08	00:48:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	19:27	19:40	00:13:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	20:32	20:46	00:14:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	21:23	21:46	00:23:00	FP	DEAxialbearingtemp.High
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
29-Apr-10	TG1	21:59	22:11	00:12:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	22:45	23:00	00:15:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG1	23:31	23:48	00:17:00	FP	DEAxialbearingtemp.High
29-Apr-10	TG2	12:03	13:48	01:45:00	FP	DERadialbearingtemp.High
29-Apr-10	TG2	14:23	16:07	01:44:00	FP	DERadialbearingtemp.High
29-Apr-10	TG2	16:48	18:30	01:42:00	FP	DERadialbearingtemp.High
29-Apr-10	TG2	19:00	21:31	02:31:00	FP	DERadialbearingtemp.High
30-Apr-10	TG1	06:01	06:51	00:50:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	07:41	07:58	00:17:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	08:53	09:19	00:26:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	10:11	10:27	00:16:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	11:10	11:48	00:38:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	14:59	15:20	00:21:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	16:17	18:19	02:02:00	FP	DEAxialbearingtemp.High
30-Apr-10	TG1	19:04	23:59	04:55:00	FG	Gridfailure
30-Apr-10	TG2	08:54	10:05	01:11:00	FP	DERadialbearingtemp.High
30-Apr-10	TG2	16:19	23:59	07:40:00	FG	Gridfailure
01-May-10	TG1	00:00	17:16	17:16:00	FG	Gridfailure
01-May-10	TG1	18:48	19:45	00:57:00	FP	DEAxialbearingtemp.High
01-May-10	TG1	20:54	21:11	00:17:00	FP	DEAxialbearingtemp.High
01-May-10	TG1	21:35	22:00	00:25:00	FP	DEAxialbearingtemp.High
01-May-10	TG1	22:14	22:44	00:30:00	FP	DEAxialbearingtemp.High
01-May-10	TG1	23:05	23:59	00:54:00	FP	DEAxialbearingtemp.High
01-May-10	TG2	00:00	18:59	18:59:00	FG	Gridfailure
01-May-10	TG2	19:40	21:05	01:25:00	FP	DERadialbearingtemp.High
01-May-10	TG2	21:50	22:53	01:03:00	FP	DERadialbearingtemp.High
01-May-10	TG2	23:32	00:00	00:28:00	FP	DERadialbearingtemp.High
02-May-10	TG1	00:00	00:05	00:05:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	00:33	01:06	00:33:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	01:16	02:00	00:44:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	03:16	03:51	00:35:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	04:10	04:43	00:33:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	04:58	05:18	00:20:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	05:27	05:56	00:29:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	06:19	06:54	00:35:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	07:15	08:30	01:15:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	09:12	10:18	01:06:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	10:46	11:10	00:24:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	11:21	12:06	00:45:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	12:29	13:40	01:11:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	14:09	14:40	00:31:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	14:55	15:15	00:20:00	FP	DEAxialbearingtemp.High

02-May-10	TG1	15:27	16:16	00:49:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	16:33	17:05	00:32:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	17:22	18:26	01:04:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	18:54	19:58	01:04:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	20:37	21:33	00:56:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	22:00	22:31	00:31:00	FP	DEAxialbearingtemp.High
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
02-May-10	TG1	22:48	23:08	00:20:00	FP	DEAxialbearingtemp.High
02-May-10	TG1	23:23	00:00	00:37:00	FP	DEAxialbearingtemp.High
02-May-10	TG2	03:17	07:38	04:21:00	FP	DERadialbearingtemp.High
02-May-10	TG2	17:12	19:04	01:52:00	FP	DERadialbearingtemp.High
02-May-10	TG2	19:26	20:31	01:05:00	FP	DERadialbearingtemp.High
02-May-10	TG2	21:45	22:58	01:13:00	FP	DEAxialbearingtemp.High
02-May-10	TG2	23:24	00:00	00:36:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	00:00	00:31	00:31:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	00:45	01:06	00:21:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	01:54	02:13	00:19:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	02:31	02:52	00:21:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	03:22	03:42	00:20:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	04:24	04:46	00:22:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	05:37	06:44	01:07:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	06:47	07:20	00:33:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	08:00	08:38	00:38:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	09:57	10:29	00:32:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	11:47	12:16	00:29:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	13:40	14:23	00:43:00	FP	DEAxialbearingtemp.High
03-May-10	TG1	16:35	17:04	00:29:00	FP	DEAxialbearingtemp.High
03-May-10	TG2	00:46	15:12	14:26:00	FP	DEAxialbearingtemp.High
03-May-10	TG2	15:58	17:26	01:28:00	FP	DEAxialbearingtemp.High
03-May-10	TG2	18:42	22:40	03:58:00	FP	DEAxialbearingtemp.High
04-May-10	TG2	14:34	18:37	04:03:00	FP	DEAxialbearingtemp.High
05-May-10	TG1	17:47	18:03	00:16:00	FP	DEAxialbearingtemp.High
05-May-10	TG1	18:18	18:56	00:38:00	FP	DEAxialbearingtemp.High
05-May-10	TG1	22:07	22:54	00:47:00	FP	DEAxialbearingtemp.High
05-May-10	TG2	18:20	21:53	03:33:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	00:23	02:00	01:37:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	03:29	04:41	01:12:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	05:40	06:11	00:31:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	08:29	09:03	00:34:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	10:04	10:28	00:24:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	17:30	17:48	00:18:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	19:08	19:39	00:31:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	20:03	20:22	00:19:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	20:27	21:03	00:36:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	21:23	21:46	00:23:00	FP	DEAxialbearingtemp.High
06-May-10	TG1	23:19	23:43	00:24:00	FP	DEAxialbearingtemp.High
06-May-10	TG2	03:35	09:03	05:28:00	FP	DEAxialbearingtemp.High
06-May-10	TG2	09:45	18:04	08:19:00	FP	DEAxialbearingtemp.High
06-May-10	TG2	20:03	21:50	01:47:00	FP	DEAxialbearingtemp.High

06-May-10	TG2	23:27	00:00	00:33:00	FP	DEAxialbearingtemp.High
07-May-10	TG1	00:21	01:30	01:09:00	FP	DEAxialbearingtemp.High
07-May-10	TG1	04:41	05:16	00:35:00	FP	DEAxialbearingtemp.High
07-May-10	TG1	14:23	15:01	00:38:00	FP	DEAxialbearingtemp.High
07-May-10	TG1	17:55	18:33	00:38:00	FP	DEAxialbearingtemp.High
07-May-10	TG1	22:26	22:50	00:24:00	FP	DEAxialbearingtemp.High
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
07-May-10	TG1	23:41	23:59	00:18:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	00:00	00:04	00:04:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	00:32	00:53	00:21:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	02:08	02:36	00:28:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	03:19	04:10	00:51:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	06:52	07:51	00:59:00	FP	DEAxialbearingtemp.High
08-May-10	TG1	18:27	18:52	00:25:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	00:00	01:47	01:47:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	02:14	03:38	01:24:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	07:06	08:43	01:37:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	09:10	10:53	01:43:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	12:05	15:10	03:05:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	18:28	20:57	02:29:00	FP	DEAxialbearingtemp.High
08-May-10	TG2	23:49	23:59	00:10:00	FP	DEAxialbearingtemp.High
09-May-10	TG1	18:31	19:26	00:55:00	FP	DEAxialbearingtemp.High
09-May-10	TG1	20:42	21:16	00:34:00	FP	DEAxialbearingtemp.High
09-May-10	TG1	22:40	23:10	00:30:00	FP	DEAxialbearingtemp.High
09-May-10	TG2	00:00	06:07	06:07:00	FP	DEAxialbearingtemp.High
09-May-10	TG2	23:43	23:59	00:16:00	FP	DEAxialbearingtemp.High
10-May-10	TG1	00:00	00:04	00:04:00	FP	DEAxialbrghigh
10-May-10	TG1	05:43	06:01	00:18:00	FP	DEAxialbrghigh
10-May-10	TG1	09:40	09:59	00:19:00	FP	DEAxialbrghigh
10-May-10	TG1	15:34	16:01	00:27:00	FG	Overfrequency
10-May-10	TG1	21:30	21:47	00:17:00	FP	DEAxialbrghigh
10-May-10	TG1	22:49	23:07	00:18:00	FP	DEAxialbrghigh
10-May-10	TG1	23:19	00:00	00:41:00	FP	DEAxialbrghigh
10-May-10	TG2	01:15	02:42	01:27:00	FP	DEAxialbearingtemphigh
10-May-10	TG2	06:06	07:09	01:03:00	FP	DEAxialbearingtemphigh
10-May-10	TG2	07:54	23:59	16:05:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
11-May-10	TG1	06:03	06:21	00:18:00	FP	DEAxialbrghigh
11-May-10	TG1	08:02	08:28	00:26:00	FP	DEAxialbrghigh
11-May-10	TG1	15:02	16:15	01:13:00	SP	RequestbyMAVEL
11-May-10	TG1	17:48	18:11	00:23:00	FP	DEAxialbrghigh
11-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
12-May-10	TG1	14:24	14:50	00:26:00	FP	Waterflowintoturbine
12-May-10	TG1	14:50	17:16	02:26:00	FP	Onesensor(shearpin)ofwicketgatebroken
12-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
13-May-10	TG1	14:18	15:33	01:15:00	SP	ShutdownrequestbyMAVEL
13-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling

						systemandDEaxialbearing.
14-May-10	TG1	14:00	23:59	09:59:00	SP	ShutdownrequestbyMAVEL
14-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
15-May-10	TG1	00:00	23:59	23:59:00	SP	ShutdownrequestbyMAVEL
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
15-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
16-May-10	TG1	00:00	15:25	15:25:00	SP	ShutdownrequestbyMAVEL
16-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
17-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
18-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
19-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
20-May-10	TG1	05:33	05:54	00:21:00	FP	HHOutletAirtempduetochockedfilters
20-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
21-May-10	TG1	14:03	18:29	04:26:00	SP	ShutdownrequestbyMAVEL
21-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
22-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
23-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
24-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
25-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
26-May-10	TG1	14:19	18:51	04:32:00	FG	Gridfailure
26-May-10	TG1	19:16	19:33	00:17:00	FG	Gridfailure
26-May-10	TG1	23:27	00:00	00:33:00	FG	Gridfailure
26-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
27-May-10	TG1	00:00	08:05	08:05:00	FG	Gridfailure
27-May-10	TG1	15:16	16:37	01:21:00	FG	Gridfailure
27-May-10	TG1	20:17	00:00	03:43:00	FP	DEaxialbearingtemp.HH(couplingforAClubricationpumpbroken.Bearingsuspecteddamaged)
27-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.
28-May-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAClubricationpumpbroken.Bearingsuspecteddamaged)
28-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcoolingsystemandDEaxialbearing.

29-May-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
29-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
30-May-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
30-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
31-May-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
31-May-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
01-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
01-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
02-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
02-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
03-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
03-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
04-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
04-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
05-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
05-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
06-Jun-10	TG1	00:00	23:59	23:59:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
06-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
07-Jun-10	TG1	00:00	19:41	19:41:00	FP	DEaxialbearingtemp.HH(couplingforAC lubricationpumpbroken.Bearingsuspected damaged)
07-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling

						systemandDEaxialbearing.
08-Jun-10	TG1	11:15	12:59	01:44:00	SP	MAVELrequeststoreplaceFiltersandcooler
08-Jun-10	TG1	18:21	18:36	00:15:00	FG	PowerFlactuation
08-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
09-Jun-10	TG1	15:00	16:19	01:19:00	SP	MAVELrequesttoinstallamorerobustoil cooler.
09-Jun-10	TG1	21:56	22:16	00:20:00	FG	Overfrequencyfromthegrid
09-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
10-Jun-10	TG1	11:03	11:36	00:33:00	SP	Modificationonoillubeaggregate
10-Jun-10	TG1	14:23	18:27	04:04:00	SP	Changingthelub.pumpwithoneofhigher capacity
10-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
11-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
12-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
13-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
14-Jun-10	TG1	18:57	19:17	00:20:00	FG	Overfrequencyfromthegrid
14-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
15-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
16-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
17-Jun-10	TG1	17:43	17:57	00:14:00	FP	Coolingwaterflowintothe turbine
17-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
18-Jun-10	TG1	17:58	18:16	00:18:00	FG	Unit33H1Eopened
18-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
19-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
20-Jun-10	TG1	17:06	17:26	00:20:00	FG	Unit33H1Eopened
20-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
21-Jun-10	TG1	10:38	11:12	00:34:00	FG	Gridfailure
21-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
22-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
23-Jun-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
24-Jun-10	TG1	14:06	15:10	01:04:00	SP	TestingthemachinebyMavelstaffs

24-Jun-10	TG1	15:21	15:58	00:37:00	FP	Trippedduetocoolerwaterintoturbine.
24-Jun-10	TG2	00:00	18:09	18:09:00	FP	Breakdown.MAVELteamcheckingcooling systemandDEaxialbearing.
25-Jun-10	TG1	14:30	14:51	00:21:00	FP	Theunitshutdownduetopowerhouse flooding
25-Jun-10	TG1	19:13	19:34	00:21:00	SP	TestingTG2byMavelstaffs
Outage				Duration	Type	Problem Description
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
25-Jun-10	TG2	00:00	19:00	19:00:00	SP	Testingtheunithavingworkedonthebearing
25-Jun-10	TG2	19:40	22:42	03:02:00	SP	Waitingforfinaltesting
26-Jun-10	TG1	08:45	09:57	01:12:00	SP	TestingTG2byMavelstaffs
26-Jun-10	TG1	16:37	19:13	02:36:00	SP	TestingTG2byMavelstaffs
26-Jun-10	TG2	00:01	16:02	16:01:00	SP	MAVELteamtesting.
26-Jun-10	TG2	16:10	23:59	07:49:00	SP	MAVELteamtesting.
27-Jun-10	TG2	00:01	13:44	13:43:00	SP	MAVELteamtesting.
27-Jun-10	TG2	14:14	22:00	07:46:00	SP	MAVELteamtesting.
28-Jun-10	TG2	00:47	13:10	12:23:00	FM	LOWWATERLEVEL
28-Jun-10	TG2	21:12	23:59	02:47:00	SP	MAVELteamtesting.
29-Jun-10	TG1	12:42	13:54	01:12:00	SP	requestfromNkendatostopthemachine
29-Jun-10	TG1	14:28	14:45	00:17:00	FG	Overfrequencyfromthegrid
29-Jun-10	TG2	07:50	23:59	16:09:00	FM	LOWWATERLEVEL
30-Jun-10	TG2	00:00	23:59	23:59:00	FM	LOWWATERLEVEL
01-Jul-10	TG1	01:05	01:22	00:17:00	FG	Gridproblem.Unit33H1Eatsubstation opened
01-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
02-Jul-10	TG1	21:09	21:58	00:49:00	FG	Gridfailure(132KVoff)
02-Jul-10	TG1	22:07	22:29	00:22:00	FG	Gridfailure(132KVoff)
02-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
03-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
04-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
05-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
06-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
07-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
08-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
09-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
10-Jul-10	TG2	00:00	23:59	23:59:00	FP	Breakdown.MAVELteamworkingonthe bearing
11-Jul-10	TG2	00:00	14:29	14:29:00	FP	Breakdown.MAVELteamworkingonthe bearing
12-Jul-10	TG1	11:38	11:53	00:15:00	FP	Theunitshutdownduetopowerhouse flooding
12-Jul-10	TG1	14:51	15:11	00:20:00	SP	TestingTG2(MAVELstaff)
12-Jul-10	TG2	00:00	15:41	15:41:00	FM	Lowwaterflowintheriver
12-Jul-10	TG2	16:09	23:59	07:50:00	FM	Lowwaterflowintheriver

13-Jul-10	TG1	11:07	12:07	01:00:00	FG	Gridfailure
13-Jul-10	TG1	15:03	16:24	01:21:00	FG	Gridfailure
13-Jul-10	TG2	00:00	09:20	09:20:00	FM	Lowwaterflowintheriver
14-Jul-10	TG1	11:18	13:49	02:31:00	FG	Gridfailure
14-Jul-10	TG2	00:00	13:49	13:49:00	FM	Lowwaterflowintheriver
14-Jul-10	TG2	18:23	23:42	05:19:00	FG	Gridproblem(Overcurrenttrip).
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
15-Jul-10	TG1	06:28	08:51	02:23:00	FM	Lowwaterflowintheriver
15-Jul-10	TG1	10:01	10:20	00:19:00	FM	Lowwaterflowintheriver
15-Jul-10	TG1	20:18	23:59	03:41:00	FM	Lowwaterflowintheriver
16-Jul-10	TG1	00:00	12:43	12:43:00	FM	Lowwaterflowintheriver
16-Jul-10	TG1	14:59	15:26	00:27:00	FM	Lowwaterflowintheriver
16-Jul-10	TG2	10:23	12:42	02:19:00	FG	Gridemergencyshutdown
17-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
18-Jul-10	TG1	18:37	18:59	00:22:00	FG	Gridproblem.Breaker33LH1EinBugoye substationopened
18-Jul-10	TG2	00:00	09:52	09:52:00	FM	Lowwaterflowintheriver
19-Jul-10	TG1	09:56	17:40	07:44:00	FM	Lowwaterflowintheriver
19-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
20-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
21-Jul-10	TG2	12:00	23:59	11:59:00	FM	Lowwaterflowintheriver
22-Jul-10	TG1	12:58	21:24	08:26:00	FG	Gridfailure
22-Jul-10	TG2	00:00	04:27	04:27:00	FM	Lowwaterflowintheriver
23-Jul-10	TG1	15:54	16:13	00:19:00	FG	Gridfailure
23-Jul-10	TG1	16:31	16:45	00:14:00	FG	Gridfailure
23-Jul-10	TG1	18:32	20:18	01:46:00	FG	Gridfailure
23-Jul-10	TG2	00:00	11:13	11:13:00	FM	Lowwaterflowintheriver
23-Jul-10	TG2	11:47	16:50	05:03:00	FM	Lowwaterflowintheriver
23-Jul-10	TG2	17:20	23:59	06:39:00	FG	Gridfailure
24-Jul-10	TG1	10:04	10:28	00:24:00	SP	TestsbyUETCLstaff
24-Jul-10	TG1	11:01	11:25	00:24:00	SP	TestsbyUETCLstaff
24-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
25-Jul-10	TG2	00:00	12:54	12:54:00	FM	Lowwaterflowintheriver
26-Jul-10	TG1	00:12	08:15	08:03:00	FG	Gridfailure
26-Jul-10	TG2	10:00	19:04	09:04:00	FM	Lowwaterflowintheriver
26-Jul-10	TG2	19:43	19:59	00:16:00	FM	Lowwaterflowintheriver
27-Jul-10	TG2	00:41	06:21	05:40:00	FM	Lowwaterflowintheriver
27-Jul-10	TG2	07:18	23:59	16:41:00	FM	Lowwaterflowintheriver
28-Jul-10	TG1	12:04	13:14	01:10:00	FM	Lowwaterflowintheriver
28-Jul-10	TG2	00:00	15:49	15:49:00	FM	Lowwaterflowintheriver
29-Jul-10	TG2	06:35	23:59	17:24:00	FM	Lowwaterflowintheriver
30-Jul-10	TG1	15:31	15:46	00:15:00	FG	Gridproblem.Unit33H1Eatsubstation opened
30-Jul-10	TG1	18:57	19:15	00:18:00	FG	Gridproblem.Unit33H1Eatsubstation opened
30-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
31-Jul-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
01-Aug-10	TG1	18:18	18:46	00:28:00	FG	Gridproblem.Unit33H1Eatsubstation

						opened
01-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
02-Aug-10	TG2	00:00	08:04	08:04:00	FM	Lowwaterflowintheriver
03-Aug-10	TG1	08:11	17:15	09:04:00	FM	Lowwaterflowintheriver
03-Aug-10	TG1	17:37	18:25	00:48:00	FM	Lowwaterflowintheriver
03-Aug-10	TG1	18:54	22:08	03:14:00	FM	Lowwaterflowintheriver
03-Aug-10	TG2	00:00	17:35	17:35:00	FM	Lowwaterflowintheriver
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
03-Aug-10	TG2	18:13	00:00	05:47:00	FG	Gridproblem.Unit33H1Eatsubstation opened
04-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
05-Aug-10	TG1	14:24	23:59	09:35:00	FM	Lowwaterflowintheriver
05-Aug-10	TG2	00:00	13:58	13:58:00	FM	Lowwaterflowintheriver
06-Aug-10	TG1	00:00	13:31	13:31:00	FM	Lowwaterflowintheriver
06-Aug-10	TG1	13:55	23:59	10:04:00	FM	Lowwaterflowintheriver
06-Aug-10	TG2	13:10	14:25	01:15:00	FG	Gridfailure
07-Aug-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
07-Aug-10	TG2	13:54	15:10	01:16:00	FG	Gridfailure
08-Aug-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
09-Aug-10	TG1	00:00		00:00:00	FM	Lowwaterflowintheriver
11-Aug-10	TG1	17:21	17:42	00:21:00	FG	Gridfailure(overcurrent)
11-Aug-10	TG2	17:18	18:18	01:00:00	FG	Gridproblem(overcurrent)
12-Aug-10	TG1	04:27	04:58	00:31:00	FG	Gridfailure.TransformerbreakeratNkenda trippedduetoafaultalongFortPortalfeeder.
12-Aug-10	TG1	09:42	10:10	00:28:00	FG	Gridfailure(overcurrent)
12-Aug-10	TG2	04:27	10:00	05:33:00	FG	TransformeratNkendafailedduetofault alongFortPortalfeeder.
13-Aug-10	TG1	10:03	10:25	00:22:00	FG	Gridfailure(overcurrent)
13-Aug-10	TG1	10:46	12:15	01:29:00	FM	Lowwaterflowintheriver
13-Aug-10	TG1	18:29	19:42	01:13:00	FG	Gridfailure.TransformerbreakeratNkenda tripped.
13-Aug-10	TG2	10:04	19:33	09:29:00	FG	Gridproblem(overcurrent)
14-Aug-10	TG1	19:51	22:43	02:52:00	FG	Gridfailure.TransformerbreakeratNkenda tripped.
14-Aug-10	TG2	11:31	22:46	11:15:00	FP	Compressormotorburnt
15-Aug-10	TG1	11:45	12:22	00:37:00	FG	Gridfailure.TransformerbreakeratNkenda tripped.
15-Aug-10	TG2	11:45	20:05	08:20:00	FG	Gridfailure.TransformerbreakeratNkenda tripped.
15-Aug-10	TG2	21:14	22:24	01:10:00	FM	Lowwaterflowintheriver
16-Aug-10	TG2	00:00	18:00	18:00:00	FM	Lowwaterflowintheriver
16-Aug-10	TG2	19:10	23:59	04:49:00	FM	Lowwaterflowintheriver
17-Aug-10	TG2	00:35	10:02	09:27:00	FM	Lowwaterflowintheriver
18-Aug-10	TG2	09:30	14:14	04:44:00	FM	Lowwaterflowintheriver
18-Aug-10	TG2	14:54	23:59	09:05:00	FM	Lowwaterflowintheriver
19-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
20-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
21-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
22-Aug-10	TG2	00:00	08:53	08:53:00	FM	Lowwaterflowintheriver

23-Aug-10	TG1	09:00	23:59	14:59:00	FM	Lowwaterflowintheriver
23-Aug-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
24-Aug-10	TG1	00:00	00:07	00:07:00	FM	Lowwaterflowintheriver
24-Aug-10	TG1	00:20	00:40	00:20:00	FG	Gridfailure
24-Aug-10	TG2	00:00	23:59	23:59:00	FP	Airoutlettemphigh
25-Aug-10	TG1	11:55	12:30	00:35:00	FG	Gridfailure
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
25-Aug-10	TG1	12:44	00:00	11:16:00	FM	Lowwaterflowintheriver
25-Aug-10	TG2	00:00	12:34	12:34:00	FM	Lowwaterflowintheriver
26-Aug-10	TG1	21:59	22:07	00:08:00	FG	Gridfailure
26-Aug-10	TG1	22:07	23:59	01:52:00	FM	Lowwaterflowintheriver
26-Aug-10	TG2	17:10	22:07	04:57:00	FP	TG2failedduetofaultymanometerandmost ofthelubeoilgotsspilledandtheminimum leveltrippedthemachinehencerestarted TG1
27-Aug-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
28-Aug-10	TG1	00:00	17:21	17:21:00	FM	Lowwaterflowintheriver
28-Aug-10	TG2	17:11	23:59	06:48:00	FG	Gridfailure
29-Aug-10	TG2	00:00	23:24	23:24:00	FM	Lowwaterflowintheriver
30-Aug-10	TG1	16:07	17:03	00:56:00	FM	Lowwaterflowintheriver
30-Aug-10	TG1	17:58	18:41	00:43:00	FG	Gridfailure
30-Aug-10	TG2	11:17	15:11	03:54:00	FM	Lowwaterflowintheriver
30-Aug-10	TG2	17:58	18:05	00:07:00	FG	Gridfailure
31-Aug-10	TG2	16:48	20:34	03:46:00	FM	Lowwaterflowintheriver
31-Aug-10	TG2	21:29	22:12	00:43:00	FM	Lowwaterflowintheriver
01-Sep-10	TG2	08:26	14:34	06:08:00	FM	Lowwaterflowintheriver
01-Sep-10	TG2	15:52	16:10	00:18:00	FM	Lowwaterflowintheriver
02-Sep-10	TG1	14:15	15:12	00:57:00	FG	Gridfailure
02-Sep-10	TG2	14:43	23:00	08:17:00	FG	Gridfailure
03-Sep-10	TG2	02:58	07:00	04:02:00	FM	Lowwaterflowintheriver
03-Sep-10	TG2	08:20	08:46	00:26:00	FM	Lowwaterflowintheriver
04-Sep-10	TG1	08:32	08:45	00:13:00	FG	Gridproblem.Unit33H1Eatsubstation opened
04-Sep-10	TG2	08:33	20:08	11:35:00	FG	Gridproblem.Unit33H1Eatsubstation opened
06-Sep-10	TG1	19:43	20:22	00:39:00	FG	Gridfailure
06-Sep-10	TG1	21:36	22:06	00:30:00	FG	Gridfailure
06-Sep-10	TG2	19:43	22:01	02:18:00	FG	Gridfailure
07-Sep-10	TG2	16:00	21:16	05:16:00	FP	Cooler400vacsupplyfailure
08-Sep-10	TG1	08:26	10:04	01:38:00	FP	Cloggedfilters
10-Sep-10	TG1	13:15	14:09	00:54:00	FP	Stuffingboxclogged
10-Sep-10	TG1	23:07	23:59	00:52:00	FP	Coolerwaterflowintotheturbine
10-Sep-10	TG2	20:29	22:04	01:35:00	FP	Stuffingboxclogged
11-Sep-10	TG1	00:00	00:27	00:27:00	FP	Coolerwaterflowintotheturbine
11-Sep-10	TG1	08:05	08:40	00:35:00	FP	Cloggedfilters
11-Sep-10	TG1	21:08	21:51	00:43:00	FP	Stuffingboxclogged
11-Sep-10	TG1	22:05	23:08	01:03:00	FP	Stuffingboxclogged
12-Sep-10	TG1	08:25	09:30	01:05:00	FP	Coolerwaterflowintotheturbine

12-Sep-10	TG2	03:56	15:10	11:14:00	FP	Coolingwaterflowintotheturbine
13-Sep-10	TG1	20:27	21:05	00:38:00	FP	Stuffingboxhightemperaturehigh
14-Sep-10	TG1	17:37	18:26	00:49:00	FP	Coolerwaterflowintotheturbine
17-Sep-10	TG2	14:53	16:33	01:40:00	FP	Coolingwaterflowintotheturbine
18-Sep-10	TG1	15:54	16:33	00:39:00	FG	Gridfailure(OvercurrentfaultonKasese feeder)
18-Sep-10	TG2	15:54	19:59	04:05:00	FG	Gridproblem(frquencyspike55HZ)
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
20-Sep-10	TG2	19:43	20:16	00:33:00	FP	Coolingwaterflowintotheturbine
21-Sep-10	TG2	17:23	18:25	01:02:00	FP	Coolingwaterflowintotheturbine
23-Sep-10	TG1	18:09	18:30	00:21:00	FG	Gridfrequencyshotupfrom(50.02to54)HZ
23-Sep-10	TG2	18:09	21:31	03:22:00	FG	Gridfrequencyshotupfrom(50.02to54)HZ
24-Sep-10	TG1	11:32	19:11	07:39:00	FG	Gridproblem(132kVlineshutdowntoinstalla transformeratNkongesubstation)
24-Sep-10	TG2	02:48	18:11	15:23:00	FM	Lowwaterflowintheriver
24-Sep-10	TG2	18:37	23:59	05:22:00	FP	Powerhouseflooding
25-Sep-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
26-Sep-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
27-Sep-10	TG1	09:27	00:00	14:33:00	FM	Lowwaterflowintheriver
27-Sep-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
28-Sep-10	TG1	14:57	21:50	06:53:00	FM	Lowwaterflowintheriver
28-Sep-10	TG2	22:51	23:23	00:32:00	FM	Lowwaterflowintheriver
29-Sep-10	TG1	19:36	22:25	02:49:00	FG	Gridfailure
29-Sep-10	TG2	00:00	20:51	20:51:00	FM	Lowwaterflowintheriver
30-Sep-10	TG2	10:14	12:32	02:18:00	FM	Lowwaterflowintheriver
30-Sep-10	TG2	13:13	23:59	10:46:00	FM	Lowwaterflowintheriver
01-Oct-10	TG2	00:00	12:12	12:12:00	FM	Lowwaterflowintheriver
02-Oct-10	TG1	12:14	15:19	03:05:00	SP	Blackstart&Islandmodetesting
02-Oct-10	TG2	00:00	00:00	00:00:00	FM	Lowwaterflowintheriver
03-Oct-10	TG1	12:19	00:00	11:41:00	SP	Blackstart&Islandmodetesting
03-Oct-10	TG2	00:00	22:31	22:31:00	SP	Blackstart&Islandmodetesting
04-Oct-10	TG1	00:00	08:10	08:10:00	SP	Blackstart&Islandmodetesting
06-Oct-10	TG2	10:22	17:30	07:08:00	SP	Blackstart&Islandmodetesting
07-Oct-10	TG1	14:24	18:35	04:11:00	SP	Blackstart&Islandmodetesting
07-Oct-10	TG2	14:10	14:36	00:26:00	SP	Blackstart&Islandmodetesting
08-Oct-10	TG2	13:05	22:23	09:18:00	FG	Gridfailure
11-Oct-10	TG1	09:19	10:20	01:01:00	SP	Blackstart&Islandmodetesting
11-Oct-10	TG2	09:20	19:53	10:33:00	SP	Blackstart&Islandmodetesting
13-Oct-10	TG1	12:35	19:53	07:18:00	FG	Nkendashutdown
13-Oct-10	TG2	12:35	23:23	10:48:00	FG	Nkendashutdown
14-Oct-10	TG1	06:49	07:12	00:23:00	FG	Gridproblem.Voltagedropfrom34.82kVto 32.51kVopenedthelinebreakerinthe substation
14-Oct-10	TG2	06:49	17:41	10:52:00	FG	Gridproblem.Voltagedropfrom34.82kVto 32.51kVopenedthelinebreakerinthe substation
14-Oct-10	TG2	18:28	22:00	03:32:00	FP	Coolingwaterflowintotheturbine
15-Oct-10	TG1	08:44	10:30	01:46:00	FG	Gridproblem.Lugogocontrolcentercalled informingBugoyeaboutashutdownonthe

						132kVline.
15-Oct-10	TG1	12:00	13:34	01:34:00	FG	Gridproblem.Shutdownonthe132kVline.
15-Oct-10	TG1	14:14	15:36	01:22:00	FG	Gridproblem.Shutdownonthe132kVline.
15-Oct-10	TG2	08:46	15:10	06:24:00	FG	Gridproblem.Lugogocontrolcentercalled informingBugoyeaboutashutdownonthe 132kVline.
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
15-Oct-10	TG2	15:32	19:39	04:07:00	FG	Gridproblem.Voltagedropfrom34.82kVto 32.51kVopenedthelinebreakerinthe substation
17-Oct-10	TG1	07:24	07:56	00:32:00	FG	Gridfailure
17-Oct-10	TG1	18:20	18:46	00:26:00	SP	Blackstart&Islandmodetesting
17-Oct-10	TG2	01:23	02:19	00:56:00	FP	coolingwaterflowintotheturbine
17-Oct-10	TG2	07:23	18:40	11:17:00	FG	Gridfailure
18-Oct-10	TG1	22:26	22:48	00:22:00	FP	Powerhouseflooding
18-Oct-10	TG2	09:07	22:45	13:38:00	FP	coolingwaterflowintotheturbine
19-Oct-10	TG1	04:21	05:09	00:48:00	FP	Coolingwaterflowintoturbine
21-Oct-10	TG2	08:12	18:44	10:32:00	FP	400vacbreakertripped
22-Oct-10	TG1	18:30	18:53	00:23:00	FG	GridfailurefromJinja(SentongoJohnfrom Nkenda).
22-Oct-10	TG2	18:27	18:36	00:09:00	FP	Coolingwaterflowintotheturbine
23-Oct-10	TG1	06:14	06:31	00:17:00	FG	SwitchingonislandmodetoenableUETCL staffstomaintainthetransmissionline
23-Oct-10	TG1	11:25	11:43	00:18:00	FP	Himafeederopened
23-Oct-10	TG2	06:14	11:44	05:30:00	SG	SwitchingonislandmodetoenableUETCL staffstomaintainthetransmissionline
24-Oct-10	TG1	22:31	23:17	00:46:00	FP	Powerhouseflooding
24-Oct-10	TG1	23:33	23:54	00:21:00	FP	Powerhouseflooding
24-Oct-10	TG2	22:31	23:15	00:44:00	FP	Powerhouseflooding
25-Oct-10	TG2	05:00	18:28	13:28:00	FP	Aircoolerstemphigh
31-Oct-10	TG1	18:08	18:36	00:28:00	FG	circuitbreaker0.4STIEopened(voltagedip, from35.17kvdownto32.64kv)
31-Oct-10	TG2	18:08	19:57	01:49:00	FP	circuitbreaker0.4STIEopened(voltagedip, from35.17kvdownto32.64kv)
02-Nov-10	TG1	04:49	05:21	00:32:00	FG	132kVfailed
03-Nov-10	TG1	13:25	13:45	00:20:00	FG	132kVfailed
03-Nov-10	TG2	13:25	13:44	00:19:00	FG	Gridfailure
04-Nov-10	TG2	01:31	07:03	05:32:00	FP	Coolingwaterflowintotheturbine
06-Nov-10	TG1	06:47	07:00	00:13:00	FG	Gridshutdownby UETCL
06-Nov-10	TG1	17:20	17:50	00:30:00	FG	Gridproblem.33kVKasesefeedertrippedon overcurrent
06-Nov-10	TG1	18:30	19:21	00:51:00	FG	Gridproblem.33kVKasesefeedertrippedon overcurrent(Structureandconductors collapsed)
06-Nov-10	TG1	19:50	20:03	00:13:00	FG	Gridproblem.33kVF/Portalfeedertripped
06-Nov-10	TG2	06:47	17:17	10:30:00	FG	GridshutdownbyUETCL
06-Nov-10	TG2	18:30	20:03	01:33:00	FG	Gridproblem.33kVF/Portalfeedertripped
07-Nov-10	TG1	06:11	06:27	00:16:00	FG	Gridproblem.Reducedgenerationtobalance

						loadsatNkendatoavoidtotaltrip
07-Nov-10	TG1	09:19	09:40	00:21:00	FG	Underfrequency(Dipfrom50.2HZto45HZ)
07-Nov-10	TG2	09:19	11:56	02:37:00	FG	Underfrequency(Dipfrom50.2HZto45HZ)
13-Nov-10	TG1	17:25	17:49	00:24:00	FG	Gridfailure
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
13-Nov-10	TG1	17:58	18:16	00:18:00	FG	Gridfailure
13-Nov-10	TG1	19:44	20:05	00:21:00	FP	Lowpenstockpressure.Forebaycloggeddue toheavyfloodinginEsyariver
13-Nov-10	TG1	20:56	21:29	00:33:00	FG	Gridfailure
13-Nov-10	TG1	22:37	22:56	00:19:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
13-Nov-10	TG1	23:39	00:00	00:21:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
13-Nov-10	TG2	11:13	17:42	06:29:00	FG	Gridissue.UETCLrequestedforashutdown
13-Nov-10	TG2	17:58	20:38	02:40:00	FG	Gridissue.Himafeedertrippedonovercurrent (Twopolescollapsed)
13-Nov-10	TG2	20:56	22:56	02:00:00	FG	Gridfailure
14-Nov-10	TG1	01:05	01:26	00:21:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
14-Nov-10	TG1	04:33	05:32	00:59:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
14-Nov-10	TG1	10:03	10:42	00:39:00	FP	Stuffingboxtemp.(BT321)HH
14-Nov-10	TG2	01:04	05:06	04:02:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
15-Nov-10	TG1	00:25	00:51	00:26:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
15-Nov-10	TG1	01:18	02:18	01:00:00	FP	Waterflowintotheturbine(Watermuddydue tofloodsinEsyariver)
15-Nov-10	TG1	15:06	15:35	00:29:00	FG	Gridfailure.Fortportalline.
15-Nov-10	TG2	15:06	00:00	08:54:00	FG	Gridfailure.Fortportalline.
16-Nov-10	TG1	00:26	00:46	00:20:00	FP	Himafeederopened
16-Nov-10	TG2	00:25	16:40	16:15:00	FG	Himafeederopened
25-Nov-10	TG1	16:22	16:45	00:23:00	FP	Breaker 0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
25-Nov-10	TG2	16:22	22:47	06:25:00	FP	Breaker0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
27-Nov-10	TG1	22:28	22:50	00:22:00	FG	Breaker 0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
27-Nov-10	TG2	22:28	00:00	01:32:00	FP	Breaker0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
28-Nov-10	TG1	12:49	13:06	00:17:00	FG	Gridfailure(KCCLtripped)
28-Nov-10	TG1	13:29	13:57	00:28:00	FG	Gridfailure(132kvline)
28-Nov-10	TG2	12:49	13:45	00:56:00	FG	Gridfailure(KCCLtripped)
01-Dec-10	TG2	09:10	18:44	09:34:00	SP	MAVELteamtesting.
02-Dec-10	TG1	08:57	09:38	00:41:00	SP	MAVELTESTINGONISLAND
02-Dec-10	TG1	11:04	11:25	00:21:00	SP	MAVELTESTINGONISLAND

02-Dec-10	TG1	12:02	13:20	01:18:00	SP	MAVELTESTINGONISLAND
02-Dec-10	TG1	17:35	18:12	00:37:00	SP	MAVELTESTINGONISLAND
03-Dec-10	TG1	01:00	01:15	00:15:00	FP	Breaker0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
03-Dec-10	TG1	09:24	10:55	01:31:00	SP	SAFETYPRACTICAL
03-Dec-10	TG1	18:29	18:43	00:14:00	FP	Breaker0.4ST1E,forauxillaryopenedon voltagesurge(33.67kvto35.71kv)
Outage				Duration	Type	ProblemDescription
Date	Unit	From	To	Hrs:Mins	FP SP FG SG FM	
03-Dec-10	TG2	18:29	22:09	03:40:00	FP	Breaker0.4ST1E,forauxillaryopenedon voltagesurge(33.00kvto35.71kv)
08-Dec-10	TG1	15:35	16:01	00:26:00	FG	Gridfailure
08-Dec-10	TG2	15:35	20:37	05:02:00	FG	Gridfailure.132kVlinewentoffontransient andBreaker0.4ST1E,forauxillaryopened
12-Dec-10	TG1	20:21	20:36	00:15:00	FM	Breaker0.4T1Etrippedafterfortportalfeeder tripping
12-Dec-10	TG2	20:21	22:57	02:36:00	FP	Breaker0.4T1Etrippedafterfortportalfeeder tripping
13-Dec-10	TG1	10:43	10:59	00:16:00	FM	Breaker0.4T1Etrippedafterfortportalfeeder tripping
13-Dec-10	TG2	10:43	16:53	06:10:00	FP	Breaker0.4T1Etrippedafterfortportalfeeder tripping
14-Dec-10	TG1	14:59	16:34	01:35:00	FP	cleaningfilters
15-Dec-10	TG2	14:15	22:18	08:03:00	FM	Lowwaterflowintheriver
16-Dec-10	TG1	09:16	14:09	04:53:00	FM	Lowwaterflowintheriver
16-Dec-10	TG1	17:22	18:57	01:35:00	FM	Lowwaterflowintheriver
16-Dec-10	TG1	19:32	23:38	04:06:00	FM	Lowwaterflowintheriver
16-Dec-10	TG2	09:14	18:58	09:44:00	FM	Lowwaterflowintheriver
16-Dec-10	TG2	19:23	23:59	04:36:00	FM	Lowwaterflowintheriver
17-Dec-10	TG1	00:00	08:15	08:15:00	FM	Lowwaterflowintheriver
17-Dec-10	TG2	08:45	23:59	15:14:00	FM	Lowwaterflowintheriver
18-Dec-10	TG2	00:00	06:19	06:19:00	FM	Lowwaterflowintheriver
19-Dec-10	TG1	06:28	23:59	17:31:00	FM	Lowwaterflowintheriver
19-Dec-10	TG2	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
20-Dec-10	TG1	00:00	08:59	08:59:00	FM	Lowwaterflowintheriver
20-Dec-10	TG2	09:07	12:34	03:27:00	FM	Lowwaterflowintheriver
21-Dec-10	TG1	12:25	23:46	11:21:00	FM	Lowwaterflowintheriver
21-Dec-10	TG1	23:53	23:59	00:06:00	FG	gridfailure
21-Dec-10	TG2	00:00	23:52	23:52:00	FM	Lowwaterflowintheriver
22-Dec-10	TG1	00:00	00:16	00:16:00	FG	gridfailure
22-Dec-10	TG1	00:34	23:59	23:25:00	FM	Lowwaterflowintheriver
23-Dec-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
24-Dec-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
25-Dec-10	TG1	00:00	23:59	23:59:00	FM	Lowwaterflowintheriver
26-Dec-10	TG1	00:00	06:52	06:52:00	FM	Lowwaterflowintheriver
26-Dec-10	TG1	06:58	07:10	00:12:00	FP	Powerhouseflooding
26-Dec-10	TG2	06:58	15:54	08:56:00	FM	Lowwaterflowintheriver
27-Dec-10	TG2	00:00	15:06	15:06:00	FM	Lowwaterflowintheriver
31-Dec-10	TG1	14:18	14:40	00:22:00	FG	TxatNkendaopened
31-Dec-10	TG2	14:18	21:05	06:47:00	FG	TxatNkendaopened

	TG1	TG2
TotalhoursofShutdown2009	443.3	183.8
TotalhoursofShutdown2010	2077.9	4065.6