

Monitoring Report #2010-1
For the Greater New Bedford LFG Utilization Project
Dartmouth, Massachusetts
For Verification Period January 1, 2010 through June 30, 2010

July 28, 2010

CommonWealth

Resource Management Corporation

July 28, 2010

Iris Caldwell
Environmental Engineer
First Environment, Inc.
Chicago Civic Opera Building
20 N. Wacker Dr., Suite 1545

Re: Greater New Bedford LFG Utilization Project Emissions Reductions Verification
Verification Processes: Voluntary Carbon Standard
For the Periods: January 1, 2010 through June 30, 2010

Dear Iris,

On behalf of our subsidiary CommonWealth New Bedford Energy LLC, we are hereby submitting for your review the information required to perform a Verification of documented methane emissions reductions achieved from January 1, 2010 through June 30, 2010 (the GHG Reductions or Emission Reductions) at the Greater New Bedford LFG Utilization Project (the Project) in Dartmouth, Massachusetts.

Please perform the Verification and prepare a Verification Report required for verification process under the Voluntary Carbon Standard. Specifically, we are asking you to Verify our documented claims that the emission reductions generated by the Project during first half of 2010 are equivalent to 52,406 metric tons of Voluntary Carbon Units (VCUs) in accordance with verification protocol under the Voluntary Carbon Standard.

In support of claims, attached for your review are the following:

1. Exhibit 1 summarizes the emission reductions from methane oxidation during energy generation and flaring from January 1, 2010 through June 30, 2010.
2. Exhibit 2 provides LFG totalizer readings, and methane content readings for the periods from January 1, 2010 through June 30, 2010, and calculations using the verification protocols under the VCS to obtain emission reductions from methane oxidation during energy generation.
3. Exhibit 3 provides LFG totalizer readings, and methane content readings for the periods from January 1, 2010 through June 30, 2010, and calculations using the


verification protocols under the VCS to obtain emission reductions from methane oxidation during flaring.

4. Exhibit 4 provides the key factors, equations, and calculation of VCUs in accordance with the approved consolidated baseline methodology ACM0001/Version 09.1 “Consolidated baseline and monitoring methodology for the landfill gas project activities” promulgated by the United Nations Framework Convention of Climate Change (UNFCCC) under the Clean Development Mechanism (CDM).
5. Exhibit 5 is a compilation of the field data logs recording the total landfill gas volumes and methane content readings for the identified reporting periods.
6. Exhibit 6 documents the calibration of the LFG flow rate and provides a compilation of methane content calibration reports for the California Analytical Analyzer for the periods.

Hourly data for the months of January 1, 2010 through June 30, 2010 are provided in two MS Excel spreadsheets titled “Hourly Reports for 2010 Jan – March” and “Hourly Reports for 2010 April – June.”

Please call me with any questions at 508-339-3074. Thank you.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas Yeransian". The signature is stylized with a large, sweeping initial 'T' and a long horizontal flourish extending to the right.

Thomas Yeransian
Principal

EXHIBIT 2														
CommonWealth New Bedford Energy LLC														
Emission Reductions from methane oxidation during energy generation														
Physical constants:														
Methane, molecular weight (lb per lb-mole)					16				Calculation of Verified Emission Reduction in CO2 equivalent tons per the following:					
Pounds to metric ton					2,205				Verification Process: UNFCCC's CDM methodology ACM0001 (Version 9.1)					
Gas constant, scf per lb-mole					385				Standard of Verification: Voluntary Carbon Standard 2007.1					
Begin period - date	End period - date	Totalizer reading end period	Totalizer reading start period	Total in period	Methane delivered to engines	Methane delivered cumulative	Methane delivered in the period	Methane delivered in the period	Methane oxidation efficiency	MD electricity, Mass methane destroyed in the period	MD electricity, Mass methane destroyed cumulative	Global warming potential methane	Emission reduction	Emission reduction cumulative
mm/dd/yy	mm/dd/yy	MMBtu HHV	MMBtu HHV	MMBtu HHV	scf	scf	metric tons	metric tons	%	metric tons	metric tons	tons CO2 equivalent per ton methane	CO2 equivalent metric tons	CO2 equivalent metric tons
1-Jan-10														
1-Jan-10	31-Jan-10	26,636	-	26,636	26,320,228	26,320,228	496	496	100.0%	496	496	21	10,417	10,417
1-Feb-10	28-Feb-10	50,533	26,636	23,897	23,613,636	49,933,864	445	941	100.0%	445	941	21	9,346	19,764
1-Mar-10	31-Mar-10	77,226	50,533	26,693	26,376,482	76,310,346	497	1,438	100.0%	497	1,438	21	10,440	30,203
1-Apr-10	30-Apr-10	101,716	77,226	24,490	24,199,605	100,509,951	456	1,894	100.0%	456	1,894	21	9,578	39,781
1-May-10	31-May-10	126,160	101,716	24,444	24,154,150	124,664,101	455	2,350	100.0%	455	2,350	21	9,560	49,341
1-Jun-10	30-Jun-10	148,315	126,160	22,155	21,892,292	146,556,394	413	2,762	100.0%	413	2,762	21	8,665	58,006

EXHIBIT 3																
CommonWealth New Bedford Energy LLC																
Calculation of Verified Emission Reduction in CO2 equivalent tons per the Project Methodology																
Emission Reductions from methane oxidation from LFG flaring																
Physical constants:																
Methane, molecular weight (lb per lb-mole) 16																
Pounds to metric ton 2,205																
Gas constant, scf per lb-mole 385																
Calculation of Verified Emission Reduction in CO2 equivalent tons per the following																
Verification Process: UNFCCC's CDM methodology ACM0001 (Version 9.1)																
Standard of Verification: Voluntary Carbon Standard 2007.1																
Begin period - date	End period - date	Totalizer reading end period	Totalizer reading start period	Total in period	Methane delivered to flare	Methane delivered cumulative	Methane delivered in the period	Methane delivered cumulative	Methane oxidation efficiency	MD flare, Mass methane destroyed in the period	MD flare, Mass methane destroyed cumulative	Global warming potential methane	Emission reduction	Emission reduction cumulative	PE flare, Project emissions (uncontrolled emissions to atmosphere from flare)	PE flare, Project emissions cumulative (uncontrolled emissions to atmosphere from flare)
mm/dd/yy	mm/dd/yy	MMBtu HHV	MMBtu HHV	MMBtu HHV	scf	scf	metric tons	metric tons	%	metric tons	metric tons	tons CO2 equivalent per ton methane	CO2 equivalent metric tons	CO2 equivalent metric tons	CO2 equivalent metric tons	CO2 equivalent metric tons
	1-Jan-10															
1-Jan-10	31-Jan-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-
1-Feb-10	28-Feb-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-
1-Mar-10	31-Mar-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-
1-Apr-10	30-Apr-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-
1-May-10	31-May-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-
1-Jun-10	30-Jun-10	-	-	-	-	-	0	0	0%	-	-	21	-	-	-	-

EXHIBIT 4

Emission Reductions from the Greater New Bedford LFG Utilization Project using ACM0001 (Version 9.1) under the VCS Program

Key factors to determine baseline and emission reductions (1):								
Methane oxidation efficiency for electric generation:								100%
Methane oxidation efficiency for flare:								50%
GWP methane, Global warming potential for methane:								21
Quantity methane collected and controlled to make electricity								100%
Quantity methane collected and controlled by flare								0%
EL lfg	Indirect electricity required by baseline activity							0
ET lfg	Indirect thermal energy required by baseline activity							0
PE	Project emissions, which are indirect emissions from Project Activity							0
MD project	Methane destroyed by Project Activity							See below
MD bl	Methane destroyed in the District Initial System.							See below
MD flared	Methane destroyed by flaring = methane delivered to flare - methane emitted to atmosphere							See below
MD electricity	Methane destroyed by generation of electricity							See below
BE	Baseline emissions = (MD project-MD bl) * GWP methane + indirect emissions of baseline activity							See below
ER	Emission reductions, which is equal to BE - PE							See below

Year	Methane collected and delivered to engines and flare, methane metric tons	MD electricity, methane metric tons	MD flared, methane metric tons	MD project, methane metric tons	MD bl (2), methane metric tons	(MD project - MD bl) methane metric tons	BE, CO2e metric tons	ER, CO2e metric tons
1st Half 2010	2,762	2,762	-	2,762	267	2,496	52,406	52,406

(1) Key factors and equations are from UNFCCC CDM document ACM0001/Version 09.1.

(2) Calculation of MD bl in accordance with validation report shown below.

Year	Methane delivered to flare from District Initial System, metric tons	MD bl, Methane destroyed in the District Initial System, metric tons
2001	3,548	1,774
2002	3,104	1,552
2003	2,716	1,358
2004	2,377	1,188
2005	2,080	1,040
2006	1,820	910
2007	1,592	796
2008	1,393	697
2009	1,219	610
2010	1,067	533
2011	933	467
2012	817	408
2013	715	357
2014	625	313
2015	547	274
2016	479	239
Annual rate of decline =	0.125	

EXHIBIT 5

Compilation of the field data logs recording the total landfill gas volumes and methane content readings for the first half 2010

JANUARY 2010

JANUARY 2010																
CNBE Daily Reports Summary Data																
	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	
	1/1/2010	1/2/2010	1/3/2010	1/4/2010	1/5/2010	1/6/2010	1/7/2010	1/8/2010	1/9/2010	1/10/2010	1/11/2010	1/12/2010	1/13/2010	1/14/2010	1/15/2010	
Landfill Gas Flow to the Engines (KSCF)	1,635	1,623	1,033	1,721	1,678	1,699	1,710	1,737	1,752	1,647	1,721	1,710	1,786	1,744	1,683	
Landfill Gas Flow to the Engines (MMBTU HHV)	869	862	554	889	864	879	878	891	879	838	872	875	897	852	871	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,635	1,623	1,033	1,721	1,678	1,699	1,710	1,737	1,752	1,647	1,721	1,710	1,786	1,744	1,683	
Landfill Gas Total Flow (MMBTU HHV)	869	862	554	889	864	879	878	891	879	838	872	875	897	852	871	
Average Methane Content (%)	52.5	52.5	53.0	51.1	50.9	51.1	50.7	50.7	49.6	50.3	50.1	50.6	49.6	48.3	51.1	
Engine 1 Hours	24	24	15	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 2 Hours	24	24	15	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 3 Hours	24	24	13	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 4 Hours	24	24	15	24	24	24	24	24	24	24	24	24	24	24	24	
Generator 1 Power Output (kW/hr)	14,360	14,316	9,841	15,926	16,044	16,330	16,278	15,719	14,627	14,407	16,028	15,348	15,593	14,965	15,300	
Generator 2 Power Output (kW/hr)	13,959	13,916	9,626	16,839	16,129	16,266	14,697	13,978	14,102	13,983	15,621	15,015	15,554	15,162	14,983	
Generator 3 Power Output (kW/hr)	18,588	18,504	9,411	17,034	15,867	16,166	17,425	18,605	14,591	14,230	15,981	15,747	16,419	15,112	14,842	
Generator 4 Power Output (kW/hr)	18,206	18,149	10,142	17,110	16,220	16,513	17,653	18,668	18,859	18,721	18,791	17,744	18,846	18,122	18,176	
Gross Power Output (kW/hr)	65,469	65,251	39,321	67,345	64,784	65,811	66,489	67,371	62,647	61,803	66,856	64,279	66,901	63,837	63,769	
Net Power Output (kW/hr)	64,326	64,090	38,573	66,030	63,412	64,413	65,079	65,932	61,210	60,573	65,473	62,896	65,432	62,443	62,491	
Power Sold as metered by NStar, (kW/hr)	65,030	65,023	38,628	66,582	64,551	64,413	65,729	66,559	61,184	61,061	65,716	63,387	65,490	62,688	62,467	
Offgrid RECs (kW/hr)	1,143	1,161	748	1,315	1,372	1,398	1,410	1,439	1,437	1,230	1,383	1,383	1,469	1,394	1,278	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	598	597	656	664	669	680	678	655	609	600	668	640	650	624	638	
Generator 2	582	580	642	702	672	678	612	582	588	583	651	626	648	632	624	
Generator 3	775	771	724	710	661	674	726	775	608	593	666	656	684	630	618	
Generator 4	759	756	676	713	676	688	736	778	786	780	783	739	785	755	757	
Power output (kW average over 24-hrs)																
Facility Gross	2,728	2,719	1,638	2,806	2,699	2,742	2,770	2,807	2,610	2,575	2,786	2,678	2,788	2,660	2,657	
Facility Net	2,680	2,670	1,607	2,751	2,642	2,684	2,712	2,747	2,550	2,524	2,728	2,621	2,726	2,602	2,604	
In-plant load	48	48	31	55	57	58	59	60	60	51	58	58	61	58	53	
Daily availability factor																
Facility	100%	100%	60%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 1	100%	100%	63%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	63%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	54%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	63%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	83%	82%	50%	85%	82%	83%	84%	85%	79%	78%	84%	81%	84%	81%	81%	
Engine 1	73%	72%	80%	80%	81%	82%	82%	79%	74%	73%	81%	78%	79%	76%	77%	
Engine 2	71%	70%	78%	85%	81%	82%	74%	71%	71%	71%	79%	76%	79%	77%	76%	
Engine 3	94%	93%	88%	86%	80%	82%	88%	94%	74%	72%	81%	80%	83%	76%	75%	
Engine 4	92%	92%	82%	86%	82%	83%	89%	94%	95%	95%	95%	90%	95%	92%	92%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	
Engine 1	24	48	63	87	111	135	159	183	207	231	255	279	303	327	351	
Engine 2	24	48	63	87	111	135	159	183	207	231	255	279	303	327	351	
Engine 3	24	48	61	85	109	133	157	181	205	229	253	277	301	325	349	
Engine 4	24	48	63	87	111	135	159	183	207	231	255	279	303	327	351	
Engine operating run hours total from 0 hours																
Engine 1	35,371	35,395	35,410	35,434	35,458	35,482	35,506	35,530	35,554	35,578	35,602	35,626	35,650	35,674	35,698	
Engine 2	35,251	35,275	35,290	35,314	35,338	35,362	35,386	35,410	35,434	35,458	35,482	35,506	35,530	35,554	35,578	
Engine 3	34,842	34,866	34,879	34,903	34,927	34,951	34,975	34,999	35,023	35,047	35,071	35,095	35,119	35,143	35,167	
Engine 4	34,062	34,086	34,101	34,125	34,149	34,173	34,197	34,221	34,245	34,269	34,293	34,317	34,341	34,365	34,389	
Cumulative availability, %																
Engine 1	100%	100%	88%	91%	93%	94%	95%	95%	96%	96%	97%	97%	97%	97%	98%	
Engine 2	100%	100%	88%	91%	93%	94%	95%	95%	96%	96%	97%	97%	97%	97%	98%	
Engine 3	100%	100%	85%	89%	91%	92%	93%	94%	95%	95%	96%	96%	96%	97%	97%	
Engine 4	100%	100%	88%	91%	93%	94%	95%	95%	96%	96%	97%	97%	97%	97%	98%	
Engine cumulative gross output, kW/hr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	
Engine 1	598	1,195	1,851	2,514	3,183	3,863	4,542	5,197	5,806	6,406	7,074	7,714	8,363	8,987	9,624	
Engine 2	582	1,161	1,803	2,505	3,177	3,855	4,467	5,049	5,637	6,220	6,870	7,496	8,144	8,776	9,400	
Engine 3	775	1,546	2,269	2,979	3,640	4,314	5,040	5,815	6,423	7,016	7,682	8,338	9,022	9,652	10,270	
Engine 4	759	1,515	2,191	2,904	3,580	4,268	5,003	5,781	6,567	7,347	8,130	8,869	9,654	10,410	11,167	
Cumulative capacity factor, %																
Engine 1	73%	72%	75%	76%	77%	78%	79%	79%	78%	78%	78%	78%	78%	78%	78%	
Engine 2	71%	70%	70%	76%	77%	78%	77%	77%	76%	75%	76%	76%	76%	76%	76%	
Engine 3	94%	94%	92%	90%	88%	87%	87%	88%	87%	85%	85%	84%	84%	84%	83%	
Engine 4	92%	92%	89%	88%	87%	86%	87%	88%	88%	89%	90%	90%	90%	90%	90%	

JANUARY 2010

	Friday 1/1/2010	Saturday 1/2/2010	Sunday 1/3/2010	Monday 1/4/2010	Tuesday 1/5/2010	Wednesday 1/6/2010	Thursday 1/7/2010	Friday 1/8/2010	Saturday 1/9/2010	Sunday 1/10/2010	Monday 1/11/2010	Tuesday 1/12/2010	Wednesday 1/13/2010	Thursday 1/14/2010	Friday 1/15/2010
Cumulative by Facility in month															
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440
Actual cumulative engine run hours	96	192	250	346	442	538	634	730	826	922	1,018	1,114	1,210	1,306	1,402
Cumulative Availability, %	100.0%	100.0%	86.8%	90.1%	92.1%	93.4%	94.3%	95.1%	95.6%	96.0%	96.4%	96.7%	97.0%	97.2%	97.4%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000
Actual cumulative gross output, kWhr	65,469	130,720	170,041	237,386	302,170	367,981	434,470	501,841	564,488	626,291	693,147	757,426	824,327	888,164	951,933
Cumulative Capacity Factor	82.7%	82.5%	71.6%	74.9%	76.3%	77.4%	78.4%	79.2%	79.2%	79.1%	79.6%	79.7%	80.1%	80.1%	80.1%
Cumulative fuel input, MMBtu HHV	869	1,731	2,285	3,174	4,038	4,917	5,795	6,686	7,565	8,403	9,275	10,150	11,047	11,899	12,770
Cumulative gross output, kWhr	65,469	130,720	170,041	237,386	302,170	367,981	434,470	501,841	564,488	626,291	693,147	757,426	824,327	888,164	951,933
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	11,949	11,892	12,683	11,883	12,006	12,023	11,887	11,905	12,631	12,206	11,741	12,254	12,070	12,014	12,296
Daily heat rate, Btu/kWe gross HHV	13,273	13,211	14,089	13,201	13,337	13,356	13,205	13,225	14,031	13,559	13,043	13,613	13,408	13,346	13,659
Cumulative heat rate, Btu/kWe gross LHV	11,949	11,920	12,097	12,036	12,030	12,029	12,007	11,993	12,064	12,078	12,046	12,063	12,064	12,060	12,076
Cumulative heat rate, Btu/kWe gross HHV	13,273	13,242	13,438	13,371	13,363	13,362	13,338	13,323	13,402	13,417	13,381	13,401	13,401	13,397	13,415
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440
Actual cumulative engine run hours	96	192	250	346	442	538	634	730	826	922	1,018	1,114	1,210	1,306	1,402
Cumulative Availability, %	100.0%	100.0%	86.8%	90.1%	92.1%	93.4%	94.3%	95.1%	95.6%	96.0%	96.4%	96.7%	97.0%	97.2%	97.4%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000
Actual cumulative gross output, kWhr	65,469	130,720	170,041	237,386	302,170	367,981	434,470	501,841	564,488	626,291	693,147	757,426	824,327	888,164	951,933
Cumulative Capacity Factor	82.7%	82.5%	71.6%	74.9%	76.3%	77.4%	78.4%	79.2%	79.2%	79.1%	79.6%	79.7%	80.1%	80.1%	80.1%
Cumulative fuel input, MMBtu HHV	869	1,731	2,285	3,174	4,038	4,917	5,795	6,686	7,565	8,403	9,275	10,150	11,047	11,899	12,770
Cumulative gross output, kWhr	65,469	130,720	170,041	237,386	302,170	367,981	434,470	501,841	564,488	626,291	693,147	757,426	824,327	888,164	951,933
Cumulative heat rate, Btu/kWe gross LHV	11,949	11,920	12,097	12,036	12,030	12,029	12,007	11,993	12,064	12,078	12,046	12,063	12,064	12,060	12,076
Cumulative heat rate, Btu/kWe gross HHV	13,273	13,242	13,438	13,371	13,363	13,362	13,338	13,323	13,402	13,417	13,381	13,401	13,401	13,397	13,415
Service															
Engine 1															
Engine 2															
Engine 3			NStar outage			Operations									
Engine 4			communication loss			meeting				Fuel system problem					
			due to snow storm							E3 low cyl, exh temps					
Oil - oil and filter change										District checked leachate lines - clear.			District fabricating	4th well connected	District initiates
Service - plugs, air filter, valve inspection and adjustment					Wells adjusted.	Wells adjusted.	Wells adjusted.					pipng.			pumping
NSTAR Power Reports															
Date	Friday 1/1/2010	Saturday 1/2/2010	Sunday 1/3/2010	Monday 1/4/2010	Tuesday 1/5/2010	Wednesday 1/6/2010	Thursday 1/7/2010	Friday 1/8/2010	Saturday 1/9/2010	Sunday 1/10/2010	Monday 1/11/2010	Tuesday 1/12/2010	Wednesday 1/13/2010	Thursday 1/14/2010	Friday 1/15/2010
Hour															
1	2,712	2,709	555	3,061	2,690	2,690	2,691	2,800	2,768	2,544	2,546	2,813	2,758	2,718	2,557
2	2,711	2,710	-	3,059	2,692	2,691	2,692	2,801	2,753	2,543	2,545	2,814	2,756	2,718	2,557
3	2,709	2,709	-	2,903	2,692	2,692	2,690	2,801	2,607	2,542	2,546	2,814	2,754	2,716	2,558
4	2,709	2,708	-	2,879	2,691	2,689	2,690	2,802	2,599	2,542	2,548	2,811	2,757	2,716	2,559
5	2,710	2,708	-	2,877	2,690	2,689	2,689	2,802	2,585	2,543	2,548	2,810	2,758	2,717	2,560
6	2,711	2,708	-	2,878	2,690	2,689	2,689	2,804	2,557	2,544	2,548	2,810	2,758	2,696	2,560
7	2,711	2,709	-	2,877	2,691	2,691	2,691	2,804	2,503	2,544	2,546	2,811	2,738	2,674	2,559
8	2,713	2,709	-	2,879	2,694	2,692	2,693	2,803	2,484	2,544	2,546	2,813	2,692	2,673	2,559
9	2,711	2,711	-	2,737	2,692	2,691	2,693	2,798	2,476	2,543	2,613	2,801	2,690	2,664	2,562
10	2,711	2,712	48	2,750	2,687	2,686	2,688	2,725	2,481	2,544	2,895	2,710	2,689	2,597	2,650
11	2,711	2,712	574	2,778	2,685	2,689	2,685	2,730	2,475	2,545	2,980	2,711	2,689	2,575	1,800
12	2,713	2,710	932	2,674	2,687	2,687	2,690	2,735	2,495	2,547	2,947	1,741	2,747	2,554	2,693
13	2,709	2,710	2,803	2,659	2,690	2,690	2,692	2,733	2,515	2,543	2,866	779	2,750	2,550	2,689
14	2,708	2,710	3,068	2,680	2,687	2,647	2,747	2,744	2,548	2,543	2,859	2,374	2,754	2,554	2,693
15	2,712	2,710	3,070	2,694	2,687	2,601	2,800	2,764	2,528	2,544	2,863	2,938	2,747	2,552	2,692
16	2,708	2,710	3,065	2,687	2,692	2,679	2,803	2,768	2,509	2,545	2,815	2,766	2,717	2,555	2,692
17	2,706	2,710	3,065	2,688	2,690	2,691	2,801	2,768	2,515	2,546	2,812	2,761	2,718	2,558	2,694
18	2,707	2,708	3,067	2,687	2,688	2,689	2,801	2,768	2,540	2,544	2,811	2,758	2,713	2,555	2,691
19	2,709	2,707	3,066	2,689	2,688	2,688	2,800	2,771	2,541	2,544	2,814	2,759	2,718	2,555	2,690
20	2,709	2,707	3,065	2,688	2,688	2,689	2,801	2,769	2,541	2,544	2,816	2,757	2,719	2,556	2,690
21	2,709	2,707	3,063	2,691	2,692	2,691	2,801	2,768	2,540	2,544	2,816	2,759	2,716	2,557	2,690
22	2,707	2,709	3,063	2,689	2,692	2,690	2,801	2,767	2,540	2,546	2,813	2,759	2,717	2,559	2,692
23	2,707	2,710	3,061	2,689	2,689	2,691	2,801	2,767	2,541	2,546	2,812	2,759	2,717	2,559	2,690
24	2,707	2,710	3,063	2,689	2,687	2,691	2,800	2,767	2,543	2,547	2,811	2,759	2,718	2,560	2,690
TOTAL	65,030	65,023	38,628	66,582	64,551	64,413	65,729	66,559	61,184	61,061	65,716	63,387	65,490	62,688	62,467
Cumulative Output Sold, kWhr	65,030	130,053	168,681	235,263	299,814	364,227	429,956	496,515	557,699	618,760	684,476	747,863	813,353	876,041	938,508
Transformer and line efficiency	101.1%	101.5%	100.1%	100.8%	101.8%	100.0%	101.0%	101.0%	100.0%	100.8%	100.4%	100.8%	100.1%	100.4%	100.0%
Hourly average	2,710	2,709	1,610	2,774	2,690	2,684	2,739	2,773	2,549	2,544	2,738	2,641	2,729	2,612	2,603

JANUARY 2010

JANUARY 2010																	
CNBE Daily Reports Summary Data																	
	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	TOTAL
	1/16/2010	1/17/2010	1/18/2010	1/19/2010	1/20/2010	1/21/2010	1/22/2010	1/23/2010	1/24/2010	1/25/2010	1/26/2010	1/27/2010	1/28/2010	1/29/2010	1/30/2010	1/31/2010	
Landfill Gas Flow to the Engines (KSCF)	1,735	1,737	1,695	1,652	1,663	1,628	1,631	1,707	1,628	1,666	1,521	1,661	1,687	1,692	1,759	1,669	51,607
Landfill Gas Flow to the Engines (MMBTU HHV)	887	889	904	875	882	858	869	868	839	860	804	856	876	879	877	843	26,636
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,735	1,737	1,695	1,652	1,663	1,628	1,631	1,707	1,628	1,666	1,521	1,661	1,687	1,692	1,759	1,669	51,607
Landfill Gas Total Flow (MMBTU HHV)	887	889	904	875	882	858	869	868	839	860	804	856	876	879	877	843	26,636
Average Methane Content (%)	50.5	50.6	52.7	52.3	52.4	52.1	52.7	50.3	50.9	51.0	52.2	50.9	51.3	51.3	49.3	49.9	51.0
Engine 1 Hours	24	24	24	24	24	24	22	24	24	24	19	24	24	22	24	23	725
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	19	24	24	22	24	24	728
Engine 3 Hours	24	24	24	24	24	24	24	24	24	24	19	24	24	24	24	24	728
Engine 4 Hours	24	24	24	24	24	22	23	24	24	21	19	24	24	23	24	24	723
Generator 1 Power Output (kW/hr)	15,771	15,785	16,071	14,809	15,663	15,616	14,864	14,545	14,968	16,000	13,209	14,020	14,614	15,073	17,375	16,235	469,700
Generator 2 Power Output (kW/hr)	15,312	15,323	15,593	14,677	15,209	17,152	19,184	17,392	16,669	17,344	13,236	14,341	14,931	15,355	16,871	16,285	474,704
Generator 3 Power Output (kW/hr)	15,602	15,632	15,714	15,101	15,572	17,550	19,556	19,548	18,455	19,202	13,281	15,392	16,161	13,931	9,373	9,055	487,647
Generator 4 Power Output (kW/hr)	18,894	18,919	18,806	17,836	18,447	11,245	8,638	10,486	9,384	9,764	12,646	14,700	15,860	16,884	17,012	16,151	497,592
Gross Power Output (kW/hr)	66,069	66,098	66,666	62,915	65,296	61,981	62,493	62,266	59,885	62,310	52,765	59,021	62,106	61,753	61,318	58,355	1,943,230
Net Power Output (kW/hr)	64,729	64,735	65,331	61,616	63,945	60,717	61,246	60,909	58,581	60,953	51,715	57,744	60,851	60,481	59,858	56,990	1,902,774
Power Sold as metered by NStar, (kW/hr)	64,528	64,518	65,385	61,914	65,353	61,293	61,065	61,043	59,410	60,902	52,928	58,147	61,007	60,593	60,419	59,552	1,916,565
Offgrid RECs (kW/hr)	1,340	1,363	1,335	1,299	1,351	1,264	1,247	1,357	1,304	1,357	1,050	1,277	1,255	1,272	1,460	1,365	40,456
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	657	658	670	617	653	651	676	606	624	667	695	584	609	685	724	706	
Generator 2	638	638	650	612	634	715	799	725	695	723	697	598	622	698	703	679	
Generator 3	650	651	655	629	649	731	815	815	769	800	699	641	673	580	391	377	
Generator 4	787	788	784	743	769	511	376	437	391	465	666	613	661	734	709	673	
Power output (kW average over 24-hrs)																	
Facility Gross	2,753	2,754	2,778	2,621	2,721	2,583	2,604	2,594	2,495	2,596	2,199	2,459	2,588	2,573	2,555	2,431	
Facility Net	2,697	2,697	2,722	2,567	2,664	2,530	2,552	2,538	2,441	2,540	2,155	2,406	2,535	2,520	2,494	2,375	
In-plant load	56	57	56	54	56	53	52	57	54	57	44	53	52	53	61	57	
Daily availability factor																	
Facility	100%	100%	100%	100%	100%	98%	97%	100%	100%	97%	79%	100%	100%	95%	100%	99%	
Engine 1	100%	100%	100%	100%	100%	100%	92%	100%	100%	100%	79%	100%	100%	92%	100%	96%	
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	79%	100%	100%	92%	100%	100%	
Engine 3	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	79%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	92%	96%	100%	100%	88%	79%	100%	100%	96%	100%	100%	
Daily capacity factor																	
Facility	83%	83%	84%	79%	82%	78%	79%	79%	76%	79%	67%	75%	78%	78%	77%	74%	
Engine 1	80%	80%	81%	75%	79%	79%	82%	73%	76%	81%	64%	71%	74%	83%	88%	86%	
Engine 2	77%	77%	79%	74%	77%	87%	97%	88%	84%	88%	84%	72%	75%	85%	85%	82%	
Engine 3	79%	79%	79%	76%	79%	89%	99%	99%	93%	97%	85%	78%	82%	70%	47%	46%	
Engine 4	95%	96%	95%	90%	93%	62%	46%	53%	47%	56%	81%	74%	80%	89%	86%	82%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	384	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744	
Engine 1	375	399	423	447	471	495	517	541	565	589	608	632	656	678	702	725	
Engine 2	375	399	423	447	471	495	519	543	567	591	610	634	658	680	704	728	
Engine 3	373	397	421	445	469	493	517	541	565	589	608	632	656	680	704	728	
Engine 4	375	399	423	447	471	493	516	540	564	585	604	628	652	675	699	723	
Engine operating run hours total from 0 hours																	
Engine 1	35,722	35,746	35,770	35,794	35,818	35,842	35,864	35,888	35,912	35,936	35,955	35,979	36,003	36,025	36,049	36,072	
Engine 2	35,602	35,626	35,650	35,674	35,698	35,722	35,746	35,770	35,794	35,818	35,837	35,861	35,885	35,907	35,931	35,955	
Engine 3	35,191	35,215	35,239	35,263	35,287	35,311	35,335	35,359	35,383	35,407	35,426	35,450	35,474	35,498	35,522	35,546	
Engine 4	34,413	34,437	34,461	34,485	34,509	34,531	34,554	34,578	34,602	34,623	34,642	34,666	34,690	34,713	34,737	34,761	
Cumulative availability, %																	
Engine 1	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	97%	98%	98%	97%	98%	97%	
Engine 2	98%	98%	98%	98%	98%	98%	98%	98%	98%	99%	98%	98%	98%	98%	98%	98%	
Engine 3	97%	97%	97%	97%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	
Engine 4	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	97%	97%	97%	97%	97%	97%	
Engine cumulative gross output, kW/hr																	
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	24,750	
Engine 1	10,282	10,939	11,609	12,226	12,879	13,529	14,205	14,811	15,435	16,101	16,796	17,381	17,990	18,675	19,399	19,381	
Engine 2	10,038	10,677	11,326	11,938	12,572	13,286	14,086	14,810	15,505	16,228	16,924	17,522	18,144	18,842	19,545	19,520	
Engine 3	10,920	11,572	12,226	12,856	13,504	14,236	15,051	15,865	16,634	17,434	18,133	18,774	19,448	20,028	20,419	20,406	
Engine 4	11,954	12,742	13,526	14,269	15,038	15,549	15,925	16,361	16,752	17,217	17,883	18,495	19,156	19,890	20,599	20,563	
Cumulative capacity factor, %																	
Engine 1	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	
Engine 2	76%	76%	76%	76%	76%	77%	78%	78%	78%	79%	79%	79%	79%	79%	79%	79%	
Engine 3	83%	83%	82%	82%	82%	82%	83%	84%	84%	85%	85%	84%	84%	84%	83%	82%	
Engine 4	91%	91%	91%	91%	91%	90%	88%	86%	85%	83%	83%	83%	83%	83%	83%	83%	

FEBRUARY 2010														
CNBE Daily Reports Summary Data														
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
	2/1/2010	2/2/2010	2/3/2010	2/4/2010	2/5/2010	2/6/2010	2/7/2010	2/8/2010	2/9/2010	2/10/2010	2/11/2010	2/12/2010	2/13/2010	2/14/2010
Landfill Gas Flow to the Engines (KSCF)	1,739	1,713	1,753	1,708	1,717	1,687	1,741	1,731	1,694	1,539	1,433	1,715	1,713	1,695
Landfill Gas Flow to the Engines (MMBTU HHV)	881	871	883	867	882	887	899	878	862	808	781	895	899	882
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,739	1,713	1,753	1,708	1,717	1,687	1,741	1,731	1,694	1,539	1,433	1,715	1,713	1,695
Landfill Gas Total Flow (MMBTU HHV)	881	871	883	867	882	887	899	878	862	808	781	895	899	882
Average Methane Content (%)	50.1	50.2	49.8	50.2	50.8	52.0	51.0	50.1	50.3	51.9	53.9	51.6	51.8	51.4
Engine 1 Hours	24	22	24	24	23	22	24	24	24	23	24	24	24	24
Engine 2 Hours	24	24	23	24	24	24	24	24	24	23	24	24	24	24
Engine 3 Hours	23	23	24	22	24	24	24	24	24	22	24	24	24	24
Engine 4 Hours	22	20	24	24	24	24	24	23	24	23	24	24	24	24
Generator 1 Power Output (kWhr)	17,747	14,319	14,295	15,144	14,481	14,190	14,340	17,355	19,005	14,830	12,049	19,880	19,953	19,759
Generator 2 Power Output (kWhr)	18,594	18,816	16,959	19,333	18,301	17,105	16,731	18,237	19,052	14,541	11,401	18,767	18,759	18,584
Generator 3 Power Output (kWhr)	15,192	18,545	17,663	15,584	17,988	18,538	18,825	18,618	19,477	15,223	11,346	18,005	18,420	17,967
Generator 4 Power Output (kWhr)	11,430	10,991	13,148	10,031	12,535	14,153	13,907	8,856	4,708	5,697	5,116	4,681	5,064	5,011
Gross Power Output (kWhr)	63,555	63,170	62,586	60,636	63,945	64,591	64,340	63,587	62,674	50,947	40,591	61,859	62,754	61,889
Net Power Output (kWhr)	62,109	61,728	61,057	59,236	62,505	63,158	62,794	62,125	61,252	49,694	39,366	60,383	61,419	60,514
Power Sold as metered by NStar, (kWhr)	60,764	61,928	61,617	59,088	62,379	63,379	63,553	62,674	62,263	49,629	40,173	60,299	61,377	61,055
Offgrid RECs (kWhr)	1,446	1,442	1,509	1,400	1,440	1,433	1,546	1,462	1,422	1,253	1,225	1,476	1,335	1,375
Calculated Performance Results														
Daily														
Power output (kW average when running)														
Generator 1	739	651	596	631	630	645	598	723	792	645	502	828	831	823
Generator 2	775	784	737	806	763	713	697	760	794	632	475	782	782	774
Generator 3	661	806	736	708	750	772	784	776	812	692	473	750	768	749
Generator 4	520	550	548	418	522	590	579	385	196	248	213	195	211	209
Power output (kW average over 24-hrs)														
Facility Gross	2,648	2,632	2,607	2,527	2,664	2,691	2,681	2,649	2,611	2,123	1,691	2,577	2,615	2,579
Facility Net	2,588	2,572	2,544	2,468	2,604	2,632	2,616	2,589	2,552	2,071	1,640	2,516	2,559	2,521
In-plant load	60	60	63	58	60	60	64	61	59	52	51	62	56	57
Daily availability factor														
Facility	97%	93%	99%	98%	99%	98%	100%	99%	100%	95%	100%	100%	100%	100%
Engine 1	100%	92%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 2	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	96%	100%	100%	92%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 4	92%	83%	100%	100%	100%	100%	100%	96%	100%	96%	100%	100%	100%	100%
Daily capacity factor														
Facility	80%	80%	79%	77%	81%	82%	81%	80%	79%	64%	51%	78%	79%	78%
Engine 1	90%	79%	72%	76%	76%	72%	72%	88%	96%	78%	61%	100%	101%	100%
Engine 2	94%	95%	89%	98%	92%	86%	85%	92%	96%	77%	58%	95%	95%	94%
Engine 3	80%	98%	89%	86%	91%	94%	95%	94%	98%	84%	57%	91%	93%	91%
Engine 4	63%	67%	66%	51%	63%	71%	70%	47%	24%	30%	26%	24%	26%	25%
Cumulative by engine														
Engine operating run hours in the month														
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336
Engine 1	24	46	70	94	117	139	163	187	211	234	258	282	306	330
Engine 2	24	48	71	95	119	143	167	191	215	238	262	286	310	334
Engine 3	23	46	70	92	116	140	164	188	212	234	258	282	306	330
Engine 4	22	42	66	90	114	138	162	185	209	232	256	280	304	328
Engine operating run hours total from 0 hours														
Engine 1	36,096	36,118	36,142	36,166	36,189	36,211	36,235	36,259	36,283	36,306	36,330	36,354	36,378	36,402
Engine 2	35,979	36,003	36,026	36,050	36,074	36,098	36,122	36,146	36,170	36,193	36,217	36,241	36,265	36,289
Engine 3	35,569	35,592	35,616	35,638	35,662	35,686	35,710	35,734	35,758	35,780	35,804	35,828	35,852	35,876
Engine 4	34,783	34,803	34,827	34,851	34,875	34,899	34,923	34,946	34,970	34,993	35,017	35,041	35,065	35,089
Cumulative availability, %														
Engine 1	100%	96%	97%	98%	98%	97%	97%	97%	98%	98%	98%	98%	98%	98%
Engine 2	100%	100%	99%	99%	99%	99%	99%	99%	100%	99%	99%	99%	99%	99%
Engine 3	96%	96%	97%	96%	97%	97%	98%	98%	98%	98%	98%	98%	98%	98%
Engine 4	92%	88%	92%	94%	95%	96%	96%	96%	97%	97%	97%	97%	97%	98%
Engine cumulative gross output, kWhr														
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550
Engine 1	739	1,390	1,986	2,617	3,247	3,892	4,489	5,212	6,004	6,649	7,151	7,979	8,811	9,634
Engine 2	775	1,559	2,296	3,102	3,864	4,577	5,274	6,034	6,828	7,460	7,935	8,717	9,499	10,273
Engine 3	661	1,467	2,203	2,911	3,661	4,433	5,217	5,993	6,805	7,497	7,969	8,720	9,487	10,236
Engine 4	520	1,069	1,617	2,035	2,557	3,147	3,726	4,111	4,308	4,555	4,768	4,963	5,174	5,383
Cumulative capacity factor, %														
Engine 1	90%	84%	80%	79%	79%	79%	78%	79%	81%	81%	79%	81%	82%	83%
Engine 2	94%	94%	93%	94%	94%	92%	91%	91%	92%	90%	87%	88%	89%	89%
Engine 3	80%	89%	88%	88%	89%	90%	90%	91%	92%	91%	88%	88%	88%	89%
Engine 4	63%	65%	65%	62%	62%	64%	65%	62%	58%	55%	53%	50%	48%	47%

FEBRUARY 2010

	Monday 2/1/2010	Tuesday 2/2/2010	Wednesday 2/3/2010	Thursday 2/4/2010	Friday 2/5/2010	Saturday 2/6/2010	Sunday 2/7/2010	Monday 2/8/2010	Tuesday 2/9/2010	Wednesday 2/10/2010	Thursday 2/11/2010	Friday 2/12/2010	Saturday 2/13/2010	Sunday 2/14/2010
Cumulative by Facility in month														
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344
Actual cumulative engine run hours	93	182	277	371	466	560	656	751	847	938	1,034	1,130	1,226	1,322
Cumulative Availability, %	96.9%	94.8%	96.2%	96.6%	97.1%	97.2%	97.6%	97.8%	98.0%	97.7%	97.9%	98.1%	98.2%	98.4%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800
Actual cumulative gross output, kWhr	63,555	126,725	189,291	249,927	313,872	378,463	442,803	506,390	569,064	620,011	660,602	722,461	785,215	847,104
Cumulative Capacity Factor	80.2%	80.0%	79.7%	78.9%	79.3%	79.6%	79.9%	79.9%	79.8%	78.3%	75.8%	76.0%	76.3%	76.4%
Cumulative fuel input, MMBtu HHV	881	1,752	2,635	3,502	4,384	5,271	6,170	7,048	7,910	8,718	9,499	10,394	11,293	12,175
Cumulative gross output, kWhr	63,555	126,725	189,291	249,927	313,872	378,463	442,803	506,390	569,064	620,011	660,602	722,461	785,215	847,104
Heat Rate														
Daily heat rate, Btu/kWe gross LHV	12,479	12,412	12,705	12,871	12,417	12,362	12,578	12,430	12,381	14,277	17,320	13,024	12,896	12,829
Daily heat rate, Btu/kWe gross HHV	13,862	13,788	14,113	14,298	13,793	13,733	13,973	13,808	13,754	15,860	19,241	14,468	14,326	14,251
Cumulative heat rate, Btu/kWe gross LHV	12,479	12,445	12,531	12,614	12,573	12,537	12,543	12,529	12,513	12,658	12,944	12,951	12,947	12,938
Cumulative heat rate, Btu/kWe gross HHV	13,862	13,825	13,920	14,012	13,967	13,927	13,934	13,918	13,900	14,061	14,379	14,387	14,382	14,372
Cumulative by Facility starting Calendar Year														
Max cumulative available engine run hours	2,976	3,072	3,168	3,264	3,360	3,456	3,552	3,648	3,744	3,840	3,936	4,032	4,128	4,224
Actual cumulative engine run hours	2,901	2,990	3,085	3,179	3,274	3,368	3,464	3,559	3,655	3,746	3,842	3,938	4,034	4,130
Cumulative Availability, %	97.5%	97.3%	97.4%	97.4%	97.4%	97.5%	97.5%	97.6%	97.6%	97.6%	97.6%	97.7%	97.7%	97.8%
Max cumulative gross output, kWhr	2,455,200	2,534,400	2,613,600	2,692,800	2,772,000	2,851,200	2,930,400	3,009,600	3,088,800	3,168,000	3,247,200	3,326,400	3,405,600	3,484,800
Actual cumulative gross output, kWhr	1,945,467	2,008,637	2,071,203	2,131,839	2,195,784	2,260,375	2,324,715	2,388,302	2,450,976	2,501,923	2,542,514	2,604,373	2,667,127	2,729,016
Cumulative Capacity Factor	79.2%	79.3%	79.2%	79.2%	79.2%	79.3%	79.3%	79.4%	79.4%	79.0%	78.3%	78.3%	78.3%	78.3%
Cumulative fuel input, MMBtu HHV	26,640	27,511	28,394	29,261	30,143	31,030	31,929	32,807	33,669	34,477	35,258	36,153	37,052	37,934
Cumulative gross output, kWhr	1,945,467	2,008,637	2,071,203	2,131,839	2,195,784	2,260,375	2,324,715	2,388,302	2,450,976	2,501,923	2,542,514	2,604,373	2,667,127	2,729,016
Cumulative heat rate, Btu/kWe gross LHV	12,327	12,329	12,341	12,356	12,358	12,358	12,364	12,366	12,366	12,405	12,483	12,496	12,506	12,513
Cumulative heat rate, Btu/kWe gross HHV	13,693	13,696	13,709	13,726	13,728	13,728	13,735	13,737	13,737	13,780	13,867	13,882	13,892	13,900
Service														
Engine 1	Operations meeting		C12 firing problem			C12 fixed.		Run E1,2,3						
Engine 2			MAT sensor fixed					at full, and E4 partial				NStar outage due to communication		
Engine 3												loss - snow storm.		
Engine 4	Exh gas manifold leak	Fixed 2 leaks.	EGS01 software		Replaced EGS01			Turndown setting				Run engines in idle mode.		
Oil - oil and filter change		Fix for heat rate												
Service - plugs, air filter, valve inspection and adjustment														
NSTAR Power Reports														
Date	Monday 2/1/2010	Tuesday 2/2/2010	Wednesday 2/3/2010	Thursday 2/4/2010	Friday 2/5/2010	Saturday 2/6/2010	Sunday 2/7/2010	Monday 2/8/2010	Tuesday 2/9/2010	Wednesday 2/10/2010	Thursday 2/11/2010	Friday 2/12/2010	Saturday 2/13/2010	Sunday 2/14/2010
Hour														
1	2,496	2,134	2,718	2,490	2,555	2,638	2,643	2,643	2,599	2,612	-	2,436	2,544	2,556
2	2,488	2,678	2,698	2,456	2,555	2,638	2,638	2,642	2,604	2,614	-	2,431	2,544	2,555
3	2,487	2,706	2,685	2,410	2,553	2,638	2,638	2,638	2,596	2,614	-	2,433	2,546	2,557
4	2,486	2,685	2,659	2,398	2,551	2,637	2,637	2,633	2,589	2,616	-	2,424	2,549	2,560
5	2,481	2,668	2,658	2,394	2,554	2,637	2,652	2,631	2,613	2,614	-	2,427	2,547	2,564
6	2,479	2,641	2,678	1,928	2,555	2,638	2,655	2,638	2,605	2,613	-	2,410	2,546	2,559
7	2,473	2,550	2,667	1,886	2,555	2,639	2,625	2,633	2,526	2,614	-	2,437	2,551	2,560
8	2,490	2,557	2,182	2,613	2,553	2,641	2,566	2,625	2,476	2,615	-	2,419	2,545	2,557
9	2,492	2,449	2,638	2,577	2,641	2,614	2,588	2,512	2,708	2,463	1,410	2,463	2,547	2,556
10	2,298	2,172	2,241	2,591	2,473	2,639	2,658	2,558	2,609	2,706	2,049	2,673	2,559	2,561
11	1,916	1,649	2,926	2,545	2,763	2,600	2,667	2,602	2,612	2,769	2,041	2,644	2,567	2,557
12	2,362	2,323	2,746	2,505	2,453	2,038	2,664	2,602	2,611	2,772	2,928	2,624	2,559	2,545
13	2,301	2,421	2,622	2,499	2,666	2,251	2,662	2,565	2,605	2,773	2,933	2,531	2,562	2,546
14	2,370	2,882	2,366	2,469	2,641	2,705	2,664	2,503	2,608	2,772	2,859	2,532	2,571	2,548
15	2,801	1,989	2,602	2,276	2,636	2,745	2,665	2,469	2,605	2,772	2,776	2,540	2,569	2,551
16	2,798	2,946	2,646	2,558	2,638	2,743	2,664	2,639	2,610	2,772	2,755	2,549	2,566	2,540
17	2,799	2,977	2,619	2,555	2,640	2,741	2,661	2,639	2,609	2,771	2,738	2,548	2,565	2,523
18	2,795	2,874	2,580	2,554	2,638	2,739	2,661	2,638	2,606	2,770	2,732	2,547	2,564	2,512
19	2,757	2,843	2,587	2,556	2,639	2,741	2,659	2,637	2,611	1,132	2,709	2,546	2,566	2,521
20	2,719	2,778	2,573	2,555	2,637	2,740	2,659	2,636	2,611	-	2,488	2,545	2,566	2,518
21	2,709	2,778	2,574	2,555	2,637	2,740	2,660	2,635	2,611	-	2,431	2,537	2,565	2,517
22	2,689	2,762	2,550	2,552	2,636	2,739	2,659	2,635	2,612	-	2,441	2,534	2,562	2,523
23	2,675	2,741	2,534	2,551	2,636	2,736	2,646	2,632	2,611	-	2,442	2,532	2,559	2,533
24	2,403	2,725	2,507	2,554	2,638	2,735	2,638	2,613	2,612	-	2,441	2,537	2,558	2,536
TOTAL	60,764	61,928	61,617	59,088	62,379	63,379	63,553	62,674	62,263	49,629	40,173	60,299	61,377	61,055
Cumulative Output Sold, kWhr	60,764	122,692	184,309	243,397	305,776	369,155	432,708	495,382	557,645	607,274	647,447	707,746	769,123	830,178
Transformer and line efficiency	97.8%	100.3%	100.9%	99.8%	99.8%	100.3%	101.2%	100.9%	101.7%	99.9%	102.0%	99.9%	99.9%	100.9%
Hourly average	2,532	2,580	2,567	2,462	2,599	2,641	2,648	2,611	2,594	2,068	1,674	2,512	2,557	2,544

FEBRUARY 2010																
CNBE Daily Reports Summary Data																
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	TOTAL	
	2/15/2010	2/16/2010	2/17/2010	2/18/2010	2/19/2010	2/20/2010	2/21/2010	2/22/2010	2/23/2010	2/24/2010	2/25/2010	2/26/2010	2/27/2010	2/28/2010		
Landfill Gas Flow to the Engines (KSCF)	1,717	1,711	1,670	1,655	1,640	1,466	1,691	1,552	1,592	1,351	1,356	1,517	1,627	1,672	45,796	
Landfill Gas Flow to the Engines (MMBTU HHV)	873	883	873	863	859	645	887	821	855	761	770	860	890	882	23,897	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,717	1,711	1,670	1,655	1,640	1,466	1,691	1,552	1,592	1,351	1,356	1,517	1,627	1,672	45,796	
Landfill Gas Total Flow (MMBTU HHV)	873	883	873	863	859	645	887	821	855	761	770	860	890	882	23,897	
Average Methane Content (%)	50.2	51.0	51.7	51.5	51.7	43.5	51.8	52.3	53.1	55.7	56.1	56.0	54.0	52.1	51.6	
Engine 1 Hours	24	24	24	24	24	18	24	24	11	-	5	10	22	24	588	
Engine 2 Hours	24	24	24	24	16	17	24	24	24	23	23	24	24	24	653	
Engine 3 Hours	24	24	24	23	24	18	24	11	24	23	23	24	24	24	644	
Engine 4 Hours	24	24	24	24	24	17	24	24	24	24	24	24	23	24	656	
Generator 1 Power Output (kWhr)	19,851	19,941	19,578	19,228	18,204	12,317	18,188	17,141	7,738	-	14	2,925	15,115	18,635	416,222	
Generator 2 Power Output (kWhr)	18,654	18,761	18,771	18,532	11,256	12,039	17,661	17,935	17,886	16,261	15,278	19,347	18,803	18,528	484,892	
Generator 3 Power Output (kWhr)	17,362	18,028	15,514	17,480	17,659	12,466	17,437	7,535	17,697	16,696	15,490	19,695	19,042	17,198	470,690	
Generator 4 Power Output (kWhr)	5,028	5,048	6,529	4,763	10,817	7,001	7,000	11,626	15,436	14,097	13,861	15,194	7,293	4,917	253,938	
Gross Power Output (kWhr)	61,441	62,311	60,893	60,574	58,306	44,298	60,858	54,689	59,123	47,319	44,856	57,220	60,753	59,849	1,639,594	
Net Power Output (kWhr)	60,025	60,898	59,543	59,208	56,993	43,290	59,528	53,584	57,951	46,387	43,811	56,025	59,400	58,615	1,602,598	
Power Sold as metered by NStar, (kWhr)	60,331	60,902	59,649	59,858	57,924	42,872	61,274	54,442	58,915	47,434	44,090	56,319	59,536	58,647	1,612,371	
Offgrid RECs (kWhr)	1,416	1,413	1,350	1,366	1,313	1,008	1,330	1,105	1,172	932	1,045	1,195	1,353	1,234	36,996	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	827	831	816	801	759	684	758	714	703	-	3	293	687	776		
Generator 2	777	782	782	772	704	708	736	747	745	707	664	806	783	772		
Generator 3	723	751	646	760	736	693	727	685	737	726	673	821	793	717		
Generator 4	210	210	272	198	451	412	292	484	643	587	578	633	317	205		
Power output (kW average over 24-hrs)																
Facility Gross	2,560	2,596	2,537	2,524	2,429	1,846	2,536	2,279	2,463	1,972	1,869	2,384	2,531	2,494		
Facility Net	2,501	2,537	2,481	2,467	2,375	1,804	2,480	2,233	2,415	1,933	1,825	2,334	2,475	2,442		
In-plant load	59	59	56	57	55	42	55	46	49	39	44	50	56	51		
Daily availability factor																
Facility	100%	100%	100%	99%	92%	73%	100%	86%	86%	73%	78%	85%	97%	100%		
Engine 1	100%	100%	100%	100%	100%	75%	100%	100%	46%	0%	21%	42%	92%	100%		
Engine 2	100%	100%	100%	100%	67%	71%	100%	100%	100%	96%	96%	100%	100%	100%		
Engine 3	100%	100%	100%	96%	100%	75%	100%	46%	100%	96%	96%	100%	100%	100%		
Engine 4	100%	100%	100%	100%	100%	71%	100%	100%	100%	100%	100%	100%	96%	100%		
Daily capacity factor																
Facility	78%	79%	77%	76%	74%	56%	77%	69%	75%	60%	57%	72%	77%	76%		
Engine 1	100%	101%	99%	97%	92%	83%	92%	87%	85%	0%	0%	35%	83%	94%		
Engine 2	94%	95%	95%	94%	85%	86%	89%	91%	90%	86%	81%	98%	95%	94%		
Engine 3	88%	91%	78%	92%	89%	84%	88%	83%	89%	88%	82%	99%	96%	87%		
Engine 4	25%	25%	33%	24%	55%	50%	35%	59%	78%	71%	70%	77%	38%	25%		
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	360	384	408	432	456	480	504	528	552	576	600	624	648	672		
Engine 1	354	378	402	426	450	468	492	516	527	527	532	542	564	588		
Engine 2	358	382	406	430	446	463	487	511	535	558	581	605	629	653		
Engine 3	354	378	402	425	449	467	491	502	526	549	572	596	620	644		
Engine 4	352	376	400	424	448	465	489	513	537	561	585	609	632	656		
Engine operating run hours total from 0 hours																
Engine 1	36,426	36,450	36,474	36,498	36,522	36,540	36,564	36,588	36,599	36,599	36,604	36,614	36,636	36,660		
Engine 2	36,313	36,337	36,361	36,385	36,401	36,418	36,442	36,466	36,490	36,513	36,536	36,560	36,584	36,608		
Engine 3	35,900	35,924	35,948	35,971	35,995	36,013	36,037	36,048	36,072	36,095	36,118	36,142	36,166	36,190		
Engine 4	35,113	35,137	35,161	35,185	35,209	35,226	35,250	35,274	35,298	35,322	35,346	35,370	35,393	35,417		
Cumulative availability, %																
Engine 1	98%	98%	99%	99%	99%	98%	98%	98%	95%	91%	89%	87%	87%	88%		
Engine 2	99%	99%	100%	100%	98%	96%	97%	97%	97%	97%	97%	97%	97%	97%		
Engine 3	98%	98%	99%	98%	98%	97%	97%	95%	95%	95%	95%	96%	96%	96%		
Engine 4	98%	98%	98%	98%	98%	97%	97%	97%	97%	97%	98%	98%	98%	98%		
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	12,375	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100		
Engine 1	10,461	11,292	12,108	12,909	13,667	14,352	15,109	15,824	16,527	16,527	16,530	16,822	17,509	18,286		
Engine 2	11,050	11,832	12,614	13,386	14,090	14,798	15,534	16,281	17,026	17,733	18,398	19,204	19,987	20,759		
Engine 3	10,959	11,710	12,357	13,117	13,853	14,545	15,272	15,957	16,694	17,420	18,093	18,914	19,707	20,424		
Engine 4	5,593	5,803	6,075	6,274	6,724	7,136	7,428	7,912	8,555	9,143	9,720	10,353	10,670	10,875		
Cumulative capacity factor, %																
Engine 1	85%	86%	86%	87%	87%	87%	87%	87%	87%	83%	80%	78%	79%	79%		
Engine 2	89%	90%	90%	90%	90%	90%	90%	90%	90%	90%	89%	90%	90%	90%		
Engine 3	89%	89%	88%	88%	88%	88%	88%	88%	88%	88%	88%	88%	88%	88%		
Engine 4	45%	44%	43%	42%	43%	43%	43%	44%	45%	46%	47%	48%	48%	47%		

	Monday 2/15/2010	Tuesday 2/16/2010	Wednesday 2/17/2010	Thursday 2/18/2010	Friday 2/19/2010	Saturday 2/20/2010	Sunday 2/21/2010	Monday 2/22/2010	Tuesday 2/23/2010	Wednesday 2/24/2010	Thursday 2/25/2010	Friday 2/26/2010	Saturday 2/27/2010	Sunday 2/28/2010	TOTAL
Cumulative by Facility in month															
Max cumulative available engine run hours	1,440	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	
Actual cumulative engine run hours	1,418	1,514	1,610	1,705	1,793	1,863	1,959	2,042	2,125	2,195	2,270	2,352	2,445	2,541	
Cumulative Availability, %	98.5%	98.6%	98.7%	98.7%	98.3%	97.0%	97.2%	96.7%	96.2%	95.3%	94.6%	94.2%	94.3%	94.5%	
Max cumulative gross output, kWhr	1,188,000	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	
Actual cumulative gross output, kWhr	908,545	970,856	1,031,749	1,092,323	1,150,629	1,194,927	1,255,785	1,310,474	1,369,597	1,416,916	1,461,772	1,518,992	1,579,745	1,639,594	
Cumulative Capacity Factor	76.5%	76.6%	76.6%	76.6%	76.5%	75.4%	75.5%	75.2%	74.5%	74.5%	73.8%	73.8%	73.9%	73.9%	
Cumulative fuel input, MMBtu HHV	13,048	13,931	14,804	15,667	16,526	17,171	18,058	18,879	19,734	20,495	21,265	22,125	23,015	23,897	
Cumulative gross output, kWhr	908,545	970,856	1,031,749	1,092,323	1,150,629	1,194,927	1,255,785	1,310,474	1,369,597	1,416,916	1,461,772	1,518,992	1,579,745	1,639,594	
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	12,791	12,757	12,906	12,825	13,262	13,107	13,120	13,514	13,018	14,477	15,453	13,530	13,187	13,266	
Daily heat rate, Btu/kWe gross HHV	14,209	14,171	14,337	14,247	14,733	14,560	14,575	15,012	14,461	16,082	17,166	15,030	14,649	14,737	
Cumulative heat rate, Btu/kWe gross LHV	12,928	12,917	12,916	12,911	12,929	12,936	12,945	12,968	12,971	13,021	13,096	13,112	13,115	13,120	
Cumulative heat rate, Btu/kWe gross HHV	14,361	14,349	14,348	14,343	14,363	14,370	14,380	14,406	14,409	14,465	14,547	14,566	14,569	14,575	
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	4,320	4,416	4,512	4,608	4,704	4,800	4,896	4,992	5,088	5,184	5,280	5,376	5,472	5,568	
Actual cumulative engine run hours	4,226	4,322	4,418	4,513	4,601	4,671	4,767	4,850	4,933	5,003	5,078	5,160	5,253	5,349	
Cumulative Availability, %	97.8%	97.9%	97.9%	97.9%	97.8%	97.3%	97.4%	97.2%	97.0%	96.5%	96.2%	96.0%	96.0%	96.1%	
Max cumulative gross output, kWhr	3,564,000	3,643,200	3,722,400	3,801,600	3,880,800	3,960,000	4,039,200	4,118,400	4,197,600	4,276,800	4,356,000	4,435,200	4,514,400	4,593,600	
Actual cumulative gross output, kWhr	2,790,457	2,852,768	2,913,661	2,974,235	3,032,541	3,076,839	3,137,697	3,192,386	3,251,509	3,298,828	3,343,684	3,400,904	3,461,657	3,521,506	
Cumulative Capacity Factor	78.3%	78.3%	78.3%	78.2%	78.1%	77.7%	77.7%	77.5%	77.1%	76.8%	76.7%	76.7%	76.7%	76.7%	
Cumulative fuel input, MMBtu HHV	38,807	39,690	40,563	41,426	42,285	42,930	43,817	44,638	45,493	46,254	47,024	47,884	48,774	49,656	
Cumulative gross output, kWhr	2,790,457	2,852,768	2,913,661	2,974,235	3,032,541	3,076,839	3,137,697	3,192,386	3,251,509	3,298,828	3,343,684	3,400,904	3,461,657	3,521,506	
Cumulative heat rate, Btu/kWe gross LHV	12,519	12,524	12,532	12,538	12,552	12,560	12,571	12,587	12,595	12,622	12,660	12,675	12,684	12,694	
Cumulative heat rate, Btu/kWe gross HHV	13,907	13,913	13,922	13,928	13,944	13,953	13,965	13,983	13,991	14,021	14,064	14,080	14,090	14,101	
Service															
Engine 1	Enguity installation work on E1 ICE Fuel System.														
Engine 2	E-1 shutdown for work														
Engine 3	E1 idle, load, sync														
Engine 4	Bad valve C12														
Oil - oil and filter change	Blower leak														
Service - plugs, air filter, valve inspection and adjust	switch blowers														
	Ron Richardson														
	Instruction on														
	ICE														
NSTAR Power Reports															
Date	Monday 2/15/2010	Tuesday 2/16/2010	Wednesday 2/17/2010	Thursday 2/18/2010	Friday 2/19/2010	Saturday 2/20/2010	Sunday 2/21/2010	Monday 2/22/2010	Tuesday 2/23/2010	Wednesday 2/24/2010	Thursday 2/25/2010	Friday 2/26/2010	Saturday 2/27/2010	Sunday 2/28/2010	TOTAL
Hour															
1	2,534	2,520	2,532	2,521	2,433	2,565	2,580	2,524	2,741	2,235	915	2,273	2,532	2,465	
2	2,535	2,518	2,526	2,519	2,432	2,516	2,581	2,512	2,741	2,236	963	2,278	2,533	2,458	
3	2,532	2,521	2,521	2,517	2,429	2,516	2,579	2,513	2,741	2,239	711	2,276	2,531	2,458	
4	2,540	2,528	2,518	2,514	2,432	2,516	2,580	2,515	2,738	2,237	1,147	2,273	2,529	2,447	
5	2,535	2,529	2,511	2,509	2,431	2,515	2,580	2,507	2,738	2,236	1,146	2,276	2,527	2,435	
6	2,528	2,524	2,533	2,507	2,433	2,515	2,581	2,491	2,737	2,236	1,144	2,289	2,527	2,435	
7	2,530	2,527	2,527	2,508	2,431	2,515	2,575	2,490	2,740	2,241	1,144	2,302	2,528	2,442	
8	2,530	2,522	2,529	2,508	2,425	2,515	2,565	2,491	2,739	2,238	1,145	2,304	2,529	2,420	
9	2,524	2,525	2,531	2,509	2,414	2,512	2,560	2,293	2,696	1,747	1,423	2,307	2,532	2,418	
10	2,516	2,530	2,519	2,512	2,167	345	2,559	2,081	2,670	1,916	2,287	2,300	2,529	2,435	
11	2,512	2,540	2,499	2,359	2,280	-	2,559	2,108	2,668	2,332	2,309	2,308	1,966	2,449	
12	2,516	2,548	2,500	2,510	2,315	-	2,548	2,108	2,127	2,326	2,311	2,306	2,733	2,445	
13	2,504	2,553	2,506	2,470	2,319	-	2,551	2,106	2,237	860	2,312	2,300	2,655	2,431	
14	2,504	2,545	2,498	2,173	2,117	-	2,545	2,105	2,238	2,173	2,296	2,298	2,668	2,458	
15	2,508	2,539	2,243	2,552	2,192	-	2,541	2,010	2,235	2,006	2,290	2,277	2,716	2,444	
16	2,508	2,546	2,316	2,545	2,257	-	2,554	1,955	2,238	1,576	2,291	2,317	2,358	2,439	
17	2,504	2,555	2,417	2,540	2,306	1,782	2,546	1,989	2,236	1,929	2,276	2,331	2,090	2,448	
18	2,490	2,553	2,206	2,525	2,460	2,579	2,533	1,994	2,235	1,820	2,277	2,312	2,259	2,453	
19	2,483	2,548	2,548	2,543	2,611	2,576	2,526	1,982	2,239	2,117	2,284	2,318	2,413	2,453	
20	2,488	2,547	2,547	2,567	2,610	2,580	2,531	1,984	2,235	2,112	2,289	2,412	2,490	2,443	
21	2,492	2,548	2,537	2,546	2,608	2,579	2,524	2,071	2,235	2,116	2,290	2,642	2,481	2,432	
22	2,497	2,553	2,533	2,528	2,608	2,583	2,524	2,137	2,236	2,120	2,287	2,550	2,479	2,427	
23	2,501	2,545	2,528	2,440	2,607	2,583	2,523	2,736	2,239	1,519	2,281	2,537	2,474	2,447	
24	2,520	2,538	2,524	2,436	2,607	2,580	2,529	2,740	2,236	867	2,272	2,533	2,457	2,465	
TOTAL	60,331	60,902	59,649	59,858	57,924	42,872	61,274	54,442	58,915	47,434	44,090	56,319	59,536	58,647	
Cumulative Output Sold, kWhr	890,509	951,411	1,011,060	1,070,918	1,128,842	1,171,714	1,232,988	1,287,430	1,346,345	1,393,779	1,437,869	1,494,188	1,553,724	1,612,371	
Transformer and line efficiency	100.5%	100.0%	100.2%	101.1%	101.6%	99.0%	102.9%	101.6%	101.7%	102.3%	100.6%	100.5%	100.2%	100.1%	0.0%
Hourly average	2,514	2,538	2,485	2,494	2,414	1,786	2,553	2,268	2,455	1,976	1,837	2,347	2,481	2,444	2,399

MARCH 2010															
CNBE Daily Reports Summary Data															
	Monday 3/1/2010	Tuesday 3/2/2010	Wednesday 3/3/2010	Thursday 3/4/2010	Friday 3/5/2010	Saturday 3/6/2010	Sunday 3/7/2010	Monday 3/8/2010	Tuesday 3/9/2010	Wednesday 3/10/2010	Thursday 3/11/2010	Friday 3/12/2010	Saturday 3/13/2010	DLST Sunday 3/14/2010	Monday 3/15/2010
Landfill Gas Flow to the Engines (KSCF)	1,381	1,433	1,530	1,560	1,669	1,684	1,670	1,656	1,665	1,668	1,694	1,646	1,580	1,473	1,572
Landfill Gas Flow to the Engines (MMBTU HHV)	783	824	881	884	908	902	897	898	890	881	890	849	834	816	875
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,381	1,433	1,530	1,560	1,669	1,684	1,670	1,656	1,665	1,668	1,694	1,646	1,580	1,473	1,572
Landfill Gas Total Flow (MMBTU HHV)	783	824	881	884	908	902	897	898	890	881	890	849	834	816	875
Average Methane Content (%)	56.0	56.8	56.9	56.0	53.8	52.9	53.1	53.6	52.8	52.2	51.9	51.0	52.2	54.7	55.0
Engine 1 Hours	24	24	24	13	24	24	24	22	24	24	24	24	24	23	22
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	23
Engine 3 Hours	16	-	24	24	24	24	24	24	24	24	24	24	24	23	22
Engine 4 Hours	9	-	9	24	24	24	24	24	24	24	24	24	24	24	24
Generator 1 Power Output (kWhr)	18,150	18,884	19,266	5,587	10,969	11,751	11,670	12,402	18,280	18,352	18,792	18,887	18,740	17,936	17,417
Generator 2 Power Output (kWhr)	18,784	19,168	19,172	19,419	19,313	19,330	19,238	19,066	11,752	13,576	17,159	16,317	16,386	15,711	15,395
Generator 3 Power Output (kWhr)	12,900	19,376	19,514	19,764	18,097	16,936	16,587	13,589	11,888	8,746	6,987	6,918	6,962	6,691	11,472
Generator 4 Power Output (kWhr)	1,679	-	4,266	19,025	16,481	17,005	16,909	18,336	19,284	19,107	18,944	18,287	18,263	17,493	19,129
Gross Power Output (kWhr)	51,991	57,931	62,800	64,217	65,530	65,685	65,037	63,954	61,872	60,402	62,562	61,131	61,067	58,540	63,922
Net Power Output (kWhr)	51,116	56,951	61,625	63,136	64,251	64,381	63,740	62,676	60,583	59,124	61,337	59,964	60,019	57,579	62,782
Power Sold as metered by NStar, (kWhr)	51,482	57,603	62,353	63,132	64,377	64,489	64,169	62,559	60,807	59,970	61,230	60,385	60,220	57,702	63,047
Offgrid RECs (kWhr)	875	980	1,175	1,081	1,279	1,304	1,297	1,278	1,289	1,278	1,225	1,167	1,048	961	1,140
Calculated Performance Results															
Daily															
Power output (kW average when running)															
Generator 1	756	787	803	430	457	490	486	564	762	765	783	787	781	780	792
Generator 2	783	799	799	809	805	805	802	794	490	566	715	680	683	683	669
Generator 3	806	807	813	824	754	706	691	566	495	364	291	288	290	291	521
Generator 4	187	-	474	793	687	709	705	764	804	796	789	762	761	761	797
Power output (kW average over 24-hrs)															
Facility Gross	2,166	2,414	2,617	2,676	2,730	2,737	2,710	2,665	2,578	2,517	2,607	2,547	2,544	2,545	2,663
Facility Net	2,130	2,373	2,568	2,631	2,677	2,683	2,656	2,612	2,524	2,464	2,556	2,499	2,501	2,503	2,616
In-plant load	36	41	49	45	53	54	54	53	54	53	51	49	44	42	48
Daily availability factor															
Facility	76%	75%	84%	89%	100%	100%	100%	98%	100%	100%	100%	100%	100%	100%	95%
Engine 1	100%	100%	100%	54%	100%	100%	100%	92%	100%	100%	100%	100%	100%	100%	92%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%
Engine 3	67%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	92%
Engine 4	38%	0%	38%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Daily capacity factor															
Facility	66%	73%	79%	81%	83%	83%	82%	81%	78%	76%	79%	77%	77%	77%	81%
Engine 1	92%	95%	97%	52%	55%	59%	59%	68%	92%	93%	95%	95%	95%	96%	96%
Engine 2	95%	97%	97%	98%	98%	98%	97%	96%	59%	69%	87%	82%	83%	83%	81%
Engine 3	98%	98%	99%	100%	91%	86%	84%	69%	60%	44%	35%	35%	35%	35%	63%
Engine 4	23%	0%	57%	96%	83%	86%	85%	93%	97%	97%	96%	92%	92%	92%	97%
Cumulative by engine															
Engine operating run hours in the month															
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	335	359
Engine 1	24	48	72	85	109	133	157	179	203	227	251	275	299	322	344
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	335	358
Engine 3	16	40	64	88	112	136	160	184	208	232	256	280	304	327	349
Engine 4	9	9	18	42	66	90	114	138	162	186	210	234	258	281	305
Engine operating run hours total from 0 hours															
Engine 1	36,684	36,708	36,732	36,745	36,769	36,793	36,817	36,839	36,863	36,887	36,911	36,935	36,959	36,983	37,004
Engine 2	36,632	36,656	36,680	36,704	36,728	36,752	36,776	36,800	36,824	36,848	36,872	36,896	36,920	36,944	36,966
Engine 3	36,206	36,230	36,254	36,278	36,302	36,326	36,350	36,374	36,398	36,422	36,446	36,470	36,494	36,517	36,539
Engine 4	35,426	35,426	35,435	35,459	35,483	35,507	35,531	35,555	35,579	35,603	35,627	35,651	35,675	35,698	35,722
Cumulative availability, %															
Engine 1	100%	100%	100%	89%	91%	92%	93%	93%	94%	95%	95%	95%	96%	96%	96%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	67%	83%	89%	92%	93%	94%	95%	96%	96%	97%	97%	97%	97%	98%	97%
Engine 4	38%	19%	25%	44%	55%	63%	68%	72%	75%	78%	80%	81%	83%	84%	85%
Engine cumulative gross output, kWhr															
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375
Engine 1	756	1,543	2,346	2,776	3,233	3,722	4,209	4,772	5,534	6,299	7,082	7,869	8,649	9,429	10,221
Engine 2	783	1,581	2,380	3,189	3,994	4,799	5,601	6,395	7,189	7,983	8,777	9,571	10,365	11,159	11,953
Engine 3	806	1,614	2,427	3,250	4,044	4,710	5,401	5,967	6,463	6,827	7,118	7,406	7,696	7,987	8,509
Engine 4	187	187	661	1,453	2,140	2,849	3,553	4,317	5,121	5,917	6,706	7,468	8,229	8,989	9,787
Cumulative capacity factor, %															
Engine 1	92%	94%	95%	84%	78%	75%	73%	72%	75%	76%	78%	79%	81%	82%	83%
Engine 2	95%	96%	96%	97%	97%	97%	97%	97%	93%	90%	89%	89%	89%	88%	88%
Engine 3	98%	98%	98%	98%	97%	95%	94%	90%	87%	83%	78%	75%	72%	69%	69%
Engine 4	23%	11%	27%	44%	52%	58%	62%	65%	69%	72%	74%	75%	77%	78%	79%

MARCH 2010																	TOTAL
CNBE Daily Reports Summary Data																	
	Tuesday 3/16/2010	Wednesday 3/17/2010	Thursday 3/18/2010	Friday 3/19/2010	Saturday 3/20/2010	Sunday 3/21/2010	Monday 3/22/2010	Tuesday 3/23/2010	Wednesday 3/24/2010	Thursday 3/25/2010	Friday 3/26/2010	Saturday 3/27/2010	Sunday 3/28/2010	Monday 3/29/2010	Tuesday 3/30/2010	Wednesday 3/31/2010	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,637	1,605	1,596	1,642	1,669	1,660	1,652	1,611	1,614	1,626	1,623	1,655	1,615	1,621	1,603	1,600	49,910
Landfill Gas Flow to the Engines (MMBTU HHV)	871	864	860	854	859	835	847	867	866	853	852	843	833	853	871	853	26,693
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,637	1,605	1,596	1,642	1,669	1,660	1,652	1,611	1,614	1,626	1,623	1,655	1,615	1,621	1,603	1,600	49,910
Landfill Gas Total Flow (MMBTU HHV)	871	864	860	854	859	835	847	867	866	853	852	843	833	853	871	853	26,693
Average Methane Content (%)	52.6	53.2	53.2	51.4	50.9	49.7	50.7	53.2	53.0	51.8	51.9	50.3	51.0	52.0	53.7	52.7	52.8
Engine 1 Hours	22	22	24	21	24	24	24	24	24	24	24	24	24	24	24	24	721
Engine 2 Hours	24	24	20	24	24	24	24	24	24	24	24	24	24	24	24	24	738
Engine 3 Hours	24	24	20	23	24	21	23	24	24	24	24	24	24	24	24	24	724
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	689
Generator 1 Power Output (kWhr)	16,132	15,327	18,721	14,559	13,951	16,468	18,391	16,559	16,474	16,260	16,172	15,830	15,419	15,935	16,303	15,875	495,459
Generator 2 Power Output (kWhr)	13,342	12,045	12,246	16,123	18,148	19,175	17,913	16,330	16,340	15,945	15,734	15,404	16,356	16,889	16,304	15,433	513,513
Generator 3 Power Output (kWhr)	16,787	17,034	13,411	13,613	15,487	7,680	8,691	14,929	14,572	15,088	14,594	14,002	11,565	13,105	15,537	15,341	417,863
Generator 4 Power Output (kWhr)	19,294	18,890	19,312	18,316	17,527	19,046	17,938	16,211	16,249	15,867	15,662	15,539	16,470	16,858	16,237	15,426	499,050
Gross Power Output (kWhr)	66,073	63,861	64,257	63,134	65,880	62,878	63,684	64,755	64,456	63,905	62,898	61,491	60,457	63,474	65,096	62,811	1,945,751
Net Power Output (kWhr)	64,795	62,594	62,891	61,660	64,361	61,422	62,286	63,415	63,098	62,449	61,516	60,076	59,119	62,075	63,718	61,446	1,906,185
Power Sold as metered by NStar, (kWhr)	65,025	61,958	62,856	61,876	64,449	61,463	61,621	63,614	62,518	62,130	61,447	59,252	59,348	61,871	63,095	61,232	1,907,280
Offgrid RECs (kWhr)	1,278	1,267	1,366	1,474	1,519	1,456	1,398	1,340	1,358	1,456	1,382	1,415	1,338	1,399	1,378	1,365	39,566
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	
Generator 1	733	697	780	693	581	686	766	690	686	678	674	660	642	664	679	661	
Generator 2	556	502	612	672	756	799	746	680	681	664	656	642	682	704	679	643	
Generator 3	699	710	671	592	645	366	378	622	607	629	608	583	482	546	647	639	
Generator 4	804	787	805	763	730	794	747	675	677	661	653	647	686	702	677	643	
Power output (kW average over 24-hrs)																	
Facility Gross	2,753	2,661	2,677	2,631	2,745	2,620	2,654	2,698	2,686	2,663	2,621	2,562	2,519	2,645	2,712	2,617	
Facility Net	2,700	2,608	2,620	2,569	2,682	2,559	2,595	2,642	2,629	2,602	2,563	2,503	2,463	2,586	2,655	2,560	
In-plant load	53	53	57	61	63	61	58	56	57	61	58	59	56	58	57	57	
Daily availability factor																	
Facility	98%	98%	92%	96%	100%	97%	99%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 1	92%	100%	100%	88%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	83%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	83%	96%	100%	88%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																	
Facility	83%	81%	81%	80%	83%	79%	80%	82%	81%	81%	79%	78%	76%	80%	82%	79%	
Engine 1	89%	84%	95%	84%	70%	83%	93%	84%	83%	82%	82%	80%	78%	80%	82%	80%	
Engine 2	67%	61%	74%	81%	92%	97%	90%	82%	83%	81%	79%	78%	83%	85%	82%	78%	
Engine 3	85%	86%	81%	72%	78%	44%	46%	75%	74%	76%	74%	71%	58%	66%	78%	77%	
Engine 4	97%	95%	98%	93%	89%	96%	91%	82%	82%	80%	79%	78%	83%	85%	82%	78%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	383	407	431	455	479	503	527	551	575	599	623	647	671	695	719	743	
Engine 1	366	388	412	433	457	481	505	529	553	577	601	625	649	673	697	721	
Engine 2	382	406	426	450	474	498	522	546	570	594	618	642	666	690	714	738	
Engine 3	373	397	417	440	464	485	508	532	556	580	604	628	652	676	700	724	
Engine 4	329	353	377	401	425	449	473	497	521	545	569	593	617	641	665	689	
Engine operating run hours total from 0 hours																	
Engine 1	37,026	37,048	37,072	37,093	37,117	37,141	37,165	37,189	37,213	37,237	37,261	37,285	37,309	37,333	37,357	37,381	
Engine 2	36,990	37,014	37,034	37,058	37,082	37,106	37,130	37,154	37,178	37,202	37,226	37,250	37,274	37,298	37,322	37,346	
Engine 3	36,563	36,587	36,607	36,630	36,654	36,675	36,698	36,722	36,746	36,770	36,794	36,818	36,842	36,866	36,890	36,914	
Engine 4	35,746	35,770	35,794	35,818	35,842	35,866	35,890	35,914	35,938	35,962	35,986	36,010	36,034	36,058	36,082	36,106	
Cumulative availability, %																	
Engine 1	96%	95%	96%	95%	95%	96%	96%	96%	96%	96%	96%	97%	97%	97%	97%	97%	
Engine 2	100%	100%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	
Engine 3	97%	98%	97%	97%	97%	96%	96%	97%	97%	97%	97%	97%	97%	97%	97%	97%	
Engine 4	86%	87%	87%	88%	89%	89%	90%	90%	91%	91%	91%	92%	92%	92%	92%	93%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	24,750	
Engine 1	10,954	11,651	12,431	13,124	13,705	14,392	15,158	15,848	16,534	17,212	17,886	18,545	19,188	19,852	20,531	20,513	
Engine 2	11,437	11,939	12,551	13,223	13,979	14,778	15,524	16,205	16,885	17,550	18,205	18,847	19,529	20,232	20,912	20,875	
Engine 3	9,208	9,918	10,589	11,180	11,826	12,491	13,191	13,928	14,677	15,427	16,177	16,927	17,677	18,427	19,177	19,927	
Engine 4	10,590	11,378	12,182	12,945	13,676	14,469	15,217	15,992	16,769	17,530	18,283	19,036	19,789	20,542	21,295	22,048	
Cumulative capacity factor, %																	
Engine 1	83%	83%	84%	84%	83%	83%	84%	84%	84%	83%	83%	83%	83%	83%	83%	83%	
Engine 2	87%	85%	85%	84%	85%	85%	86%	85%	85%	85%	85%	85%	85%	85%	84%	84%	
Engine 3	70%	71%	71%	71%	72%	70%	69%	70%	70%	70%	70%	70%	70%	70%	70%	70%	
Engine 4	80%	81%	82%	83%	83%	84%	84%	84%	84%	84%	83%	83%	83%	83%	83%	83%	

APRIL 2010															
CNBE Daily Reports Summary Data															
	Thursday 4/1/2010	Friday 4/2/2010	Saturday 4/3/2010	Sunday 4/4/2010	Monday 4/5/2010	Tuesday 4/6/2010	Wednesday 4/7/2010	Thursday 4/8/2010	Friday 4/9/2010	Saturday 4/10/2010	Sunday 4/11/2010	Monday 4/12/2010	Tuesday 4/13/2010	Wednesday 4/14/2010	Thursday 4/15/2010
Landfill Gas Flow to the Engines (KSCF)	1,588	1,605	1,595	1,570	1,558	1,458	1,534	1,562	1,621	1,594	1,572	1,517	1,552	1,600	1,606
Landfill Gas Flow to the Engines (MMBTU HHV)	831	824	829	817	824	793	829	848	841	827	812	790	818	826	828
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,588	1,605	1,595	1,570	1,558	1,458	1,534	1,562	1,621	1,594	1,572	1,517	1,552	1,600	1,606
Landfill Gas Total Flow (MMBTU HHV)	831	824	829	817	824	793	829	848	841	827	812	790	818	826	828
Average Methane Content (%)	51.7	50.7	51.4	51.4	52.3	53.8	53.4	53.6	51.3	51.3	51.0	51.4	52.1	51.0	51.0
Engine 1 Hours	24	24	24	24	23	17	24	23	23	24	24	10	11	24	24
Engine 2 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24
Engine 3 Hours	24	24	24	24	24	19	10	10	23	24	24	24	24	24	24
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	23	24	24	24
Generator 1 Power Output (kWhr)	15,472	16,286	16,743	16,681	16,344	11,229	17,251	17,952	16,541	19,608	19,472	7,586	6,501	18,431	18,862
Generator 2 Power Output (kWhr)	15,124	15,910	16,265	16,181	15,810	16,984	18,930	18,277	16,347	16,995	16,844	18,593	18,330	18,082	18,522
Generator 3 Power Output (kWhr)	15,145	12,499	10,620	10,574	9,872	6,075	2,986	5,897	8,730	4,644	4,600	11,629	13,327	6,021	4,601
Generator 4 Power Output (kWhr)	15,031	16,002	16,438	16,349	17,628	19,106	19,250	19,013	18,256	19,265	19,109	18,232	17,068	16,757	18,275
Gross Power Output (kWhr)	61,486	61,488	60,925	60,631	60,341	53,831	58,956	61,621	59,980	60,681	60,204	56,194	55,205	58,173	60,696
Net Power Output (kWhr)	60,164	60,127	59,619	59,324	59,021	52,633	57,442	60,201	58,572	59,403	58,867	55,020	53,933	56,776	59,285
Power Sold as metered by NStar, (kWhr)	60,071	59,997	59,280	59,297	59,090	53,264	57,340	59,875	59,441	60,277	60,223	55,534	54,727	58,166	60,564
Offgrid RECs (kWhr)	1,322	1,361	1,306	1,307	1,320	1,198	1,514	1,420	1,408	1,278	1,337	1,174	1,272	1,397	1,411
Calculated Performance Results															
Daily															
Power output (kW average when running)															
Generator 1	645	679	698	695	711	661	719	781	719	817	811	759	591	768	786
Generator 2	630	663	678	674	659	708	789	762	681	708	702	775	764	753	772
Generator 3	631	521	443	441	411	320	299	590	380	194	192	485	555	251	192
Generator 4	626	667	685	681	735	796	802	792	761	803	796	793	711	698	761
Power output (kW average over 24-hrs)															
Facility Gross	2,562	2,562	2,539	2,526	2,514	2,243	2,457	2,568	2,499	2,528	2,509	2,341	2,300	2,424	2,529
Facility Net	2,507	2,505	2,484	2,472	2,459	2,193	2,393	2,508	2,441	2,475	2,453	2,293	2,247	2,366	2,470
In-plant load	55	57	54	54	55	50	63	59	59	53	56	49	53	58	59
Daily availability factor															
Facility	100%	100%	100%	100%	99%	88%	85%	84%	98%	100%	100%	84%	86%	100%	100%
Engine 1	100%	100%	100%	100%	96%	71%	100%	96%	100%	100%	100%	42%	46%	100%	100%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	100%	100%	100%	100%	100%	79%	42%	42%	96%	100%	100%	100%	100%	100%	100%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%
Daily capacity factor															
Facility	78%	78%	77%	77%	76%	68%	74%	78%	76%	77%	76%	71%	70%	73%	77%
Engine 1	78%	82%	85%	84%	86%	80%	87%	95%	87%	99%	98%	92%	72%	93%	95%
Engine 2	76%	80%	82%	82%	86%	86%	96%	92%	83%	86%	85%	94%	93%	91%	94%
Engine 3	76%	63%	54%	53%	50%	39%	36%	71%	46%	23%	23%	59%	67%	30%	23%
Engine 4	76%	81%	83%	83%	89%	96%	97%	96%	92%	97%	97%	96%	86%	85%	92%
Cumulative by engine															
Engine operating run hours in the month															
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360
Engine 1	24	48	72	96	119	136	160	183	206	230	254	264	275	299	323
Engine 2	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360
Engine 3	24	48	72	96	120	139	149	159	182	206	230	254	278	302	326
Engine 4	24	48	72	96	120	144	168	192	216	240	264	287	311	335	359
Engine operating run hours total from 0 hours															
Engine 1	37,405	37,429	37,453	37,477	37,500	37,517	37,541	37,564	37,587	37,611	37,635	37,645	37,656	37,680	37,704
Engine 2	37,370	37,394	37,418	37,442	37,466	37,490	37,514	37,538	37,562	37,586	37,610	37,634	37,658	37,682	37,706
Engine 3	36,938	36,962	36,986	37,010	37,034	37,053	37,063	37,073	37,096	37,120	37,144	37,168	37,192	37,216	37,240
Engine 4	36,130	36,154	36,178	36,202	36,226	36,250	36,274	36,298	36,322	36,346	36,370	36,393	36,417	36,441	36,465
Cumulative availability, %															
Engine 1	100%	100%	100%	100%	99%	94%	95%	95%	95%	96%	96%	92%	88%	89%	90%
Engine 2	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine 3	100%	100%	100%	100%	100%	89%	87%	83%	84%	86%	87%	88%	89%	90%	91%
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Engine cumulative gross output, kWhr															
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375
Engine 1	645	1,323	2,021	2,716	3,427	4,087	4,806	5,586	6,306	7,123	7,934	8,692	9,283	10,051	10,837
Engine 2	630	1,293	1,971	2,645	3,304	4,011	4,800	5,562	6,243	6,951	7,653	8,428	9,191	9,945	10,716
Engine 3	631	1,152	1,594	2,035	2,446	2,766	3,065	3,654	4,034	4,227	4,419	4,904	5,459	5,710	5,901
Engine 4	626	1,293	1,978	2,659	3,394	4,190	4,992	5,784	6,545	7,347	8,144	8,936	9,647	10,346	11,107
Cumulative capacity factor, %															
Engine 1	78%	80%	82%	82%	83%	83%	83%	85%	85%	86%	87%	88%	87%	87%	88%
Engine 2	76%	78%	80%	80%	80%	81%	83%	84%	84%	84%	84%	85%	86%	86%	87%
Engine 3	76%	70%	64%	62%	59%	56%	53%	55%	54%	51%	49%	50%	51%	49%	48%
Engine 4	76%	78%	80%	81%	82%	85%	86%	88%	88%	89%	90%	90%	90%	90%	90%

	Thursday 4/1/2010	Friday 4/2/2010	Saturday 4/3/2010	Sunday 4/4/2010	Monday 4/5/2010	Tuesday 4/6/2010	Wednesday 4/7/2010	Thursday 4/8/2010	Friday 4/9/2010	Saturday 4/10/2010	Sunday 4/11/2010	Monday 4/12/2010	Tuesday 4/13/2010	Wednesday 4/14/2010	Thursday 4/15/2010
Cumulative by Facility in month															
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440
Actual cumulative engine run hours	96	192	288	384	479	563	645	726	820	916	1,012	1,093	1,176	1,272	1,368
Cumulative Availability, %	100.0%	100.0%	100.0%	100.0%	99.8%	97.7%	96.0%	94.5%	94.9%	95.4%	95.8%	94.2%	94.6%	94.6%	95.0%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000
Actual cumulative gross output, kWhr	61,486	122,974	183,899	244,530	304,871	358,702	417,658	479,279	539,259	599,940	660,144	716,338	771,543	829,716	890,412
Cumulative Capacity Factor	77.6%	77.6%	77.4%	77.2%	77.0%	75.5%	75.3%	75.6%	75.7%	75.8%	75.8%	75.4%	74.9%	74.8%	75.0%
Cumulative fuel input, MMBtu HHV	831	1,655	2,484	3,301	4,125	4,918	5,747	6,595	7,436	8,263	9,075	9,865	10,683	11,509	12,337
Cumulative gross output, kWhr	61,486	122,974	183,899	244,530	304,871	358,702	417,658	479,279	539,259	599,940	660,144	716,338	771,543	829,716	890,412
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	12,166	12,064	12,249	12,130	12,293	13,261	12,658	12,388	12,622	12,268	12,141	12,655	13,339	12,782	12,280
Daily heat rate, Btu/kWe gross HHV	13,515	13,401	13,607	13,475	13,656	14,731	14,061	13,762	14,021	13,629	13,487	14,058	14,817	14,199	13,642
Cumulative heat rate, Btu/kWe gross LHV	12,166	12,115	12,159	12,152	12,180	12,342	12,387	12,387	12,413	12,398	12,375	12,397	12,464	12,487	12,473
Cumulative heat rate, Btu/kWe gross HHV	13,515	13,458	13,507	13,499	13,530	13,711	13,760	13,760	13,789	13,773	13,747	13,771	13,846	13,871	13,855
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	8,544	8,640	8,736	8,832	8,928	9,024	9,120	9,216	9,312	9,408	9,504	9,600	9,696	9,792	9,888
Actual cumulative engine run hours	8,221	8,317	8,413	8,509	8,604	8,688	8,770	8,851	8,945	9,041	9,137	9,218	9,301	9,397	9,493
Cumulative Availability, %	96.2%	96.3%	96.3%	96.3%	96.4%	96.3%	96.2%	96.0%	96.1%	96.1%	96.1%	96.0%	95.9%	96.0%	96.0%
Max cumulative gross output, kWhr	7,048,800	7,128,000	7,207,200	7,286,400	7,365,600	7,444,800	7,524,000	7,603,200	7,682,400	7,761,600	7,840,800	7,920,000	7,999,200	8,078,400	8,157,600
Actual cumulative gross output, kWhr	5,463,647	5,525,135	5,586,060	5,646,691	5,707,032	5,760,863	5,819,819	5,881,440	5,941,420	6,002,101	6,062,305	6,118,499	6,173,704	6,231,877	6,292,573
Cumulative Capacity Factor	77.5%	77.5%	77.5%	77.5%	77.5%	77.4%	77.4%	77.4%	77.3%	77.3%	77.3%	77.3%	77.2%	77.1%	77.1%
Cumulative fuel input, MMBtu HHV	76,309	77,133	77,962	78,779	79,603	80,396	81,225	82,073	82,914	83,741	84,553	85,343	86,161	86,987	87,815
Cumulative gross output, kWhr	5,463,647	5,525,135	5,586,060	5,646,691	5,707,032	5,760,863	5,819,819	5,881,440	5,941,420	6,002,101	6,062,305	6,118,499	6,173,704	6,231,877	6,292,573
Cumulative heat rate, Btu/kWe gross LHV	12,573	12,567	12,564	12,559	12,556	12,563	12,564	12,562	12,562	12,560	12,555	12,555	12,563	12,563	12,563
Cumulative heat rate, Btu/kWe gross HHV	13,967	13,960	13,957	13,951	13,948	13,956	13,957	13,955	13,955	13,952	13,947	13,948	13,956	13,958	13,955
Service															
Engine 1	700					Enginuity ICE system work			Fix waste gate			Service	Exhaust manifold leak fix		
Engine 2	700								Adjust waste gas to open Proact throttle plate						
Engine 3	450							Heads replaced	Adjust waste gas to open Proact throttle plate						
Engine 4	750							3,5,9,13,15				Service			
Oil - oil and filter change	2600														
Service - plugs, air filter, valve inspection and adjustment									Operations meetin						
NSTAR Power Reports															
Date	Thursday 4/1/2010	Friday 4/2/2010	Saturday 4/3/2010	Sunday 4/4/2010	Monday 4/5/2010	Tuesday 4/6/2010	Wednesday 4/7/2010	Thursday 4/8/2010	Friday 4/9/2010	Saturday 4/10/2010	Sunday 4/11/2010	Monday 4/12/2010	Tuesday 4/13/2010	Wednesday 4/14/2010	Thursday 4/15/2010
Hour															
1	2,461	2,558	2,472	2,472	2,472	2,495	2,263	2,431	2,516	2,515	2,503	2,512	2,094	2,120	2,609
2	2,465	2,562	2,471	2,472	2,473	2,495	1,941	2,431	2,506	2,513	2,509	2,505	2,076	2,121	2,608
3	2,461	2,558	2,471	2,472	2,473	2,495	2,300	2,430	2,491	2,512	2,513	2,510	2,069	2,173	2,604
4	2,465	2,563	2,467	2,473	2,472	2,497	2,529	2,431	2,527	2,510	2,512	2,509	2,068	2,153	2,607
5	2,461	2,559	2,471	2,473	2,471	2,499	2,518	2,431	2,525	2,502	2,511	2,504	2,066	2,108	2,608
6	2,465	2,509	2,468	2,474	2,471	2,498	2,524	2,431	2,505	2,499	2,512	2,498	2,069	2,109	2,604
7	2,466	2,509	2,471	2,474	2,471	2,500	2,536	2,432	2,478	2,502	2,513	2,508	2,070	2,113	2,608
8	2,444	2,505	2,473	2,475	2,473	2,504	2,543	2,433	2,450	2,513	2,513	2,513	2,103	2,111	2,608
9	2,419	2,507	2,472	2,475	2,245	2,363	2,225	2,429	2,452	2,516	2,506	2,498	2,186	2,101	2,554
10	2,443	2,506	2,471	2,475	2,243	1,719	2,279	2,427	2,428	2,517	2,514	2,073	2,254	2,564	2,474
11	2,467	2,605	2,469	2,473	2,616	1,513	2,245	2,425	2,402	2,515	2,513	2,186	2,258	2,607	2,473
12	2,494	2,439	2,466	2,469	2,622	1,537	2,404	2,424	2,355	2,515	2,510	1,860	2,258	2,606	2,473
13	2,500	2,468	2,466	2,467	2,544	1,718	2,414	2,421	2,264	2,515	2,510	1,631	2,257	2,605	2,472
14	2,509	2,464	2,466	2,466	2,519	1,382	2,410	2,421	2,344	2,516	2,511	2,310	2,259	2,604	2,474
15	2,498	2,465	2,467	2,467	2,076	1,769	2,410	2,505	2,567	2,515	2,510	2,308	2,395	2,604	2,477
16	2,557	2,466	2,466	2,466	2,491	1,901	2,411	2,794	2,512	2,516	2,509	2,312	2,589	2,608	2,479
17	2,561	2,465	2,468	2,465	2,494	1,740	2,415	2,628	2,515	2,516	2,509	2,307	2,542	2,608	2,478
18	2,562	2,467	2,470	2,466	2,498	1,670	2,417	2,608	2,516	2,516	2,510	2,307	2,536	2,608	2,479
19	2,563	2,469	2,472	2,467	2,494	2,264	2,420	2,607	2,516	2,507	2,510	2,310	2,536	2,608	2,481
20	2,563	2,470	2,473	2,468	2,493	2,779	2,422	2,597	2,515	2,516	2,495	2,317	2,538	2,607	2,480
21	2,562	2,471	2,473	2,470	2,491	2,734	2,427	2,537	2,515	2,506	2,508	2,310	2,535	2,609	2,478
22	2,562	2,471	2,472	2,472	2,494	2,740	2,428	2,527	2,516	2,509	2,507	2,312	2,530	2,607	2,480
23	2,561	2,470	2,472	2,473	2,499	2,735	2,428	2,526	2,513	2,503	2,511	2,311	2,242	2,608	2,478
24	2,562	2,471	2,473	2,473	2,495	2,717	2,431	2,549	2,513	2,513	2,504	2,123	2,197	2,604	2,478
TOTAL	60,071	59,997	59,280	59,297	59,090	53,264	57,340	59,875	59,441	60,277	60,223	55,534	54,727	58,166	60,564
Cumulative Output Sold, kWhr	60,071	120,068	179,348	238,645	297,735	350,999	408,339	468,214	527,655	587,932	648,155	703,689	758,416	816,582	877,146
Transformer and line efficiency	99.8%	99.8%	99.4%	100.0%	100.1%	101.2%	99.8%	99.8%	101.5%	101.5%	102.3%	100.9%	102.4%	102.4%	102.2%
Hourly average	2,503	2,500	2,470	2,471	2,462	2,219	2,389	2,495	2,477	2,512	2,509	2,314	2,280	2,424	2,524

APRIL 2010																
CNBE Daily Reports Summary Data																
	Friday 4/16/2010	Saturday 4/17/2010	Sunday 4/18/2010	Monday 4/19/2010	Tuesday 4/20/2010	Wednesday 4/21/2010	Thursday 4/22/2010	Friday 4/23/2010	Saturday 4/24/2010	Sunday 4/25/2010	Monday 4/26/2010	Tuesday 4/27/2010	Wednesday 4/28/2010	Thursday 4/29/2010	Friday 4/30/2010	TOTAL
Landfill Gas Flow to the Engines (KSCF)	1,602	1,576	1,591	1,514	1,376	1,363	1,364	1,526	1,643	1,572	1,575	1,580	1,608	1,589	1,604	46,615
Landfill Gas Flow to the Engines (MMBTU HHV)	823	827	828	792	746	757	762	840	842	826	831	831	835	807	806	24,490
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,602	1,576	1,591	1,514	1,376	1,363	1,364	1,526	1,643	1,572	1,575	1,580	1,608	1,589	1,604	46,615
Landfill Gas Total Flow (MMBTU HHV)	823	827	828	792	746	757	762	840	842	826	831	831	835	807	806	24,490
Average Methane Content (%)	50.8	51.8	51.4	51.7	53.6	54.9	55.2	54.4	50.6	51.9	52.1	52.0	51.3	50.2	49.7	51.9
Engine 1 Hours	24	24	24	24	23	25	24	24	24	24	24	24	24	24	24	683
Engine 2 Hours	24	24	24	24	21	24	24	24	24	24	24	24	24	24	24	717
Engine 3 Hours	24	24	24	24	-	-	-	15	23	22	22	22	24	24	22	596
Engine 4 Hours	24	24	24	24	24	24	24	23	25	24	24	24	24	24	24	719
Generator 1 Power Output (kWhr)	18,792	18,686	18,758	19,519	19,312	19,566	19,800	18,198	15,725	15,679	15,723	15,666	15,524	15,204	18,042	499,153
Generator 2 Power Output (kWhr)	18,376	18,207	18,250	17,886	13,816	14,744	14,046	16,081	15,295	15,275	15,288	15,115	15,205	14,961	15,292	495,031
Generator 3 Power Output (kWhr)	4,626	4,589	4,605	1,518	-	-	-	9,945	15,121	12,249	13,046	13,339	13,809	13,352	8,596	242,015
Generator 4 Power Output (kWhr)	18,249	18,201	18,290	19,221	19,017	19,234	19,532	17,875	16,359	16,390	16,341	16,042	15,554	15,253	17,793	529,130
Gross Power Output (kWhr)	60,178	59,576	60,107	58,574	52,396	53,618	53,797	62,701	62,636	59,988	60,599	60,424	60,714	58,982	60,253	1,774,955
Net Power Output (kWhr)	58,844	58,268	58,778	57,307	51,278	52,457	52,657	61,319	61,081	58,601	59,119	58,887	59,068	57,302	58,530	1,733,883
Power Sold as metered by NStar, (kWhr)	59,450	59,427	59,441	57,324	51,487	53,606	52,848	61,609	61,420	58,879	59,623	59,409	59,365	58,771	58,578	1,748,383
Offgrid RECs (kWhr)	1,334	1,308	1,329	1,267	1,118	1,161	1,140	1,382	1,555	1,387	1,480	1,537	1,646	1,680	1,723	41,072
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	783	779	782	813	840	783	825	758	655	653	655	653	647	634	752	
Generator 2	766	759	760	745	658	614	585	670	637	636	637	630	634	623	637	
Generator 3	193	191	192	63	-	-	-	663	657	557	593	606	575	556	391	
Generator 4	760	758	762	801	792	801	814	777	654	683	681	668	648	636	741	
Power output (kW average over 24-hrs)																
Facility Gross	2,507	2,482	2,504	2,441	2,183	2,234	2,242	2,613	2,610	2,500	2,525	2,518	2,530	2,458	2,511	
Facility Net	2,452	2,428	2,449	2,388	2,137	2,186	2,194	2,555	2,545	2,442	2,463	2,454	2,461	2,388	2,439	
In-plant load	56	55	55	53	47	48	48	58	65	58	62	64	69	70	72	
Daily availability factor																
Facility	100%	100%	100%	100%	71%	76%	75%	90%	100%	98%	98%	98%	100%	100%	98%	
Engine 1	100%	100%	100%	100%	96%	104%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	100%	100%	100%	88%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	100%	100%	100%	0%	0%	0%	63%	96%	92%	92%	92%	100%	100%	92%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	96%	104%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	76%	75%	76%	74%	66%	68%	68%	79%	79%	76%	77%	76%	77%	74%	76%	
Engine 1	95%	94%	95%	99%	102%	95%	100%	92%	79%	79%	79%	79%	78%	77%	91%	
Engine 2	93%	92%	92%	90%	80%	74%	71%	81%	77%	77%	77%	76%	77%	76%	77%	
Engine 3	23%	23%	23%	8%	0%	0%	0%	80%	80%	67%	72%	73%	70%	67%	47%	
Engine 4	92%	92%	92%	97%	96%	97%	99%	94%	79%	83%	83%	81%	79%	77%	90%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	384	408	432	456	480	504	528	552	576	600	624	648	672	696	720	
Engine 1	347	371	395	419	442	467	491	515	539	563	587	611	635	659	683	
Engine 2	384	408	432	456	477	501	525	549	573	597	621	645	669	693	717	
Engine 3	350	374	398	422	422	422	422	437	460	482	504	526	550	574	596	
Engine 4	383	407	431	455	479	503	527	550	575	599	623	647	671	695	719	
Engine operating run hours total from 0 hours																
Engine 1	37,728	37,752	37,776	37,800	37,823	37,848	37,872	37,896	37,920	37,944	37,968	37,992	38,016	38,040	38,064	
Engine 2	37,730	37,754	37,778	37,802	37,823	37,847	37,871	37,895	37,919	37,943	37,967	37,991	38,015	38,039	38,063	
Engine 3	37,264	37,288	37,312	37,336	37,336	37,336	37,336	37,351	37,374	37,396	37,418	37,440	37,464	37,488	37,510	
Engine 4	36,489	36,513	36,537	36,561	36,585	36,609	36,633	36,656	36,681	36,705	36,729	36,753	36,777	36,801	36,825	
Cumulative availability, %																
Engine 1	90%	91%	91%	92%	92%	93%	93%	93%	94%	94%	94%	94%	94%	94%	95%	
Engine 2	100%	100%	100%	100%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	
Engine 3	91%	92%	92%	93%	88%	84%	80%	79%	80%	80%	81%	81%	82%	82%	83%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	
Engine 1	11,620	12,399	13,181	13,994	14,833	15,616	16,441	17,199	17,855	18,508	19,163	19,816	20,463	21,096	21,848	
Engine 2	11,482	12,241	13,001	13,746	14,404	15,019	15,804	16,274	16,911	17,548	18,185	18,814	19,448	20,071	20,709	
Engine 3	6,094	6,285	6,477	6,541	6,541	6,541	6,541	7,204	7,861	8,418	9,011	9,617	10,192	10,749	11,139	
Engine 4	11,868	12,626	13,388	14,189	14,981	15,783	16,596	17,374	18,028	18,711	19,392	20,060	20,708	21,344	22,085	
Cumulative capacity factor, %																
Engine 1	88%	88%	89%	89%	90%	90%	91%	91%	90%	90%	89%	89%	89%	88%	88%	
Engine 2	87%	87%	88%	88%	87%	87%	86%	86%	85%	85%	85%	84%	84%	84%	84%	
Engine 3	46%	44%	42%	42%	40%	38%	36%	38%	40%	41%	42%	43%	44%	45%	45%	
Engine 4	90%	90%	90%	91%	91%	91%	91%	92%	91%	91%	90%	90%	90%	89%	89%	

	Friday 4/16/2010	Saturday 4/17/2010	Sunday 4/18/2010	Monday 4/19/2010	Tuesday 4/20/2010	Wednesday 4/21/2010	Thursday 4/22/2010	Friday 4/23/2010	Saturday 4/24/2010	Sunday 4/25/2010	Monday 4/26/2010	Tuesday 4/27/2010	Wednesday 4/28/2010	Thursday 4/29/2010	Friday 4/30/2010	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	
Actual cumulative engine run hours	1,464	1,560	1,656	1,752	1,820	1,893	1,965	2,051	2,147	2,241	2,335	2,429	2,525	2,621	2,715	
Cumulative Availability, %	95.3%	95.6%	95.8%	96.1%	94.8%	93.9%	93.0%	92.9%	93.2%	93.4%	93.5%	93.7%	93.9%	94.1%	94.3%	
Max cumulative gross output, kWhr	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	
Actual cumulative gross output, kWhr	950,590	1,010,166	1,070,273	1,128,847	1,181,243	1,234,861	1,288,658	1,351,359	1,413,995	1,473,983	1,534,582	1,595,006	1,655,720	1,714,702	1,774,955	
Cumulative Capacity Factor	75.0%	75.0%	75.1%	75.0%	74.6%	74.2%	74.0%	74.2%	74.4%	74.4%	74.5%	74.6%	74.7%	74.7%	74.7%	
Cumulative fuel input, MMBtu HHV	13,160	13,987	14,815	15,607	16,353	17,110	17,872	18,712	19,554	20,380	21,211	22,042	22,877	23,684	24,490	
Cumulative gross output, kWhr	950,590	1,010,166	1,070,273	1,128,847	1,181,243	1,234,861	1,288,658	1,351,359	1,413,995	1,473,983	1,534,582	1,595,006	1,655,720	1,714,702	1,774,955	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	12,311	12,496	12,401	12,172	12,817	12,709	12,751	12,060	12,101	12,395	12,344	12,380	12,380	12,317	12,042	
Daily heat rate, Btu/kWe gross HHV	13,676	13,881	13,775	13,521	14,238	14,118	14,164	13,397	13,443	13,769	13,713	13,753	13,753	13,682	13,377	
Cumulative heat rate, Btu/kWe gross LHV	12,462	12,464	12,461	12,446	12,462	12,473	12,485	12,465	12,449	12,447	12,443	12,440	12,438	12,434	12,421	
Cumulative heat rate, Btu/kWe gross HHV	13,844	13,846	13,842	13,826	13,844	13,856	13,869	13,847	13,829	13,826	13,822	13,819	13,817	13,812	13,798	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	9,984	10,080	10,176	10,272	10,368	10,464	10,560	10,656	10,752	10,848	10,944	11,040	11,136	11,232	11,328	
Actual cumulative engine run hours	9,589	9,685	9,781	9,877	9,945	10,018	10,090	10,176	10,272	10,366	10,460	10,554	10,650	10,746	10,840	
Cumulative Availability, %	96.0%	96.1%	96.1%	96.2%	95.9%	95.8%	95.5%	95.5%	95.5%	95.6%	95.6%	95.6%	95.6%	95.7%	95.7%	
Max cumulative gross output, kWhr	8,236,800	8,316,000	8,395,200	8,474,400	8,553,600	8,632,800	8,712,000	8,791,200	8,870,400	8,949,600	9,028,800	9,108,000	9,187,200	9,266,400	9,345,600	
Actual cumulative gross output, kWhr	6,352,751	6,412,327	6,472,434	6,531,008	6,583,404	6,637,022	6,690,819	6,753,520	6,816,156	6,876,144	6,936,743	6,997,167	7,057,881	7,116,863	7,177,116	
Cumulative Capacity Factor	77.1%	77.1%	77.1%	77.1%	77.0%	76.9%	76.8%	76.8%	76.8%	76.8%	76.8%	76.8%	76.8%	76.8%	76.8%	
Cumulative fuel input, MMBtu HHV	88,638	89,465	90,293	91,085	91,831	92,588	93,350	94,190	95,032	95,858	96,689	97,520	98,355	99,162	99,968	
Cumulative gross output, kWhr	6,352,751	6,412,327	6,472,434	6,531,008	6,583,404	6,637,022	6,690,819	6,753,520	6,816,156	6,876,144	6,936,743	6,997,167	7,057,881	7,116,863	7,177,116	
Cumulative heat rate, Btu/kWe gross LHV	12,560	12,560	12,558	12,558	12,557	12,558	12,560	12,555	12,551	12,549	12,548	12,546	12,545	12,543	12,539	
Cumulative heat rate, Btu/kWe gross HHV	13,953	13,952	13,950	13,947	13,949	13,950	13,952	13,947	13,942	13,941	13,939	13,937	13,935	13,933	13,929	
Service																
Engine 1																
Engine 2						Turbo failure										
Engine 3						In-Frame Overhaul		Commence operation								
Engine 4																
Oil - oil and filter change					NStar required								District pumping commencement			
Service - plugs, air filter, valve inspection and adjust					lower of load								Well 29 40ft, 8 gpm			
NSTAR Power Reports																
Date	Friday 4/16/2010	Saturday 4/17/2010	Sunday 4/18/2010	Monday 4/19/2010	Tuesday 4/20/2010	Wednesday 4/21/2010	Thursday 4/22/2010	Friday 4/23/2010	Saturday 4/24/2010	Sunday 4/25/2010	Monday 4/26/2010	Tuesday 4/27/2010	Wednesday 4/28/2010	Thursday 4/29/2010	Friday 4/30/2010	TOTAL
Hour																
1	2,479	2,476	2,475	2,475	2,347	2,149	2,152	2,320	2,661	2,537	2,488	2,479	2,481	2,459	2,444	
2	2,479	2,476	2,477	2,473	2,348	2,149	2,155	2,322	2,663	2,536	2,488	2,481	2,479	2,458	2,445	
3	2,479	2,476	2,478	2,474	2,355	2,148	2,155	2,322	2,660	2,536	2,488	2,480	2,480	2,458	2,444	
4	2,479	2,474	2,477	2,474	2,354	2,148	2,157	2,323	2,638	2,536	2,487	2,481	2,480	2,457	2,445	
5	2,479	2,475	2,478	2,475	2,355	2,148	2,155	2,323	2,630	2,535	2,488	2,481	2,479	2,453	2,337	
6	2,479	2,475	2,477	2,475	2,354	2,147	2,155	2,323	2,631	2,535	2,488	2,481	2,481	2,451	2,204	
7	2,480	2,476	2,479	2,475	2,355	2,149	2,153	2,325	2,584	2,536	2,489	2,482	2,481	2,453	2,446	
8	2,481	2,477	2,479	2,470	2,355	2,148	2,156	2,323	2,527	2,425	2,489	2,483	2,481	2,452	2,445	
9	2,477	2,477	2,479	2,384	2,351	2,204	1,847	2,325	2,584	1,950	2,486	2,400	2,477	2,441	2,393	
10	2,475	2,477	2,478	2,386	2,369	2,247	1,958	2,616	2,614	1,995	2,486	2,418	2,477	2,436	2,314	
11	2,475	2,477	2,477	2,346	2,374	2,267	2,121	2,748	2,632	2,407	2,486	2,478	2,478	2,442	2,359	
12	2,474	2,477	2,474	2,324	2,378	2,317	2,179	2,774	2,630	2,491	2,486	2,478	2,478	2,443	2,391	
13	2,474	2,477	2,477	2,324	2,380	2,346	2,208	2,781	2,630	2,488	2,485	2,480	2,471	2,446	2,365	
14	2,474	2,477	2,476	2,327	1,700	2,359	2,218	2,780	2,627	2,486	2,480	2,481	2,473	2,444	2,326	
15	2,474	2,477	2,477	2,327	1,171	2,369	2,233	2,762	2,630	2,486	2,476	2,481	2,473	2,449	2,522	
16	2,478	2,477	2,477	2,331	1,583	2,375	2,290	2,733	2,631	2,489	2,481	2,483	2,482	2,449	2,528	
17	2,478	2,477	2,477	2,344	1,591	2,372	2,308	2,734	2,630	2,489	2,483	2,485	2,476	2,449	2,528	
18	2,478	2,477	2,477	2,352	1,902	2,372	2,320	2,731	2,631	2,490	2,483	2,484	2,474	2,451	2,527	
19	2,477	2,477	2,477	2,354	2,138	2,369	2,320	2,686	2,628	2,489	2,482	2,484	2,469	2,450	2,529	
20	2,477	2,468	2,477	2,353	2,146	2,220	2,324	2,685	2,617	2,489	2,482	2,484	2,464	2,449	2,526	
21	2,477	2,477	2,475	2,353	2,141	2,156	2,323	2,678	2,596	2,489	2,481	2,483	2,459	2,447	2,519	
22	2,476	2,477	2,475	2,341	2,143	2,149	2,321	2,668	2,002	2,488	2,482	2,482	2,458	2,446	2,512	
23	2,476	2,477	2,475	2,341	2,148	2,150	2,320	2,663	1,945	2,488	2,481	2,481	2,458	2,445	2,514	
24	2,475	2,476	2,474	2,346	2,149	2,148	2,320	2,664	2,399	2,489	2,478	2,479	2,456	2,443	2,515	
TOTAL	59,450	59,427	59,441	57,324	51,487	53,606	52,848	61,609	61,420	58,879	59,623	59,409	59,365	58,771	58,578	
Cumulative Output Sold, kWhr	936,596	996,023	1,055,464	1,112,788	1,164,275	1,217,881	1,270,729	1,332,338	1,393,758	1,452,637	1,512,260	1,571,669	1,631,034	1,689,805	1,748,383	
Transformer and line efficiency	101.0%	102.0%	101.1%	100.0%	100.4%	102.2%	100.4%	100.3%	100.5%	100.9%	100.9%	100.9%	100.5%	102.6%	100.1%	0.0%
Hourly average	2,477	2,476	2,477	2,389	2,145	2,234	2,202	2,567	2,559	2,453	2,484	2,475	2,474	2,449	2,441	2,428

MAY 2010																
CNBE Daily Reports Summary Data																
	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	
	5/1/2010	5/2/2010	5/3/2010	5/4/2010	5/5/2010	5/6/2010	5/7/2010	5/8/2010	5/9/2010	5/10/2010	5/11/2010	5/12/2010	5/13/2010	5/14/2010	5/15/2010	
Landfill Gas Flow to the Engines (KSCF)	1,552	1,476	1,566	1,575	1,494	1,587	1,568	1,501	1,543	1,506	1,479	1,250	1,327	1,206	1,483	
Landfill Gas Flow to the Engines (MMBTU HHV)	781	777	805	805	767	822	812	804	817	793	791	701	793	720	840	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,552	1,476	1,566	1,575	1,494	1,587	1,568	1,501	1,543	1,506	1,479	1,250	1,327	1,206	1,483	
Landfill Gas Total Flow (MMBTU HHV)	781	777	805	805	767	822	812	804	817	793	791	701	793	720	840	
Average Methane Content (%)	49.7	52.0	50.8	50.5	50.7	51.2	51.2	52.9	52.3	52.0	52.8	55.4	59.0	59.0	56.0	
Engine 1 Hours	24	24	24	24	22	24	24	24	24	24	24	8	-	13	24	
Engine 2 Hours	24	17	24	24	23	24	24	24	24	8	1	12	24	24	24	
Engine 3 Hours	24	24	23	24	21	24	24	24	24	24	24	9	3	11	24	
Engine 4 Hours	24	24	24	24	23	24	24	24	24	24	24	24	24	24	24	
Generator 1 Power Output (kWhr)	16,478	15,093	15,308	15,464	16,066	17,160	15,573	14,877	14,774	18,024	19,728	6,909	-	7,922	14,900	
Generator 2 Power Output (kWhr)	14,854	6,452	10,250	14,155	11,946	12,778	12,733	12,503	12,468	3,914	-	9,096	27,673	17,395	11,615	
Generator 3 Power Output (kWhr)	6,999	14,940	15,775	13,464	10,750	13,740	14,915	14,617	14,815	16,700	17,579	6,190	263	7,207	16,753	
Generator 4 Power Output (kWhr)	19,439	19,055	17,651	15,529	15,874	16,658	15,279	14,683	14,942	17,491	18,809	19,036	27,765	18,339	16,861	
Gross Power Output (kWhr)	58,145	55,575	59,642	59,544	55,548	61,188	59,320	57,300	57,411	56,171	56,293	41,314	56,182	50,989	60,031	
Net Power Output (kWhr)	56,516	54,048	57,949	57,847	53,988	59,503	57,767	55,974	56,100	54,900	55,044	40,323	54,811	49,746	58,504	
Power Sold as metered by NStar, (kWhr)	57,306	55,487	58,099	57,754	54,193	59,652	57,878	57,380	56,771	55,538	55,931	41,033	36,602	50,715	59,706	
Offgrid RECs (kWhr)	1,629	1,527	1,693	1,697	1,560	1,685	1,553	1,326	1,311	1,271	1,249	991	1,371	1,243	1,527	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	687	629	638	644	730	715	649	620	616	751	822	864	-	609	621	
Generator 2	619	380	427	590	519	532	531	521	520	489	-	758	1,153	725	484	
Generator 3	292	623	686	561	512	573	621	609	617	696	732	688	88	655	698	
Generator 4	810	794	735	647	690	694	637	612	623	729	784	793	1,157	764	703	
Power output (kW average over 24-hrs)																
Facility Gross	2,423	2,316	2,485	2,481	2,315	2,550	2,472	2,388	2,392	2,340	2,346	1,721	2,341	2,125	2,501	
Facility Net	2,355	2,252	2,415	2,410	2,250	2,479	2,407	2,332	2,338	2,288	2,294	1,680	2,284	2,073	2,438	
In-plant load	68	64	71	71	65	70	65	55	55	53	52	41	57	52	64	
Daily availability factor																
Facility	100%	93%	99%	100%	93%	100%	100%	100%	100%	83%	76%	55%	53%	75%	100%	
Engine 1	100%	100%	100%	100%	92%	100%	100%	100%	100%	100%	100%	33%	0%	54%	100%	
Engine 2	100%	71%	100%	100%	96%	100%	100%	100%	100%	33%	4%	50%	100%	100%	100%	
Engine 3	100%	100%	96%	100%	88%	100%	100%	100%	100%	100%	100%	38%	13%	46%	100%	
Engine 4	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Daily capacity factor																
Facility	73%	70%	75%	75%	70%	77%	75%	72%	72%	71%	71%	52%	71%	64%	76%	
Engine 1	83%	76%	77%	78%	89%	87%	79%	75%	75%	91%	100%	105%	0%	74%	75%	
Engine 2	75%	46%	52%	71%	63%	65%	64%	63%	63%	59%	0%	92%	140%	88%	59%	
Engine 3	35%	75%	83%	68%	62%	69%	75%	74%	75%	84%	89%	83%	11%	79%	85%	
Engine 4	98%	96%	89%	78%	84%	84%	84%	77%	74%	75%	88%	95%	96%	140%	85%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	
Engine 1	24	48	72	96	118	142	166	190	214	238	262	270	270	283	307	
Engine 2	24	41	65	89	112	136	160	184	208	216	217	229	253	277	301	
Engine 3	24	48	71	95	116	140	164	188	212	236	260	269	272	283	307	
Engine 4	24	48	72	96	119	143	167	191	215	239	263	287	311	335	359	
Engine operating run hours total from 0 hours																
Engine 1	38,088	38,112	38,136	38,160	38,182	38,206	38,230	38,254	38,278	38,302	38,326	38,334	38,334	38,347	38,371	
Engine 2	38,087	38,104	38,128	38,152	38,175	38,199	38,223	38,247	38,271	38,295	38,280	38,292	38,316	38,340	38,364	
Engine 3	37,534	37,558	37,605	37,650	37,626	37,650	37,674	37,698	37,722	37,746	37,770	37,779	37,782	37,793	37,817	
Engine 4	36,849	36,873	36,897	36,921	36,944	36,968	36,992	37,016	37,040	37,064	37,088	37,112	37,136	37,160	37,184	
Cumulative availability, %																
Engine 1	100%	100%	100%	100%	98%	99%	99%	99%	99%	99%	99%	94%	87%	84%	85%	
Engine 2	100%	85%	90%	93%	93%	94%	95%	96%	96%	90%	82%	80%	81%	82%	84%	
Engine 3	100%	100%	99%	99%	97%	97%	98%	98%	98%	98%	98%	93%	87%	84%	85%	
Engine 4	100%	100%	100%	100%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	
Engine 1	687	1,315	1,953	2,598	3,328	4,043	4,692	5,312	5,927	6,678	7,500	8,364	8,364	8,973	9,594	
Engine 2	619	998	1,426	2,015	2,535	3,067	3,598	4,119	4,638	5,127	5,127	5,885	7,038	7,763	8,247	
Engine 3	292	914	1,600	2,161	2,673	3,245	3,867	4,476	5,093	5,789	6,521	7,209	7,297	7,952	8,650	
Engine 4	810	1,604	2,339	2,986	3,677	4,371	5,007	5,619	6,242	6,970	7,754	8,547	9,704	10,468	11,171	
Cumulative capacity factor, %																
Engine 1	83%	80%	79%	79%	81%	82%	81%	80%	80%	81%	83%	84%	78%	78%	78%	
Engine 2	75%	61%	58%	61%	61%	62%	62%	62%	62%	62%	57%	59%	66%	67%	67%	
Engine 3	35%	55%	65%	65%	65%	66%	67%	68%	69%	70%	72%	73%	68%	69%	70%	
Engine 4	98%	97%	95%	90%	89%	88%	87%	85%	84%	84%	85%	86%	90%	91%	90%	

	Saturday 5/1/2010	Sunday 5/2/2010	Monday 5/3/2010	Tuesday 5/4/2010	Wednesday 5/5/2010	Thursday 5/6/2010	Friday 5/7/2010	Saturday 5/8/2010	Sunday 5/9/2010	Monday 5/10/2010	Tuesday 5/11/2010	Wednesday 5/12/2010	Thursday 5/13/2010	Friday 5/14/2010	Saturday 5/15/2010
Cumulative by Facility in month															
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440
Actual cumulative engine run hours	96	185	280	376	465	561	657	753	849	929	1,002	1,055	1,106	1,178	1,274
Cumulative Availability, %	100.0%	96.4%	97.2%	97.9%	96.9%	97.4%	97.8%	98.0%	98.3%	96.8%	94.9%	91.6%	88.6%	87.6%	88.5%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000
Actual cumulative gross output, kWhr	58,145	113,720	173,362	232,906	288,454	349,642	408,962	466,262	523,673	579,844	636,137	677,451	733,633	784,622	844,653
Cumulative Capacity Factor	73.4%	71.8%	73.0%	73.5%	72.8%	73.6%	73.8%	73.6%	73.5%	73.2%	73.0%	71.3%	71.3%	70.8%	71.1%
Cumulative fuel input, MMBtu HHV	781	1,558	2,363	3,168	3,935	4,757	5,569	6,373	7,190	7,983	8,774	9,475	10,268	10,988	11,828
Cumulative gross output, kWhr	58,145	113,720	173,362	232,906	288,454	349,642	408,962	466,262	523,673	579,844	636,137	677,451	733,633	784,622	844,653
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	12,091	12,586	12,150	12,170	12,430	12,093	12,322	12,631	12,810	12,709	12,649	15,274	12,706	12,711	12,596
Daily heat rate, Btu/kWe gross HHV	13,432	13,981	13,497	13,519	13,808	13,434	13,688	14,031	14,231	14,118	14,051	16,968	14,115	14,121	13,993
Cumulative heat rate, Btu/kWe gross LHV	12,091	12,333	12,270	12,245	12,280	12,247	12,258	12,304	12,360	12,393	12,416	12,590	12,599	12,607	12,606
Cumulative heat rate, Btu/kWe gross HHV	13,432	13,700	13,630	13,602	13,642	13,605	13,617	13,668	13,730	13,767	13,793	13,986	13,996	14,004	14,003
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	11,424	11,520	11,616	11,712	11,808	11,904	12,000	12,096	12,192	12,288	12,384	12,480	12,576	12,672	12,768
Actual cumulative engine run hours	10,936	11,025	11,120	11,216	11,305	11,401	11,497	11,593	11,689	11,769	11,842	11,895	11,946	12,018	12,114
Cumulative Availability, %	95.7%	95.7%	95.7%	95.8%	95.7%	95.8%	95.8%	95.8%	95.9%	95.8%	95.6%	95.3%	95.0%	94.8%	94.9%
Max cumulative gross output, kWhr	9,424,800	9,504,000	9,583,200	9,662,400	9,741,600	9,820,800	9,900,000	9,979,200	10,058,400	10,137,600	10,216,800	10,296,000	10,375,200	10,454,400	10,533,600
Actual cumulative gross output, kWhr	7,235,261	7,290,836	7,350,478	7,410,022	7,465,570	7,526,758	7,586,078	7,643,378	7,700,789	7,756,960	7,813,253	7,854,567	7,910,749	7,961,738	8,021,769
Cumulative Capacity Factor	76.8%	76.7%	76.7%	76.7%	76.6%	76.6%	76.6%	76.6%	76.6%	76.5%	76.5%	76.3%	76.2%	76.2%	76.2%
Cumulative fuel input, MMBtu HHV	100,749	101,526	102,331	103,136	103,903	104,725	105,537	106,341	107,158	107,951	108,742	109,443	110,236	110,956	111,796
Cumulative gross output, kWhr	7,235,261	7,290,836	7,350,478	7,410,022	7,465,570	7,526,758	7,586,078	7,643,378	7,700,789	7,756,960	7,813,253	7,854,567	7,910,749	7,961,738	8,021,769
Cumulative heat rate, Btu/kWe gross LHV	12,535	12,535	12,532	12,529	12,529	12,525	12,523	12,524	12,528	12,528	12,529	12,529	12,544	12,545	12,546
Cumulative heat rate, Btu/kWe gross HHV	13,925	13,925	13,922	13,918	13,918	13,914	13,912	13,913	13,915	13,917	13,918	13,934	13,935	13,936	13,937
Service															
Engine 1															Overhaul (Minor)----- Restart
Engine 2															Overhaul (Minor)----- Restart
Engine 3															Engine fuel system-----
Engine 4															
Oil - oil and filter change				District tune wellfield	Ground short on blower shut down facility twice	Operations meeting									
Service - plugs, air filter, valve inspection and adjustment															
NSTAR Power Reports															
Date	Saturday 5/1/2010	Sunday 5/2/2010	Monday 5/3/2010	Tuesday 5/4/2010	Wednesday 5/5/2010	Thursday 5/6/2010	Friday 5/7/2010	Saturday 5/8/2010	Sunday 5/9/2010	Monday 5/10/2010	Tuesday 5/11/2010	Wednesday 5/12/2010	Thursday 5/13/2010	Friday 5/14/2010	Saturday 5/15/2010
Hour															
1	2,524	1,722	2,465	2,430	2,395	2,572	2,465	2,387	2,394	2,311	2,359	2,336	1,588	1,580	2,626
2	2,529	1,725	2,461	2,429	2,395	2,572	2,464	2,387	2,395	2,311	2,362	2,340	1,590	1,579	2,622
3	2,529	1,726	2,445	2,433	2,393	2,573	2,466	2,391	2,392	2,314	2,361	2,342	1,591	1,576	2,620
4	2,528	1,726	2,443	2,436	2,392	2,572	2,464	2,393	2,386	2,316	2,361	2,347	1,592	1,579	2,614
5	2,528	1,726	2,444	2,432	2,388	2,572	2,463	2,392	2,385	2,315	2,361	2,349	1,591	1,580	2,608
6	2,389	1,726	2,442	2,432	897	2,572	2,465	2,391	2,382	2,315	2,361	2,349	1,592	1,580	2,589
7	2,356	2,343	2,448	2,423	-	2,573	2,466	2,392	2,379	2,312	2,354	2,353	1,592	1,580	2,576
8	2,357	2,574	2,459	2,389	1,888	2,571	2,463	2,392	2,377	2,308	2,341	2,351	1,589	1,582	2,536
9	2,357	2,555	2,255	2,388	2,541	2,506	2,407	2,393	2,378	2,177	2,327	1,740	1,584	1,578	2,460
10	2,357	2,562	1,986	2,388	2,542	2,386	2,380	2,388	2,378	2,281	2,317	953	1,345	1,581	2,464
11	2,359	2,543	2,512	2,389	1,209	2,385	2,382	2,388	2,380	2,299	2,315	754	92	1,769	2,461
12	2,356	2,539	2,482	2,393	2,060	2,383	2,380	2,392	2,380	2,300	2,320	757	1,583	1,586	2,463
13	2,354	2,528	2,440	2,394	2,549	2,383	2,381	2,392	2,380	2,294	2,315	953	1,576	2,376	2,463
14	2,350	2,532	2,438	2,397	2,612	2,385	2,379	2,391	2,381	2,289	2,313	1,359	1,578	2,456	2,462
15	2,351	2,528	2,437	2,403	2,623	2,485	2,383	2,390	2,379	2,328	2,313	1,499	1,578	2,555	2,452
16	2,356	2,531	2,439	2,412	2,629	2,462	2,383	2,390	2,377	2,328	2,300	1,569	1,577	2,541	2,445
17	2,358	2,513	2,443	2,409	2,619	2,462	2,384	2,389	2,377	2,322	2,297	1,571	1,680	2,619	2,446
18	2,360	2,492	2,442	2,404	2,582	2,463	2,383	2,389	2,372	2,332	2,314	1,573	1,778	2,765	2,437
19	2,359	2,486	2,441	2,402	2,590	2,463	2,386	2,390	2,341	2,321	2,315	1,591	1,605	2,853	2,431
20	2,361	2,492	2,442	2,395	2,601	2,463	2,387	2,391	2,317	2,334	2,317	1,592	1,583	2,841	2,423
21	2,356	2,494	2,440	2,397	2,572	2,463	2,387	2,391	2,314	2,359	2,325	1,590	1,582	2,679	2,394
22	2,362	2,482	2,433	2,394	2,572	2,463	2,387	2,394	2,310	2,355	2,327	1,589	1,580	2,628	2,382
23	2,360	2,473	2,431	2,392	2,572	2,462	2,386	2,394	2,308	2,359	2,327	1,587	1,578	2,627	2,369
24	2,210	2,469	2,431	2,393	2,572	2,461	2,387	2,393	2,309	2,358	2,329	1,589	1,578	2,625	2,363
TOTAL	57,306	55,487	58,099	57,754	54,193	59,652	57,878	57,380	56,771	55,538	55,931	41,033	36,602	50,715	59,706
Cumulative Output Sold, kWhr	57,306	112,793	170,892	228,646	282,839	342,491	400,369	457,749	514,520	570,058	625,989	667,022	703,624	754,339	814,045
Transformer and line efficiency	101.4%	102.7%	100.3%	99.8%	100.4%	100.3%	100.2%	102.5%	101.2%	101.2%	101.6%	101.8%	66.8%	101.9%	102.1%
Hourly average	2,388	2,312	2,421	2,406	2,258	2,486	2,412	2,391	2,365	2,314	2,330	1,710	1,525	2,113	2,488

MAY 2010																	
CNBE Daily Reports Summary Data																	
	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	TOTAL
	5/16/2010	5/17/2010	5/18/2010	5/19/2010	5/20/2010	5/21/2010	5/22/2010	5/23/2010	5/24/2010	5/25/2010	5/26/2010	5/27/2010	5/28/2010	5/29/2010	5/30/2010	5/31/2010	
Landfill Gas Flow to the Engines (KSCF)	1,496	1,429	1,526	1,621	1,549	1,588	1,602	1,606	1,578	1,499	1,537	1,504	1,539	1,580	1,519	1,471	46,757
Landfill Gas Flow to the Engines (MMBTU HHV)	802	766	811	829	787	784	781	777	768	764	796	775	805	817	787	767	24,444
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,496	1,429	1,526	1,621	1,549	1,588	1,602	1,606	1,578	1,499	1,537	1,504	1,539	1,580	1,519	1,471	46,757
Landfill Gas Total Flow (MMBTU HHV)	802	766	811	829	787	784	781	777	768	764	796	775	805	817	787	767	24,444
Average Methane Content (%)	53.0	53.0	52.5	50.5	50.2	48.8	48.2	47.8	48.1	50.4	51.2	50.9	51.7	51.1	51.2	51.5	51.7
Engine 1 Hours	24	24	24	24	23	24	24	24	24	24	24	24	24	24	24	24	690
Engine 2 Hours	24	14	14	24	24	24	24	24	24	24	24	24	24	24	24	24	665
Engine 3 Hours	24	23	24	24	24	24	24	24	24	23	24	24	24	24	24	24	689
Engine 4 Hours	24	24	24	24	24	24	24	24	9	14	24	11	13	24	20	-	666
Generator 1 Power Output (kWhr)	13,916	15,571	17,254	16,440	14,085	15,217	15,014	15,062	18,151	16,787	15,042	17,534	17,629	15,750	15,793	19,848	467,369
Generator 2 Power Output (kWhr)	11,725	7,042	8,708	15,023	14,551	14,855	14,675	14,697	17,870	16,485	15,073	17,482	16,919	14,207	14,537	19,424	411,105
Generator 3 Power Output (kWhr)	15,179	15,255	18,217	17,119	15,795	15,829	15,429	15,438	18,793	16,377	16,078	18,328	18,006	16,224	16,325	19,922	453,021
Generator 4 Power Output (kWhr)	17,009	17,200	16,655	14,926	14,692	14,439	14,681	14,737	5,501	8,899	14,890	6,262	7,798	13,337	11,468	-	459,905
Gross Power Output (kWhr)	57,766	55,279	61,340	64,279	59,691	61,033	60,322	60,553	60,919	59,055	61,598	60,232	60,944	59,942	58,586	59,815	1,806,007
Net Power Output (kWhr)	56,211	53,766	59,909	62,760	58,152	59,334	58,628	58,817	59,221	57,414	59,853	58,678	59,383	58,307	56,986	58,381	1,758,820
Power Sold as metered by NStar, (kWhr)	56,857	54,169	60,423	63,071	58,569	59,918	59,083	59,017	58,823	58,741	60,057	59,417	58,739	57,563	56,315	57,576	1,752,383
Offgrid RECs (kWhr)	1,555	1,513	1,431	1,519	1,539	1,699	1,694	1,736	1,698	1,641	1,745	1,554	1,561	1,635	1,600	1,434	47,187
Calculated Performance Results																	
Daily																	
Power output (kW average when running)																	1,044
Generator 1	580	649	719	685	612	634	626	628	756	699	627	731	735	656	658	827	
Generator 2	489	503	622	626	606	619	611	612	745	687	628	728	705	592	606	809	
Generator 3	632	663	759	713	658	660	643	643	783	712	670	764	750	676	680	830	
Generator 4	709	717	694	622	612	602	612	614	611	636	620	569	600	556	573	-	
Power output (kW average over 24-hrs)																	
Facility Gross	2,407	2,303	2,556	2,678	2,487	2,543	2,513	2,523	2,538	2,461	2,567	2,510	2,539	2,498	2,441	2,492	
Facility Net	2,342	2,240	2,496	2,615	2,423	2,472	2,443	2,451	2,468	2,392	2,494	2,445	2,474	2,429	2,374	2,433	
In-plant load	65	63	60	63	64	71	71	72	71	68	73	65	65	68	67	60	
Daily availability factor																	
Facility	100%	89%	90%	100%	99%	100%	100%	100%	84%	89%	100%	86%	89%	100%	96%	75%	
Engine 1	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 2	100%	58%	58%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 3	100%	96%	100%	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	38%	58%	100%	46%	54%	100%	83%	0%	
Daily capacity factor																	
Facility	73%	70%	77%	81%	75%	77%	76%	76%	77%	75%	78%	76%	77%	76%	74%	76%	
Engine 1	70%	79%	87%	83%	74%	77%	76%	76%	92%	85%	76%	89%	89%	80%	80%	100%	
Engine 2	59%	61%	75%	76%	73%	75%	74%	74%	90%	83%	76%	88%	85%	72%	73%	98%	
Engine 3	77%	80%	92%	86%	80%	80%	78%	78%	95%	86%	81%	93%	91%	82%	82%	101%	
Engine 4	86%	87%	84%	75%	74%	73%	74%	74%	74%	77%	75%	69%	73%	67%	70%	0%	
Cumulative by engine																	
Engine operating run hours in the month																	
Max Cumulative Available, hours	384	408	432	456	480	504	528	552	576	600	624	648	672	696	720	744	
Engine 1	331	355	379	403	426	450	474	498	522	546	570	594	618	642	666	690	
Engine 2	325	339	353	377	401	425	449	473	497	521	545	569	593	617	641	665	
Engine 3	331	354	378	402	426	450	474	498	522	546	570	594	618	642	666	690	
Engine 4	383	407	431	455	479	503	527	551	560	574	598	609	622	646	666	666	
Engine operating run hours total from 0 hours																	
Engine 1	38,395	38,419	38,443	38,467	38,490	38,514	38,538	38,562	38,586	38,610	38,634	38,658	38,682	38,706	38,730	38,754	
Engine 2	38,388	38,402	38,416	38,440	38,464	38,488	38,512	38,536	38,560	38,584	38,608	38,632	38,656	38,680	38,704	38,728	
Engine 3	37,841	37,864	37,888	37,912	37,936	37,960	37,984	38,008	38,032	38,056	38,079	38,103	38,127	38,151	38,175	38,199	
Engine 4	37,208	37,232	37,256	37,280	37,304	37,328	37,352	37,376	37,385	37,399	37,423	37,434	37,447	37,471	37,491	37,491	
Cumulative availability, %																	
Engine 1	86%	87%	88%	88%	89%	89%	90%	90%	91%	91%	91%	92%	92%	92%	93%	93%	
Engine 2	85%	83%	82%	83%	84%	84%	85%	86%	86%	87%	87%	88%	88%	89%	89%	89%	
Engine 3	86%	87%	88%	88%	89%	89%	90%	90%	91%	91%	91%	92%	92%	92%	92%	93%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	97%	96%	96%	94%	93%	93%	93%	90%	
Engine cumulative gross output, kWhr																	
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	25,575	
Engine 1	10,174	10,823	11,542	12,227	12,839	13,473	14,099	14,726	15,483	16,182	16,809	17,539	18,274	19,000	19,828	20,415	
Engine 2	8,736	9,239	9,861	10,487	11,093	11,712	12,323	12,936	13,680	14,367	14,995	15,724	16,429	17,021	17,626	18,436	
Engine 3	9,283	9,946	10,705	11,418	12,076	12,736	13,379	14,022	14,805	15,517	16,187	16,951	17,701	18,377	19,057	19,887	
Engine 4	11,880	12,596	13,290	13,912	14,524	15,126	15,738	16,352	16,963	17,599	18,219	18,788	19,388	19,944	20,517	20,517	
Cumulative capacity factor, %																	
Engine 1	77%	77%	78%	78%	78%	78%	78%	78%	78%	78%	78%	79%	79%	79%	79%	80%	
Engine 2	66%	66%	66%	67%	67%	68%	68%	68%	69%	70%	70%	71%	71%	71%	71%	72%	
Engine 3	70%	71%	72%	73%	73%	74%	74%	74%	75%	75%	75%	76%	77%	77%	77%	78%	
Engine 4	90%	90%	89%	89%	88%	87%	87%	86%	86%	85%	85%	84%	84%	83%	83%	80%	

	Sunday 5/16/2010	Monday 5/17/2010	Tuesday 5/18/2010	Wednesday 5/19/2010	Thursday 5/20/2010	Friday 5/21/2010	Saturday 5/22/2010	Sunday 5/23/2010	Monday 5/24/2010	Tuesday 5/25/2010	Wednesday 5/26/2010	Thursday 5/27/2010	Friday 5/28/2010	Saturday 5/29/2010	Sunday 5/30/2010	Monday 5/31/2010	TOTAL
Cumulative by Facility in month																	
Max cumulative available engine run hours	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	2,976	
Actual cumulative engine run hours	1,370	1,455	1,541	1,637	1,732	1,828	1,924	2,020	2,101	2,186	2,282	2,365	2,450	2,546	2,638	2,710	
Cumulative Availability, %	89.2%	89.2%	89.2%	89.7%	90.2%	90.7%	91.1%	91.5%	91.2%	91.1%	91.4%	91.2%	91.1%	91.5%	91.6%	91.1%	
Max cumulative gross output, kWhr	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	2,455,200	
Actual cumulative gross output, kWhr	902,419	957,698	1,019,038	1,083,317	1,143,008	1,204,041	1,264,363	1,324,916	1,385,835	1,444,890	1,506,488	1,566,720	1,627,664	1,687,606	1,746,192	1,806,007	
Cumulative Capacity Factor	71.2%	71.1%	71.5%	72.0%	72.2%	72.4%	72.6%	72.7%	73.0%	73.0%	73.2%	73.3%	73.4%	73.5%	73.5%	73.6%	
Cumulative fuel input, MMBtu HHV	12,630	13,396	14,207	15,036	15,823	16,607	17,388	18,165	18,933	19,697	20,493	21,268	22,073	22,890	23,677	24,444	
Cumulative gross output, kWhr	902,419	957,698	1,019,038	1,083,317	1,143,008	1,204,041	1,264,363	1,324,916	1,385,835	1,444,890	1,506,488	1,566,720	1,627,664	1,687,606	1,746,192	1,806,007	
Heat Rate																	
Daily heat rate, Btu/kWe gross LHV	12,498	12,474	11,902	11,610	11,869	11,563	11,655	11,551	11,349	11,646	11,633	11,583	11,891	12,270	12,093	11,543	
Daily heat rate, Btu/kWe gross HHV	13,884	13,857	13,221	12,897	13,185	12,846	12,947	12,832	12,607	12,937	12,922	12,867	13,209	13,630	13,433	12,823	
Cumulative heat rate, Btu/kWe gross LHV	12,599	12,592	12,550	12,494	12,462	12,416	12,380	12,342	12,298	12,272	12,246	12,220	12,208	12,210	12,206	12,184	
Cumulative heat rate, Btu/kWe gross HHV	13,996	13,988	13,942	13,880	13,843	13,793	13,752	13,710	13,662	13,632	13,603	13,575	13,561	13,564	13,559	13,535	
Cumulative by Facility starting Calendar Year																	
Max cumulative available engine run hours	12,864	12,960	13,056	13,152	13,248	13,344	13,440	13,536	13,632	13,728	13,824	13,920	14,016	14,112	14,208	14,304	
Actual cumulative engine run hours	12,210	12,295	12,381	12,477	12,572	12,668	12,764	12,860	12,941	13,026	13,122	13,205	13,290	13,386	13,478	13,550	
Cumulative Availability, %	94.9%	94.9%	94.8%	94.9%	94.9%	94.9%	95.0%	95.0%	94.9%	94.9%	94.9%	94.9%	94.8%	94.9%	94.9%	94.7%	
Max cumulative gross output, kWhr	10,612,800	10,692,000	10,771,200	10,850,400	10,929,600	11,008,800	11,088,000	11,167,200	11,246,400	11,325,600	11,404,800	11,484,000	11,563,200	11,642,400	11,721,600	11,800,800	
Actual cumulative gross output, kWhr	8,079,535	8,134,814	8,196,154	8,260,433	8,320,124	8,381,157	8,441,479	8,502,032	8,562,951	8,622,006	8,683,604	8,743,836	8,804,780	8,864,722	8,923,308	8,983,123	
Cumulative Capacity Factor	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	
Cumulative fuel input, MMBtu HHV	112,598	113,364	114,175	115,004	115,791	116,575	117,356	118,133	118,901	119,665	120,461	121,236	122,041	122,858	123,645	124,412	
Cumulative gross output, kWhr	8,079,535	8,134,814	8,196,154	8,260,433	8,320,124	8,381,157	8,441,479	8,502,032	8,562,951	8,622,006	8,683,604	8,743,836	8,804,780	8,864,722	8,923,308	8,983,123	
Cumulative heat rate, Btu/kWe gross LHV	12,545	12,545	12,540	12,533	12,528	12,521	12,515	12,508	12,500	12,494	12,488	12,482	12,477	12,472	12,474	12,467	
Cumulative heat rate, Btu/kWe gross HHV	13,936	13,936	13,930	13,922	13,917	13,909	13,902	13,895	13,886	13,879	13,872	13,865	13,861	13,859	13,856	13,850	
Service																	
Engine 1																	
Engine 2			Proact change														
Engine 3										Reverse power trip							
Engine 4																	
Oil - oil and filter change				Condensate leak, and discharge failure													
Service - plugs, air filter, valve inspection and adjust				Increase IT to 32 deg													
NSTAR Power Reports																	
Date	Sunday 5/16/2010	Monday 5/17/2010	Tuesday 5/18/2010	Wednesday 5/19/2010	Thursday 5/20/2010	Friday 5/21/2010	Saturday 5/22/2010	Sunday 5/23/2010	Monday 5/24/2010	Tuesday 5/25/2010	Wednesday 5/26/2010	Thursday 5/27/2010	Friday 5/28/2010	Saturday 5/29/2010	Sunday 5/30/2010	Monday 5/31/2010	TOTAL
Hour																	
1	2,355	2,288	2,305	2,637	2,520	2,551	2,464	2,458	2,454	2,473	2,478	2,519	2,444	2,443	2,447	1,977	
2	2,352	2,291	2,311	2,648	1,969	2,549	2,463	2,462	2,451	2,470	2,481	2,530	2,445	2,444	2,448	2,392	
3	2,361	2,284	2,308	2,646	2,093	2,549	2,462	2,462	2,450	2,468	2,482	2,537	2,447	2,443	2,451	2,395	
4	2,331	2,275	2,310	2,639	2,561	2,547	2,462	2,461	2,450	2,470	2,482	2,538	2,449	2,444	2,452	2,391	
5	2,312	2,265	2,305	2,641	2,561	2,543	2,462	2,461	2,451	2,473	2,483	2,536	2,450	2,445	2,451	2,392	
6	2,313	2,261	2,300	2,642	2,555	2,541	2,461	2,462	2,451	2,472	2,484	2,534	2,451	2,445	2,447	2,397	
7	2,329	2,266	2,310	2,642	2,550	2,544	2,461	2,463	2,454	2,471	2,485	2,532	2,451	2,445	2,452	2,401	
8	2,345	2,292	2,325	2,642	2,547	2,544	2,462	2,462	2,455	2,473	2,482	2,529	2,454	2,446	2,452	2,411	
9	2,366	2,324	2,327	2,639	2,544	2,527	2,462	2,461	2,413	1,799	2,485	2,514	2,459	2,449	2,222	2,420	
10	2,384	2,460	2,521	2,634	2,198	2,469	2,461	2,458	2,405	2,300	2,499	2,386	2,462	2,450	1,891	2,422	
11	2,386	2,223	2,544	2,635	1,290	2,468	2,460	2,457	2,415	2,696	2,532	2,420	2,397	2,368	1,890	2,420	
12	2,397	2,291	2,685	2,631	2,244	2,466	2,461	2,459	2,431	2,567	2,538	2,451	2,504	2,377	2,149	2,423	
13	2,406	2,331	2,740	2,630	2,530	2,467	2,463	2,461	2,445	2,508	2,465	2,452	2,535	2,377	2,473	2,422	
14	2,413	2,133	2,703	2,627	2,549	2,467	2,464	2,460	2,465	2,462	2,511	2,453	2,539	2,333	2,539	2,421	
15	2,408	2,379	2,685	2,624	2,586	2,471	2,465	2,460	2,462	2,455	2,513	2,453	2,532	2,309	2,530	2,423	
16	2,419	2,375	2,666	2,627	2,589	2,476	2,466	2,460	2,468	2,459	2,506	2,452	2,527	2,351	2,522	2,425	
17	2,422	2,356	2,637	2,620	2,592	2,478	2,466	2,463	2,464	2,456	2,509	2,454	2,306	2,309	2,424	2,429	
18	2,416	2,337	2,638	2,618	2,590	2,471	2,464	2,461	2,458	2,454	2,505	2,449	2,389	2,303	2,467	2,431	
19	2,413	2,305	2,638	2,618	2,591	2,470	2,462	2,460	2,460	2,454	2,516	2,449	2,290	2,347	2,455	2,432	
20	2,399	2,278	2,634	2,620	2,588	2,466	2,462	2,458	2,460	2,454	2,516	2,449	2,431	2,271	2,436	2,432	
21	2,377	1,578	2,630	2,634	2,591	2,465	2,457	2,456	2,462	2,474	2,527	2,448	2,443	2,421	2,159	2,432	
22	2,349	1,920	2,630	2,632	2,593	2,462	2,459	2,452	2,462	2,476	2,527	2,446	2,446	2,446	1,882	2,430	
23	2,311	2,341	2,635	2,586	2,589	2,463	2,457	2,449	2,467	2,478	2,525	2,443	2,444	2,448	2,257	2,429	
24	2,293	2,316	2,636	2,559	2,549	2,464	2,457	2,451	2,470	2,479	2,526	2,443	2,444	2,449	2,419	2,429	
TOTAL	56,857	54,169	60,423	63,071	58,569	59,918	59,083	59,017	58,823	58,741	60,057	59,417	58,739	57,563	56,315	57,576	
Cumulative Output Sold, kWhr	870,902	925,071	985,494	1,048,565	1,107,134	1,167,052	1,226,135	1,285,152	1,343,975	1,402,716	1,462,773	1,522,190	1,580,929	1,638,492	1,694,807	1,752,383	
Transformer and line efficiency	101.1%	100.7%	100.9%	100.5%	100.7%	101.0%	100.8%	100.3%	99.3%	102.3%	100.3%	101.3%	98.9%	98.7%	98.8%	98.6%	0.0%
Hourly average	2,369	2,257	2,518	2,628	2,440	2,497	2,462	2,459	2,451	2,448	2,502	2,476	2,447	2,398	2,346	2,399	2,355

JUNE 2010																
CNBE Daily Reports Summary Data																
	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	
	6/1/2010	6/2/2010	6/3/2010	6/4/2010	6/5/2010	6/6/2010	6/7/2010	6/8/2010	6/9/2010	6/10/2010	6/11/2010	6/12/2010	6/13/2010	6/14/2010	6/15/2010	
Landfill Gas Flow to the Engines (KSCF)	1,488	1,579	1,566	1,524	1,501	1,474	1,466	1,528	1,529	1,521	1,520	1,468	1,421	1,396	1,292	
Landfill Gas Flow to the Engines (MMBTU HHV)	766	803	785	768	764	765	760	760	755	766	751	732	749	724	665	
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Landfill Gas Total Flow (KSCF)	1,488	1,579	1,566	1,524	1,501	1,474	1,466	1,528	1,529	1,521	1,520	1,468	1,421	1,396	1,292	
Landfill Gas Total Flow (MMBTU HHV)	766	803	785	768	764	765	760	760	755	766	751	732	749	724	665	
Average Methane Content (%)	50.9	50.2	49.5	49.8	50.3	51.3	51.2	49.2	48.8	49.8	48.8	49.3	52.1	51.2	50.9	
Engine 1 Hours	23	24	24	24	24	24	9	24	24	24	24	24	24	24	21	
Engine 2 Hours	23	24	24	24	24	24	24	9	-	-	-	-	-	-	-	
Engine 3 Hours	23	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
Engine 4 Hours	10	24	24	9	-	-	23	24	24	24	23	24	24	24	24	
Generator 1 Power Output (kWhr)	17,725	15,089	15,976	18,330	20,193	19,755	5,588	18,344	20,218	20,407	20,542	20,481	20,654	20,689	16,573	
Generator 2 Power Output (kWhr)	16,955	13,980	14,639	17,446	19,600	19,613	17,396	4,877	-	-	-	-	-	-	-	
Generator 3 Power Output (kWhr)	17,901	15,563	16,544	18,395	19,977	19,913	18,294	18,513	20,418	20,669	20,652	20,696	21,001	20,760	20,407	
Generator 4 Power Output (kWhr)	6,324	14,282	15,002	5,195	-	-	15,634	17,348	19,617	19,693	19,677	19,535	19,684	19,671	19,699	
Gross Power Output (kWhr)	59,366	61,899	59,953	59,775	60,079	59,389	57,316	59,283	60,548	61,063	61,294	60,980	61,593	61,409	56,998	
Net Power Output (kWhr)	57,859	60,390	58,449	58,318	58,714	58,010	56,004	57,789	58,987	59,493	59,662	59,410	60,072	59,864	55,535	
Power Sold as metered by NStar, (kWhr)	57,065	60,899	59,246	58,935	59,132	58,667	57,203	59,149	59,291	59,535	59,081	59,347	59,513	58,843	54,897	
Offgrid RECs (kWhr)	1,507	1,509	1,504	1,457	1,365	1,379	1,312	1,494	1,561	1,570	1,632	1,570	1,521	1,545	1,463	
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	771	629	666	764	841	823	621	764	842	850	856	853	861	862	789	
Generator 2	737	583	610	727	817	817	725	542	-	-	-	-	-	-	-	
Generator 3	778	648	689	766	832	830	762	771	851	861	861	862	875	865	850	
Generator 4	632	595	625	577	-	-	680	723	817	821	856	814	820	820	821	
Power output (kW average over 24-hrs)																
Facility Gross	2,474	2,579	2,498	2,491	2,503	2,475	2,388	2,470	2,523	2,544	2,554	2,541	2,566	2,559	2,375	
Facility Net	2,411	2,516	2,435	2,430	2,446	2,417	2,334	2,408	2,458	2,479	2,486	2,475	2,503	2,494	2,314	
In-plant load	63	63	63	61	57	57	55	62	65	65	68	65	63	64	61	
Daily availability factor																
Facility	82%	100%	100%	84%	75%	75%	83%	84%	75%	75%	74%	75%	75%	75%	72%	
Engine 1	96%	100%	100%	100%	100%	100%	38%	100%	100%	100%	100%	100%	100%	100%	88%	
Engine 2	96%	100%	100%	100%	100%	100%	100%	38%	0%	0%	0%	0%	0%	0%	0%	
Engine 3	96%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	42%	100%	100%	38%	0%	0%	96%	100%	100%	100%	96%	100%	100%	100%	100%	
Daily capacity factor																
Facility	75%	78%	76%	75%	76%	75%	72%	75%	76%	77%	77%	77%	78%	78%	72%	
Engine 1	93%	76%	81%	93%	102%	100%	75%	93%	102%	103%	104%	103%	104%	104%	96%	
Engine 2	89%	71%	74%	88%	99%	99%	88%	66%	0%	0%	0%	0%	0%	0%	0%	
Engine 3	94%	79%	84%	93%	101%	101%	92%	94%	103%	104%	104%	105%	106%	105%	103%	
Engine 4	77%	72%	76%	70%	0%	0%	82%	88%	99%	99%	104%	99%	99%	99%	99%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	24	48	72	96	120	144	168	192	216	240	264	288	312	336	360	
Engine 1	23	47	71	95	119	143	152	176	200	224	248	272	296	320	341	
Engine 2	23	47	71	95	119	143	167	176	176	176	176	176	176	176	176	
Engine 3	23	47	71	95	119	143	167	191	215	239	263	287	311	335	359	
Engine 4	10	34	58	67	67	67	90	114	138	162	185	209	233	257	281	
Engine operating run hours total from 0 hours																
Engine 1	38,777	38,801	38,825	38,849	38,873	38,897	38,906	38,930	38,954	38,978	39,002	39,026	39,050	39,074	39,095	
Engine 2	38,751	38,775	38,799	38,823	38,847	38,871	38,895	38,904	38,904	38,904	38,904	38,904	38,904	38,904	38,904	
Engine 3	38,222	38,246	38,270	38,294	38,318	38,342	38,366	38,390	38,414	38,438	38,462	38,486	38,510	38,534	38,558	
Engine 4	37,501	37,525	37,549	37,558	37,558	37,558	37,581	37,605	37,629	37,653	37,676	37,700	37,724	37,748	37,772	
Cumulative availability, %																
Engine 1	96%	98%	99%	99%	99%	99%	90%	92%	93%	93%	94%	94%	95%	95%	95%	
Engine 2	96%	98%	99%	99%	99%	99%	99%	92%	81%	73%	67%	61%	56%	52%	49%	
Engine 3	96%	98%	99%	99%	99%	99%	99%	99%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	42%	71%	81%	70%	56%	47%	54%	59%	64%	68%	70%	73%	75%	76%	78%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	825	1,650	2,475	3,300	4,125	4,950	5,775	6,600	7,425	8,250	9,075	9,900	10,725	11,550	12,375	
Engine 1	771	1,399	2,065	2,829	3,670	4,493	5,114	5,878	6,721	7,571	8,427	9,280	10,141	11,003	11,792	
Engine 2	737	1,320	1,930	2,657	3,473	4,290	5,015	5,557	5,557	5,557	5,557	5,557	5,557	5,557	5,557	
Engine 3	778	1,427	2,116	2,883	3,715	4,545	5,307	6,078	6,929	7,790	8,651	9,513	10,388	11,253	12,103	
Engine 4	632	1,227	1,853	2,430	2,430	2,430	3,110	3,832	4,650	5,470	6,326	7,140	7,960	8,780	9,600	
Cumulative capacity factor, %																
Engine 1	93%	85%	83%	86%	89%	91%	89%	89%	91%	92%	93%	94%	95%	95%	95%	
Engine 2	89%	80%	78%	81%	84%	87%	87%	84%	75%	67%	61%	56%	52%	48%	45%	
Engine 3	94%	86%	85%	87%	90%	92%	92%	92%	93%	94%	95%	96%	97%	97%	98%	
Engine 4	77%	74%	75%	74%	59%	49%	54%	58%	63%	66%	70%	72%	74%	76%	78%	

	Tuesday 6/1/2010	Wednesday 6/2/2010	Thursday 6/3/2010	Friday 6/4/2010	Saturday 6/5/2010	Sunday 6/6/2010	Monday 6/7/2010	Tuesday 6/8/2010	Wednesday 6/9/2010	Thursday 6/10/2010	Friday 6/11/2010	Saturday 6/12/2010	Sunday 6/13/2010	Monday 6/14/2010	Tuesday 6/15/2010
Cumulative by Facility in month															
Max cumulative available engine run hours	96	192	288	384	480	576	672	768	864	960	1,056	1,152	1,248	1,344	1,440
Actual cumulative engine run hours	79	175	271	352	424	496	576	657	729	801	872	944	1,016	1,088	1,157
Cumulative Availability, %	82.3%	91.1%	94.1%	91.7%	88.3%	86.1%	85.7%	85.5%	84.4%	83.4%	82.6%	81.9%	81.4%	81.0%	80.3%
Max cumulative gross output, kWhr	79,200	158,400	237,600	316,800	396,000	475,200	554,400	633,600	712,800	792,000	871,200	950,400	1,029,600	1,108,800	1,188,000
Actual cumulative gross output, kWhr	59,366	121,265	181,218	240,993	301,072	360,461	417,777	477,060	537,608	598,671	659,965	720,945	782,538	843,947	900,945
Cumulative Capacity Factor	75.0%	76.6%	76.3%	76.1%	76.0%	75.9%	75.4%	75.3%	75.4%	75.6%	75.8%	75.9%	76.0%	76.1%	75.8%
Cumulative fuel input, MMBtu HHV	766	1,569	2,354	3,122	3,886	4,651	5,411	6,171	6,926	7,692	8,443	9,175	9,924	10,648	11,313
Cumulative gross output, kWhr	59,366	121,265	181,218	240,993	301,072	360,461	417,777	477,060	537,608	598,671	659,965	720,945	782,538	843,947	900,945
Heat Rate															
Daily heat rate, Btu/kWe gross LHV	11,615	11,678	11,787	11,566	11,447	11,596	11,936	11,540	11,225	11,292	11,030	10,806	10,947	10,613	10,503
Daily heat rate, Btu/kWe gross HHV	12,903	12,973	13,094	12,848	12,717	12,881	13,260	12,820	12,469	12,544	12,252	12,004	12,160	11,790	11,667
Cumulative heat rate, Btu/kWe gross LHV	11,615	11,647	11,693	11,662	11,619	11,615	11,659	11,644	11,597	11,566	11,516	11,456	11,416	11,358	11,304
Cumulative heat rate, Btu/kWe gross HHV	12,903	12,939	12,990	12,955	12,907	12,903	12,952	12,935	12,883	12,848	12,793	12,726	12,682	12,617	12,557
Cumulative by Facility starting Calendar Year															
Max cumulative available engine run hours	14,400	14,496	14,592	14,688	14,784	14,880	14,976	15,072	15,168	15,264	15,360	15,456	15,552	15,648	15,744
Actual cumulative engine run hours	13,629	13,725	13,821	13,902	13,974	14,046	14,118	14,190	14,262	14,334	14,406	14,478	14,550	14,622	14,694
Cumulative Availability, %	94.6%	94.7%	94.7%	94.6%	94.5%	94.4%	94.3%	94.3%	94.1%	94.0%	93.9%	93.8%	93.7%	93.5%	93.4%
Max cumulative gross output, kWhr	11,880,000	11,959,200	12,038,400	12,117,600	12,196,800	12,276,000	12,355,200	12,434,400	12,513,600	12,592,800	12,672,000	12,751,200	12,830,400	12,909,600	12,988,800
Actual cumulative gross output, kWhr	9,042,489	9,104,388	9,164,341	9,224,116	9,284,195	9,343,584	9,400,900	9,460,183	9,520,731	9,581,794	9,643,088	9,704,068	9,765,661	9,827,070	9,888,068
Cumulative Capacity Factor	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%
Cumulative fuel input, MMBtu HHV	125,178	125,981	126,766	127,534	128,298	129,063	129,823	130,583	131,338	132,104	132,855	133,587	134,336	135,060	135,725
Cumulative gross output, kWhr	9,042,489	9,104,388	9,164,341	9,224,116	9,284,195	9,343,584	9,400,900	9,460,183	9,520,731	9,581,794	9,643,088	9,704,068	9,765,661	9,827,070	9,888,068
Cumulative heat rate, Btu/kWe gross LHV	12,462	12,456	12,452	12,446	12,440	12,434	12,431	12,426	12,418	12,411	12,402	12,392	12,383	12,372	12,361
Cumulative heat rate, Btu/kWe gross HHV	13,843	13,837	13,833	13,826	13,819	13,813	13,810	13,803	13,795	13,787	13,777	13,766	13,756	13,744	13,732
Service															
Engine 1						Failed turbo									
Engine 2															
Engine 3															
Engine 4															
Oil - oil and filter change		NStar outage													Installation of add
Service - plugs, air filter, valve inspection and adjustment															Wells 31, 33, 25, 2
NSTAR Power Reports															
Date	Tuesday 6/1/2010	Wednesday 6/2/2010	Thursday 6/3/2010	Friday 6/4/2010	Saturday 6/5/2010	Sunday 6/6/2010	Monday 6/7/2010	Tuesday 6/8/2010	Wednesday 6/9/2010	Thursday 6/10/2010	Friday 6/11/2010	Saturday 6/12/2010	Sunday 6/13/2010	Monday 6/14/2010	Tuesday 6/15/2010
Hour															
1	2,431	2,625	2,490	2,457	2,465	2,468	1,645	2,472	2,444	2,483	2,478	2,468	2,474	2,476	1,632
2	2,432	2,622	2,490	2,460	2,467	2,469	1,671	2,469	2,449	2,483	2,477	2,468	2,480	2,476	1,633
3	2,431	2,618	2,489	2,460	2,466	2,465	2,123	2,466	2,450	2,483	2,477	2,474	2,485	2,477	1,738
4	2,432	2,617	2,487	2,458	2,468	2,467	2,427	2,467	2,449	2,483	2,478	2,475	2,486	2,477	2,410
5	2,433	2,611	2,488	2,459	2,467	2,465	2,429	2,467	2,448	2,483	2,477	2,474	2,488	2,477	2,431
6	2,436	2,611	2,491	2,458	2,466	2,468	2,433	2,468	2,451	2,484	2,479	2,475	2,483	2,478	2,433
7	2,435	2,578	2,491	2,458	2,467	2,467	2,441	2,467	2,458	2,485	2,480	2,476	2,485	2,478	2,431
8	2,437	2,579	2,490	2,457	2,469	2,467	2,440	2,480	2,475	2,484	2,479	2,474	2,487	2,479	2,436
9	2,440	2,581	2,489	2,359	2,457	2,464	2,440	2,410	2,481	2,485	2,479	2,473	2,488	2,477	2,436
10	2,437	2,574	2,455	2,465	2,456	2,461	2,431	2,471	2,479	2,481	2,476	2,474	2,489	2,474	2,437
11	2,439	2,517	2,352	2,459	2,461	2,461	2,427	2,474	2,480	2,481	2,263	2,472	2,486	2,472	2,335
12	2,438	2,499	2,511	2,462	2,462	2,459	2,429	2,472	2,476	2,479	2,438	2,472	2,476	2,457	2,487
13	2,438	2,497	2,494	2,460	2,465	2,459	2,429	2,470	2,475	2,479	2,441	2,471	2,476	2,460	2,513
14	2,661	2,505	2,475	2,461	2,464	2,460	2,426	2,468	2,476	2,479	2,450	2,471	2,476	2,456	2,196
15	2,618	2,506	2,470	2,463	2,466	2,460	2,425	2,464	2,475	2,478	2,465	2,472	2,475	2,443	2,391
16	2,581	2,487	2,457	2,461	2,462	2,459	2,524	2,470	2,476	2,476	2,470	2,472	2,475	2,446	2,378
17	2,573	2,478	2,452	2,460	2,463	2,459	2,585	2,471	2,475	2,479	2,474	2,473	2,476	2,461	2,388
18	2,570	2,481	2,450	2,461	2,464	2,465	2,538	2,467	2,478	2,480	2,474	2,473	2,475	2,460	2,365
19	2,565	2,482	2,454	2,460	2,463	2,465	2,539	2,464	2,483	2,479	2,475	2,473	2,476	2,460	2,359
20	2,562	2,484	2,454	2,460	2,459	2,466	2,532	2,461	2,483	2,479	2,475	2,474	2,475	2,460	2,334
21	2,570	2,482	2,454	2,460	2,459	2,463	2,471	2,465	2,483	2,479	2,471	2,473	2,476	2,459	2,302
22	922	2,486	2,452	2,458	2,464	2,460	2,467	2,465	2,482	2,478	2,469	2,473	2,475	2,458	2,287
23	1,169	2,489	2,455	2,457	2,467	2,457	2,465	2,454	2,482	2,477	2,468	2,473	2,475	2,463	2,277
24	2,615	2,490	2,456	2,462	2,465	2,013	2,466	2,447	2,483	2,478	2,468	2,474	2,476	2,119	2,268
TOTAL	57,065	60,899	59,246	58,935	59,132	58,667	57,203	59,149	59,291	59,535	59,081	59,347	59,513	58,843	54,897
Cumulative Output Sold, kWhr	57,065	117,964	177,210	236,145	295,277	353,944	411,147	470,296	529,587	589,122	648,203	707,550	767,063	825,906	880,803
Transformer and line efficiency	98.6%	100.8%	101.4%	101.1%	100.7%	101.1%	102.1%	102.4%	100.5%	100.1%	99.0%	99.9%	99.1%	98.3%	98.9%
Hourly average	2,378	2,537	2,469	2,456	2,464	2,444	2,383	2,465	2,470	2,481	2,462	2,473	2,480	2,452	2,287

JUNE 2010																
CNBE Daily Reports Summary Data																
	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	TOTAL
	6/16/2010	6/17/2010	6/18/2010	6/19/2010	6/20/2010	6/21/2010	6/22/2010	6/23/2010	6/24/2010	6/25/2010	6/26/2010	6/27/2010	6/28/2010	6/29/2010	6/30/2010	
Landfill Gas Flow to the Engines (KSCF)	1,452	1,388	1,396	1,392	1,450	1,444	1,457	1,434	1,429	1,443	1,462	1,444	1,385	1,433	1,440	43,723
Landfill Gas Flow to the Engines (MMBTU HHV)	735	716	710	713	744	738	739	732	721	715	729	724	701	714	711	22,155
Landfill Gas Flow to the Flare (KSCF)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Flow to the Flare (MMBTU HHV)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Landfill Gas Total Flow (KSCF)	1,452	1,388	1,396	1,392	1,450	1,444	1,457	1,434	1,429	1,443	1,462	1,444	1,385	1,433	1,440	43,723
Landfill Gas Total Flow (MMBTU HHV)	735	716	710	713	744	738	739	732	721	715	729	724	701	714	711	22,155
Average Methane Content (%)	50.0	51.0	50.3	50.6	50.7	50.5	50.1	50.4	49.8	48.9	49.3	49.6	50.0	49.2	48.8	50.1
Engine 1 Hours	15	11	24	5	-	-	-	10	9	-	-	-	14	24	24	477
Engine 2 Hours	14	24	24	24	24	24	24	24	24	24	24	24	14	-	1	469
Engine 3 Hours	24	15	-	19	24	24	24	24	24	24	24	24	24	24	24	681
Engine 4 Hours	24	24	24	24	24	24	24	24	24	24	24	24	24	23	23	639
Generator 1 Power Output (kWhr)	9,228	8,214	20,150	3,373	-	-	-	5,005	5,661	-	-	-	9,121	20,343	20,341	372,000
Generator 2 Power Output (kWhr)	9,929	18,919	19,781	19,803	19,788	19,631	19,679	17,516	17,312	19,503	19,717	19,495	10,091	-	-	355,670
Generator 3 Power Output (kWhr)	20,752	12,315	-	15,767	20,314	20,211	20,149	18,112	18,002	20,120	20,640	20,485	18,950	20,203	20,471	556,194
Generator 4 Power Output (kWhr)	19,732	18,788	19,771	19,770	19,696	19,668	19,600	17,326	17,344	19,660	19,854	19,635	17,993	19,399	17,539	497,136
Gross Power Output (kWhr)	60,078	58,563	59,964	58,837	59,894	59,852	59,833	58,323	58,954	59,922	60,731	60,290	56,648	60,441	58,802	1,792,077
Net Power Output (kWhr)	58,490	56,963	58,339	57,253	58,254	58,131	58,130	56,584	57,221	58,177	58,913	58,469	54,893	58,624	57,130	1,744,127
Power Sold as metered by NStar, (kWhr)	57,933	57,517	58,596	57,510	58,667	58,551	58,356	58,177	58,228	58,543	58,821	58,853	55,626	58,775	56,995	1,751,951
Offgrid RECs (kWhr)	1,588	1,600	1,625	1,584	1,640	1,721	1,703	1,739	1,733	1,745	1,818	1,821	1,755	1,817	1,672	47,950
Calculated Performance Results																
Daily																
Power output (kW average when running)																
Generator 1	615	747	840	675	-	-	-	501	629	-	-	-	652	848	848	
Generator 2	709	788	824	825	825	818	820	730	721	813	822	812	721	-	-	
Generator 3	865	821	-	830	846	842	840	755	750	838	860	854	790	842	853	
Generator 4	822	783	824	824	821	820	817	722	723	819	827	818	750	843	763	
Power output (kW average over 24-hrs)																
Facility Gross	2,503	2,440	2,499	2,452	2,496	2,494	2,493	2,430	2,456	2,497	2,530	2,512	2,360	2,518	2,450	
Facility Net	2,437	2,373	2,431	2,386	2,427	2,422	2,422	2,358	2,384	2,424	2,455	2,436	2,287	2,443	2,380	
In-plant load	66	67	68	66	68	72	71	72	72	73	76	76	73	76	70	
Daily availability factor																
Facility	80%	77%	75%	75%	75%	75%	75%	85%	84%	75%	75%	75%	79%	74%	75%	
Engine 1	63%	46%	100%	21%	0%	0%	0%	42%	38%	0%	0%	0%	58%	100%	100%	
Engine 2	58%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	58%	0%	4%	
Engine 3	100%	63%	0%	79%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Engine 4	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	96%	96%	
Daily capacity factor																
Facility	76%	74%	76%	74%	76%	76%	76%	74%	74%	76%	77%	76%	72%	76%	74%	
Engine 1	75%	91%	102%	82%	0%	0%	0%	61%	76%	0%	0%	0%	79%	103%	103%	
Engine 2	86%	96%	100%	100%	100%	99%	99%	88%	87%	99%	100%	98%	87%	0%	0%	
Engine 3	105%	100%	0%	101%	103%	102%	102%	91%	102%	104%	103%	96%	102%	103%	103%	
Engine 4	100%	95%	100%	100%	99%	99%	99%	88%	88%	99%	100%	99%	91%	102%	92%	
Cumulative by engine																
Engine operating run hours in the month																
Max Cumulative Available, hours	384	408	432	456	480	504	528	552	576	600	624	648	672	696	720	
Engine 1	356	367	391	396	396	396	396	406	415	415	415	415	429	453	477	
Engine 2	190	214	238	262	286	310	334	358	382	406	430	454	468	468	469	
Engine 3	383	398	398	417	441	465	489	513	537	561	585	609	633	657	681	
Engine 4	305	329	353	377	401	425	449	473	497	521	545	569	593	616	639	
Engine operating run hours total from 0 hours																
Engine 1	39,110	39,121	39,145	39,150	39,150	39,150	39,150	39,160	39,169	39,169	39,169	39,169	39,183	39,207	39,231	
Engine 2	38,918	38,942	38,966	38,990	39,014	39,038	39,062	39,086	39,110	39,134	39,158	39,182	39,196	39,196	39,197	
Engine 3	38,582	38,597	38,597	38,616	38,640	38,668	38,712	38,736	38,760	38,784	38,808	38,832	38,856	38,880	38,880	
Engine 4	37,796	37,820	37,844	37,868	37,892	37,916	37,940	37,964	37,988	38,012	38,036	38,060	38,084	38,107	38,130	
Cumulative availability, %																
Engine 1	93%	90%	91%	87%	83%	79%	75%	74%	72%	69%	67%	64%	64%	65%	66%	
Engine 2	49%	52%	55%	57%	60%	62%	63%	65%	66%	68%	69%	70%	70%	67%	65%	
Engine 3	100%	98%	92%	91%	92%	93%	93%	94%	94%	94%	94%	94%	94%	94%	95%	
Engine 4	79%	81%	82%	83%	84%	84%	85%	86%	86%	87%	87%	88%	88%	89%	89%	
Engine cumulative gross output, kWhr																
Max cumulative capacity one engine	13,200	14,025	14,850	15,675	16,500	17,325	18,150	18,975	19,800	20,625	21,450	22,275	23,100	23,925	24,750	
Engine 1	12,408	13,154	13,994	14,668	14,668	14,668	15,169	15,798	15,798	15,798	15,798	15,798	16,449	17,297	18,145	
Engine 2	6,266	7,055	7,879	8,704	9,528	10,346	11,166	11,896	12,618	13,430	14,252	15,064	15,785	15,785	15,785	
Engine 3	12,968	13,789	13,789	14,619	15,465	16,307	17,147	17,902	18,652	19,490	20,350	21,204	21,993	22,835	23,688	
Engine 4	10,423	11,205	12,029	12,853	13,674	14,493	15,310	16,032	16,754	17,573	18,401	19,219	19,969	20,812	21,575	
Cumulative capacity factor, %																
Engine 1	94%	94%	94%	94%	89%	85%	81%	80%	80%	77%	74%	71%	71%	72%	73%	
Engine 2	47%	50%	53%	56%	58%	60%	62%	63%	64%	65%	66%	68%	68%	66%	64%	
Engine 3	98%	98%	93%	93%	94%	94%	94%	94%	94%	94%	95%	95%	95%	95%	96%	
Engine 4	79%	80%	81%	82%	83%	84%	84%	84%	85%	85%	86%	86%	86%	87%	87%	

	Wednesday 6/16/2010	Thursday 6/17/2010	Friday 6/18/2010	Saturday 6/19/2010	Sunday 6/20/2010	Monday 6/21/2010	Tuesday 6/22/2010	Wednesday 6/23/2010	Thursday 6/24/2010	Friday 6/25/2010	Saturday 6/26/2010	Sunday 6/27/2010	Monday 6/28/2010	Tuesday 6/29/2010	Wednesday 6/30/2010	TOTAL
Cumulative by Facility in month																
Max cumulative available engine run hours	1,536	1,632	1,728	1,824	1,920	2,016	2,112	2,208	2,304	2,400	2,496	2,592	2,688	2,784	2,880	
Actual cumulative engine run hours	1,234	1,308	1,380	1,452	1,524	1,596	1,668	1,750	1,831	1,903	1,975	2,047	2,123	2,194	2,266	
Cumulative Availability, %	80.3%	80.1%	79.9%	79.6%	79.4%	79.2%	79.0%	79.3%	79.5%	79.3%	79.1%	79.0%	79.0%	78.8%	78.7%	
Max cumulative gross output, kWhr	1,267,200	1,346,400	1,425,600	1,504,800	1,584,000	1,663,200	1,742,400	1,821,600	1,900,800	1,980,000	2,059,200	2,138,400	2,217,600	2,296,800	2,376,000	
Actual cumulative gross output, kWhr	961,023	1,019,586	1,079,550	1,138,387	1,198,281	1,258,133	1,317,966	1,376,289	1,435,243	1,495,165	1,555,896	1,616,186	1,672,834	1,733,275	1,792,077	
Cumulative Capacity Factor	75.8%	75.7%	75.7%	75.7%	75.6%	75.6%	75.6%	75.6%	75.5%	75.5%	75.6%	75.6%	75.4%	75.5%	75.4%	
Cumulative fuel input, MMBtu HHV	12,048	12,764	13,474	14,187	14,931	15,669	16,408	17,140	17,861	18,576	19,305	20,029	20,730	21,444	22,155	
Cumulative gross output, kWhr	961,023	1,019,586	1,079,550	1,138,387	1,198,281	1,258,133	1,317,966	1,376,289	1,435,243	1,495,165	1,555,896	1,616,186	1,672,834	1,733,275	1,792,077	
Heat Rate																
Daily heat rate, Btu/kWe gross LHV	11,013	11,006	10,659	10,909	11,182	11,100	11,118	11,298	11,009	10,741	10,806	10,810	11,140	10,634	10,885	
Daily heat rate, Btu/kWe gross HHV	12,234	12,226	11,840	12,118	12,422	12,330	12,351	12,551	12,230	11,932	12,004	12,009	12,375	11,813	12,091	
Cumulative heat rate, Btu/kWe gross LHV	11,285	11,269	11,235	11,219	11,217	11,211	11,207	11,211	11,203	11,184	11,169	11,156	11,155	11,137	11,129	
Cumulative heat rate, Btu/kWe gross HHV	12,537	12,519	12,481	12,462	12,460	12,454	12,449	12,454	12,445	12,424	12,408	12,393	12,392	12,372	12,363	
Cumulative by Facility starting Calendar Year																
Max cumulative available engine run hours	15,840	15,936	16,032	16,128	16,224	16,320	16,416	16,512	16,608	16,704	16,800	16,896	16,992	17,088	17,184	
Actual cumulative engine run hours	14,784	14,858	14,930	15,002	15,074	15,146	15,218	15,300	15,381	15,453	15,525	15,597	15,673	15,744	15,816	
Cumulative Availability, %	93.3%	93.2%	93.1%	93.0%	92.9%	92.8%	92.7%	92.7%	92.6%	92.5%	92.4%	92.3%	92.2%	92.1%	92.0%	
Max cumulative gross output, kWhr	13,068,000	13,147,200	13,226,400	13,305,600	13,384,800	13,464,000	13,543,200	13,622,400	13,701,600	13,780,800	13,860,000	13,939,200	14,018,400	14,097,600	14,176,800	
Actual cumulative gross output, kWhr	9,944,146	10,002,709	10,062,673	10,121,510	10,181,404	10,241,256	10,301,089	10,359,412	10,418,366	10,478,288	10,539,019	10,599,309	10,655,957	10,716,398	10,775,200	
Cumulative Capacity Factor	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.1%	76.0%	76.0%	76.0%	76.0%	76.0%	76.0%	76.0%	
Cumulative fuel input, MMBtu HHV	136,460	137,176	137,886	138,599	139,343	140,081	140,820	141,552	142,273	142,988	143,717	144,441	145,142	145,856	146,567	
Cumulative gross output, kWhr	9,944,146	10,002,709	10,062,673	10,121,510	10,181,404	10,241,256	10,301,089	10,359,412	10,418,366	10,478,288	10,539,019	10,599,309	10,655,957	10,716,398	10,775,200	
Cumulative heat rate, Btu/kWe gross LHV	12,353	12,345	12,335	12,327	12,320	12,313	12,306	12,300	12,293	12,284	12,276	12,267	12,261	12,252	12,245	
Cumulative heat rate, Btu/kWe gross HHV	13,723	13,714	13,703	13,694	13,686	13,678	13,670	13,664	13,656	13,646	13,637	13,627	13,621	13,611	13,602	
Service																
Engine 1																
Engine 2																
Engine 3																
Engine 4																
Oil - oil and filter change																
Service - plugs, air filter, valve inspection and adjust																
Sounding wells and well balancing, and connection to new cell by leachate cleanout Installation of additional pump in 13A																
Hourly Data																
Hour	6/16/2010	6/17/2010	6/18/2010	6/19/2010	6/20/2010	6/21/2010	6/22/2010	6/23/2010	6/24/2010	6/25/2010	6/26/2010	6/27/2010	6/28/2010	6/29/2010	6/30/2010	TOTAL
1	2,264	2,439	2,444	2,356	2,449	2,448	2,436	2,429	2,420	2,426	2,453	2,456	2,456	2,452	2,465	
2	2,255	2,439	2,444	2,500	2,447	2,449	2,436	2,428	2,426	2,428	2,453	2,455	2,456	2,449	2,192	
3	2,248	2,442	2,445	2,550	2,447	2,449	2,433	2,429	2,426	2,428	2,455	2,453	2,456	2,448	1,714	
4	2,242	2,440	2,443	2,314	2,445	2,449	2,440	2,428	2,423	2,429	2,454	2,455	2,455	2,448	1,935	
5	2,237	2,441	2,470	1,610	2,444	2,448	2,446	2,429	2,426	2,424	2,453	2,456	2,457	2,446	2,105	
6	2,240	2,441	2,455	2,175	2,445	2,449	2,448	2,431	2,425	2,439	2,456	2,458	2,455	2,443	2,443	
7	2,264	2,441	2,445	2,447	2,447	2,450	2,450	2,431	2,423	2,444	2,456	2,458	2,458	2,444	2,456	
8	2,281	2,441	2,447	2,448	2,449	2,448	2,448	2,431	2,421	2,446	2,454	2,455	2,453	2,448	2,456	
9	2,316	2,439	2,440	2,450	2,444	2,443	2,439	2,426	2,403	2,448	2,453	2,454	2,445	2,455	2,453	
10	2,360	2,434	2,436	2,447	2,441	2,431	2,436	2,425	2,432	2,446	2,453	2,453	2,445	2,392	2,450	
11	2,498	2,288	2,436	2,446	2,441	2,427	2,434	2,423	2,418	2,445	2,451	2,452	2,350	2,330	2,450	
12	2,707	1,085	2,433	2,442	2,441	2,426	2,433	2,421	2,416	2,444	2,446	2,452	2,332	2,461	2,454	
13	2,699	2,423	2,436	2,442	2,439	2,422	2,426	2,423	2,411	2,444	2,447	2,449	2,346	2,461	2,448	
14	2,686	2,647	2,436	2,442	2,440	2,433	2,428	2,419	2,422	2,442	2,447	2,446	2,367	2,459	2,462	
15	2,668	2,735	2,436	2,444	2,442	2,433	2,411	2,419	2,429	2,441	2,446	2,445	2,411	2,460	2,454	
16	2,440	2,431	2,436	2,444	2,442	2,438	2,412	2,437	2,430	2,440	2,447	2,446	1,103	2,462	2,454	
17	2,443	2,440	2,436	2,443	2,444	2,438	2,417	2,417	2,435	2,441	2,447	2,447	1,093	2,464	2,455	
18	2,443	2,443	2,437	2,442	2,444	2,439	2,425	2,424	2,433	2,439	2,449	2,443	2,426	2,464	2,452	
19	2,442	2,443	2,439	2,443	2,446	2,439	2,428	2,417	2,436	2,436	2,445	2,445	2,449	2,465	2,450	
20	2,442	2,446	2,439	2,446	2,445	2,438	2,426	2,418	2,441	2,441	2,450	2,460	2,448	2,465	2,445	
21	2,441	2,445	2,438	2,442	2,446	2,438	2,425	2,417	2,437	2,443	2,447	2,454	2,440	2,465	2,443	
22	2,440	2,422	2,441	2,443	2,447	2,442	2,428	2,418	2,434	2,437	2,452	2,455	2,435	2,465	2,452	
23	2,438	2,428	2,441	2,445	2,445	2,436	2,426	2,418	2,432	2,436	2,448	2,454	2,443	2,464	2,452	
24	2,439	2,444	2,443	2,449	2,447	2,438	2,425	2,419	2,429	2,454	2,459	2,453	2,447	2,465	2,455	
TOTAL	57,933	57,517	58,596	57,510	58,667	58,551	58,356	58,177	58,228	58,543	58,821	58,853	55,626	58,775	56,995	
Cumulative Output Sold, kWhr	938,736	996,253	1,054,849	1,112,359	1,171,026	1,229,577	1,287,933	1,346,110	1,404,338	1,462,881	1,521,702	1,580,555	1,636,181	1,694,956	1,751,951	
Transformer and line efficiency	99.0%	101.0%	100.4%	100.4%	100.7%	100.7%	100.4%	102.8%	101.8%	100.6%	99.8%	100.7%	101.3%	100.3%	99.8%	0.0%
Hourly average	2,414	2,397	2,442	2,396	2,444	2,440	2,432	2,424	2,426	2,439	2,451	2,452	2,318	2,449	2,375	2,433

EXHIBIT 6

Calibration records of the LFG flow rate and compilation of methane content calibration reports for the California analytical analyzer for the first half 2010

Landfill Gas Flow Calculation						
Crapo Hill Landfill, New Bedford/Dartmouth, Massachusetts						
Note: Calculation of volumetric flow of LFG through a pipe using a pitot tube and manometer.						
	Engine 1, kW	675	800	670	700	850
	Engine 2, kW	700	800	670	650	-
	Engine 3, kW	675	800	670	730	845
	Engine 4, kW	700	200	670	700	835
	Gross, kW	2,750	2,600	2,680	2,780	2,530
MEASURING INSTRUMENT:	Pitot Tube:	166	166	166	166	166
	Manometer:	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II	Dwyer Mark II
DATE OF MEASUREMENT:		6-Jan-10	17-Feb-10	25-Mar-10	18-May-10	11-Jun-10
TIME OF MEASUREMENT:		13:20	10:30	2:15	12:30	14:15
PARAMETERS	UNITS	VALUES	VALUES	VALUES	VALUES	VALUES
Pipe dimensions						
	Inside Diameter	inches	10.420	10.420	10.420	10.420
	Area of cross section	square feet	0.5922	0.5922	0.5922	0.5922
Flow Calculation						
	Kp	pitot tube constant	ft/sec((lb/lb-mole)(in. Hg)/(R)(in H2O))^1/2	85.49	85.49	85.49
	Cp	Pitot tube coefficient	dimensionless	1.00	1.00	1.00
	dP	Average velocity pressure of stack gas	in H2O	0.281	0.274	0.245
Blower Inlet						
	Ts	Stack temperature	Degrees Fahrenheit	70	68	68
			Degrees Rankine	530	528	528
	Pg	Stack static pressure	inch H2O	-56	-62	-60
			inch Hg	(4.12)	(4.56)	(4.41)
	Ps	Absolute stack gas pressure	inch Hg	25.40	24.89	25.48
Blower Outlet						
	Ts	Stack temperature	Degrees Fahrenheit	110	110	110
			Degrees Rankine	570	570	570
	Pg	Stack static pressure	inch H2O	44.3	47.1	47.1
			inch Hg	3.26	3.46	3.46
			psig	1.60	1.70	1.70
	Pbar	Barometric pressure	inch Hg	29.52	29.45	29.89
	Ps	Absolute stack gas pressure	inch Hg	32.78	32.91	33.35
	Ms	Molecular weight of stack gas, wet	lb/lb-mole	28.05	28.24	28.20
	Vs	Average stack gas velocity	feet per second	39.1	38.8	36.3
	Qact	Volumetric Flow	actual cubic feet per minute	1,389	1,378	1,289
	Qstd	Volumetric Flow at actual methane content	standard cubic feet per minute *	1,175	1,146	1,097
	Qstd corr	Volumetric Flow at 50% methane	standard cubic feet per minute **	1,229	1,191	1,167
	Ht HHV	Heat input	MMBtu per hour HHV	37.32	36.15	35.42
	Ht LHV	Heat input	MMBtu per hour LHV	33.59	32.55	31.88
		Methane Content	%, vol/vol wet	52.30%	51.96%	53.15%
	Diff. between pitot tube and orifice reading:			0.3%	-2.8%	-2.8%
					0.9%	-1.0%
	dP	Delta pressure across orifice plate	inches H2O	11.10	11.20	10.00
	Qact	Volumetric Flow	acfm	1,154	1,156	1,092
	Qstd	Volumetric Flow at actual methane content	standard cubic feet per minute *	1,171	1,178	1,128
	Qstd	Volumetric Flow at 50% methane	standard cubic feet per minute **	1,225	1,224	1,199
	Ht HHV	Heat input	MMBtu per hour HHV	37.20	37.16	36.40
	Ht LHV	Heat input	MMBtu per hour LHV	33.49	33.45	32.76
* Standard conditions are corrected to 68 degrees F and 29.92 in Hg at actual methane content.						
** Standard conditions corrected to 50 % methane content.						
Input values are in blue or bold.						
Calculated output values are in black or not bold.						
Calculation Formulas:						
$Vs = Kp \cdot Cp \cdot (\sqrt{dP}) \cdot \sqrt{(Ts / (Ps \cdot Ms))}$						
$Qact = Vs \cdot A \cdot 60$						
$Qstd = Qact \cdot Tstd / Ts \cdot Ps / Pstd$						
$Flow, ACFM = 96.3221 \cdot \sqrt{Qact} \cdot \sqrt{dP} \cdot \sqrt{(460 + Temperature)} / (2.703 \cdot (Pressure + 14.7))$						
Conversions and constants						
13.5958 in H2O/in Hg						
1 PSI = 2.036 in HG						
1 PSI = 27.68 in WG						
Tstd = 528 degrees R						
Pstd = 29.92 in Hg						
Methane heat content = 1,012 BTU per scf HHV						
Methane heat content = 911 BTU per scf LHV						

Landfill Gas Flow Measurements					
Crapo Hill Landfill, New Bedford/Dartmouth, Massachusetts					
Measurements by	TY/RB	TY/RB	TY/RB	TY/RB	TY/RB
Date	6-Jan-10	17-Feb-10	25-Mar-10	18-May-10	11-Jun-10
Time	13:20	10:30	2:15	12:30	14:15
Flow valve					
Pipe inside diameter, inches	10.42	10.42	10.42	10.42	10.42
Orifice measurement, cfm	NA	NA	NA	NA	NA
Ambient Temperature, F	57	40	40	55	65
Barometric Pressure, In Hg	29.52	29.45	29.89	30.12	30.14
Blower Inlet Temperature, F	70	68	68	78	80
Outlet Temperature, F	110	110	110	110	114
Blower Inlet Pressure (SP), In H2O	-56	-62	-60	-63	-55
Blower Outlet Pressure, PSIG	1.60	1.70	1.70	1.70	1.70
Blower Outlet Pressure, In H2O	44.29	47.06	47.06	47.06	47.06
Measurement					
Manometer					
Pitot Tube					
Velocity Pressure (dP)					
Point					
1	0.26	0.26	0.24	0.26	0.2
2	0.28	0.27	0.24	0.26	0.21
3	0.28	0.27	0.24	0.27	0.21
4	0.28	0.28	0.24	0.27	0.21
5	0.28	0.28	0.24	0.27	0.21
6	0.28	0.28	0.25	0.28	0.21
7	0.3	0.28	0.25	0.28	0.21
8	0.29	0.27	0.26	0.285	0.21
9					
Average	0.281	0.274	0.245	0.272	0.209
Gas Composition					
Compound, %v/v					
Methane (CH4)	52.3%	52.0%	53.2%	52.3%	50.9%
Carbon dioxide (CO2)	42.0%	41.7%	42.5%	42.2%	39.1%
Oxygen (O2)	0.40%	0.70%	0.45%	0.70%	0.08%
Balance gas	5.30%	5.60%	3.95%	4.82%	10.00%
Total	100.0%	100.0%	100.0%	100.0%	100.0%
Moisture (H2O) (included in balance gas)	2.3%	2.3%	2.3%	3.3%	3.5%
Molecular weight, lb/lb-mole wet	28.23	28.24	28.20	28.16	27.81
H2S, PPMV	150	160	160	120	140

